### **DATASHEET - NZM2/3-XUVHIV**



Undervoltage release, +2early N/O, for delay unit

Part no. NZM2/3-XUVHIV Catalog No. 259684



**Delivery program** 

| zomony program     |  |
|--------------------|--|
| Product range      | Accessories  |
| Accessories        | Undervoltage release   |
| Accessories        | Undervoltage release for use with delay unit UVU   |
| Standard/Approval  | IEC  |
| Construction size  | NZM2/3   |
| Description        | Combination of separate delay unit and special releases. For use with emergency-stop devices in connection with an emergency-stop button. not UL/CSA approved Special releases for combining with separate delay time. UVU-NZM delay unit is additionally required. Cannot be installed simultaneously with separate NZMXHIV early-make auxiliary contact or NZMXA shunt release. Cannot be used in conjunction with NZMXR remote operator. Early make of auxiliary contact on switching on and off (manual operation): approx. 20 ms. |
| Connection type    | With bolt connection   |
| Auxiliary contacts | with 2 early-make auxiliary contacts   |
| For use with       | NZM2(-4), N(S)2(-4)<br>NZM3(-4), N(S)3(-4)   |

# Technical data

Undervoltage releases, off-delayed

| Rated operational voltage                 | U <sub>e</sub> | V               |                                      |
|---|----------------|-----------------|--------------------------------------|
|   | U <sub>e</sub> | V DC            | 18                                   |
| Terminal capacities                       |                | $mm^2$          |                                      |
| Solid or flexible conductor, with ferrule |                | mm <sup>2</sup> | 1 x (0,75 - 2,5)<br>2 x (0,75 - 2,5) |
|   |                | AWG             | 1 x (18 14)<br>2 x (18 14)           |

# **Design verification as per IEC/EN 61439**

| 20.g.: 100u.io 40 por 120, 211 01 100  |  |
|--|--|
| EC/EN 61439 design verification  |  |
| 10.2 Strength of materials and parts   |  |
| 10.2.2 Corrosion resistance  | Meets the product standard's requirements.                         |
| 10.2.3.1 Verification of thermal stability of enclosures   | Meets the product standard's requirements.                         |
| 10.2.3.2 Verification of resistance of insulating materials to normal heat   | Meets the product standard's requirements.                         |
| 10.2.3.3 Verification of resistance of insulating materials to abnormal heat and fire due to internal electric effects | Meets the product standard's requirements.                         |
| 10.2.4 Resistance to ultra-violet (UV) radiation   | Meets the product standard's requirements.                         |
| 10.2.5 Lifting   | Does not apply, since the entire switchgear needs to be evaluated. |
| 10.2.6 Mechanical impact   | Does not apply, since the entire switchgear needs to be evaluated. |
| 10.2.7 Inscriptions  | Meets the product standard's requirements.                         |
| 10.3 Degree of protection of ASSEMBLIES  | Does not apply, since the entire switchgear needs to be evaluated. |
| 10.4 Clearances and creepage distances   | Meets the product standard's requirements.                         |
| 10.5 Protection against electric shock   | Does not apply, since the entire switchgear needs to be evaluated. |
| 10.6 Incorporation of switching devices and components   | Does not apply, since the entire switchgear needs to be evaluated. |
| 10.7 Internal electrical circuits and connections  | Is the panel builder's responsibility.                             |

| 10.8 Connections for external conductors                 | Is the panel builder's responsibility.   |
|--|--|
| 10.9 Insulation properties                               |  |
| 10.9.2 Power-frequency electric strength                 | Is the panel builder's responsibility.   |
| 10.9.3 Impulse withstand voltage                         | Is the panel builder's responsibility.   |
| 10.9.4 Testing of enclosures made of insulating material | Is the panel builder's responsibility.   |
| 10.10 Temperature rise                                   | The panel builder is responsible for the temperature rise calculation. Eaton will provide heat dissipation data for the devices. |
| 10.11 Short-circuit rating                               | Is the panel builder's responsibility. The specifications for the switchgear must be observed.                                   |
| 10.12 Electromagnetic compatibility                      | Is the panel builder's responsibility. The specifications for the switchgear must be observed.                                   |
| 10.13 Mechanical function                                | The device meets the requirements, provided the information in the instruction leaflet (IL) is observed.                         |

#### **Technical data ETIM 7.0**

| Low-voltage industrial components (EG000017) / Under voltage coil (EC001022)   |   |                  |  |  |
|--|---|------------------|--|--|
| Electric engineering, automation, process control engineering / Low-voltage switch technology / Circuit breaker (LV < 1 kV) / Undervoltage trip (ecl@ss10.0.1-27-37-04-17 [AKF015013]) |   |                  |  |  |
| Rated control supply voltage Us at AC 50HZ   | V | 0 - 0            |  |  |
| Rated control supply voltage Us at AC 60HZ   | V | 0 - 0            |  |  |
| Rated control supply voltage Us at DC  | V | 0 - 0            |  |  |
| Voltage type for actuating   |   | DC               |  |  |
| Type of electric connection  |   | Screw connection |  |  |
| Number of contacts as normally open contact  |   | 1                |  |  |
| Number of contacts as normally closed contact  |   | 0                |  |  |
| Number of contacts as change-over contact  |   | 0                |  |  |
| Delayed  |   | Yes              |  |  |
| Suitable for power circuit breaker   |   | Yes              |  |  |
| Suitable for off-load switch   |   | Yes              |  |  |
| Suitable for motor safety switch   |   | No               |  |  |
| Suitable for overload relay  |   | No               |  |  |
|  |   |                  |  |  |

#### **Approvals**

| Product Standards           | UL489; CSA-C22.2 No. 5-09; IEC60947, CE marking |
|-----------------------------|---|
| UL File No.                 | E140305   |
| UL Category Control No.     | DIHS  |
| CSA File No.                | 022086  |
| CSA Class No.               | 1437-01   |
| North America Certification | UL listed, CSA certified                        |

#### **Additional product information (links)**

IL01208005Z (AWA1230-1915) Shunt release, Undervoltage release, Early-make auxiliary contact

IL01208005Z (AWA1230-1915) Shunt release, Undervoltage release, Early-make auxiliary contact ftp://ftp.moeller.net/DOCUMENTATION/AWA\_INSTRUCTIONS/IL01208005Z2018\_02.pdf