Box terminal, 4p, up to 160 A

Part no. NZM2-4-160-XKC

266755

EL Number 4300373

(Norway)



(Norway) General specifications	
Product name	Estan Maellar series NZM connection time
	Eaton Moeller series NZM connection type
Part no.	NZM2-4-160-XKC
EAN De la	4015082667559
Product Length/Depth	60 millimetre
Product height	45 millimetre
Product width	70 millimetre
Product weight	0.3 kilogram
Compliances	IEC RoHS conform
Product Tradename	NZM
Product Type	Accessories
Product Sub Type	Connection type
elivery program	
Туре	Accessory Box terminal
Number of poles	Four-pole
Amperage Rating	≦ 160 A
Frame	NZM2
Suitable for	Copper cable Four-pole
Used with	NZM2(-4), PN2(-4), N(S)2(-4)
echnical Data - Mechanical - Terminals	
Terminal capacity (stranded cable)	Up to 95 mm² can be connected depending on the cable manufacturer. 12 - 350 AWG/kcmil (1x) 10 mm² - 185 mm² (1x) 4 mm² - 70 mm² (2x)
Terminal capacity (copper strip)	2 segments of 9 mm x 0.8 mm - 10 segments of 16 mm x 0.8 mm or 8 segments of 15.5 mm x 0.8 mm (2x)
esign verification as per IEC/EN 61439	
10.2.2 Corrosion resistance	Meets the product standard's requirements.
10.2.3.1 Verification of thermal stability of enclosures	Meets the product standard's requirements.
10.2.3.2 Verification of resistance of insulating materials to normal heat	Meets the product standard's requirements.
10.2.3.3 Resist. of insul. mat. to abnormal heat/fire by internal elect. effects	Meets the product standard's requirements.
10.2.4 Resistance to ultra-violet (UV) radiation	Meets the product standard's requirements.
10.2.5 Lifting	Does not apply, since the entire switchgear needs to be evaluated.
10.2.6 Mechanical impact	Does not apply, since the entire switchgear needs to be evaluated.
10.2.7 Inscriptions	Meets the product standard's requirements.
10.3 Degree of protection of assemblies	Does not apply, since the entire switchgear needs to be evaluated.
10.4 Clearances and creepage distances	Meets the product standard's requirements.
10.5 Protection against electric shock	Does not apply, since the entire switchgear needs to be evaluated.
10.6 Incorporation of switching devices and components	Does not apply, since the entire switchgear needs to be evaluated.
10.7 Internal electrical circuits and connections	Is the panel builder's responsibility.
10.8 Connections for external conductors	Is the panel builder's responsibility.
10.9.2 Power-frequency electric strength	Is the panel builder's responsibility.
10.9.3 Impulse withstand voltage	Is the panel builder's responsibility.
10.9.4 Testing of enclosures made of insulating material	Is the panel builder's responsibility.
10.10 Temperature rise	The panel builder is responsible for the temperature rise calculation. Eaton will provide heat dissipation data for the devices.
10.11 Short-circuit rating	Is the panel builder's responsibility. The specifications for the switchgear must lobserved.

10.12 Electromagnetic compatibility	Is the panel builder's responsibility. The specifications for the switchgear must be observed.
10.13 Mechanical function	The device meets the requirements, provided the information in the instruction leaflet (IL) is observed.
Additional information	
Model	Other

Technical data ETIM 9.0

100041 4444 211111 010		
Low-voltage industrial components (EG000017) / Wiring set for power circuit breaker (EC002050)		
Electric engineering, automation, process control engineering / Low-voltage switch technology / Circuit breaker (LV < 1 kV) / Wiring set for circuit breaker (ecl@ss13-27-37-04-24 [ACN957016])		
Suitable for number of poles	4	
Model	Other	