### **DATASHEET - HR518**



Actuating roller lever, AT4, 50 mm, With roller from insulated material, I 50 mm, For use with R-AT4



Part no.HR518Catalog No.048106Alternate CatalogHR518No.No.

## **Delivery program**

| Basic function       |   |    | Components   |
|----------------------|---|----|--|
| Part group reference |   |    | AT4  |
| Product range        |   |    | Actuators  |
| Function             |   |    | actuating roller lever   |
| Diameter             | Ø | mm | 50   |
| Description          |   |    | For adding R-AT4 rotary drive<br>With roller from insulated material |
| Lever length         | L | mm | 50   |
| For use with         |   |    | R-AT4  |

# Design verification as per IEC/EN 61439

| Technical data for design verification  |                   |    |   |
|---|-------------------|----|---|
| Rated operational current for specified heat dissipation  | In                | А  | 0   |
| Heat dissipation per pole, current-dependent  | P <sub>vid</sub>  | W  | 0   |
| Equipment heat dissipation, current-dependent   | P <sub>vid</sub>  | W  | 0   |
| Static heat dissipation, non-current-dependent  | P <sub>vs</sub>   | w  | 0   |
| Heat dissipation capacity   | P <sub>diss</sub> | w  | 0   |
| Operating ambient temperature min.  |                   | °C | -25   |
| Operating ambient temperature max.  |                   | °C | 70  |
| IEC/EN 61439 design verification  |                   |    |   |
| 10.2 Strength of materials and parts  |                   |    |   |
| 10.2.2 Corrosion resistance   |                   |    | Meets the product standard's requirements.  |
| 10.2.3.1 Verification of thermal stability of enclosures  |                   |    | Meets the product standard's requirements.  |
| 10.2.3.2 Verification of resistance of insulating materials to normal heat  |                   |    | Meets the product standard's requirements.  |
| 10.2.3.3 Verification of resistance of insulating materials to abnormal heat<br>and fire due to internal electric effects |                   |    | Meets the product standard's requirements.  |
| 10.2.4 Resistance to ultra-violet (UV) radiation  |                   |    | Please enquire  |
| 10.2.5 Lifting  |                   |    | Does not apply, since the entire switchgear needs to be evaluated.                                |
| 10.2.6 Mechanical impact  |                   |    | Does not apply, since the entire switchgear needs to be evaluated.                                |
| 10.2.7 Inscriptions   |                   |    | Meets the product standard's requirements.  |
| 10.3 Degree of protection of ASSEMBLIES   |                   |    | Does not apply, since the entire switchgear needs to be evaluated.                                |
| 10.4 Clearances and creepage distances  |                   |    | Meets the product standard's requirements.  |
| 10.5 Protection against electric shock  |                   |    | Does not apply, since the entire switchgear needs to be evaluated.                                |
| 10.6 Incorporation of switching devices and components  |                   |    | Does not apply, since the entire switchgear needs to be evaluated.                                |
| 10.7 Internal electrical circuits and connections   |                   |    | Is the panel builder's responsibility.  |
| 10.8 Connections for external conductors  |                   |    | Is the panel builder's responsibility.  |
| 10.9 Insulation properties  |                   |    |   |
| 10.9.2 Power-frequency electric strength  |                   |    | Is the panel builder's responsibility.  |
| 10.9.3 Impulse withstand voltage  |                   |    | Is the panel builder's responsibility.  |
| 10.9.4 Testing of enclosures made of insulating material  |                   |    | Is the panel builder's responsibility.  |
| 10.10 Temperature rise  |                   |    | Not applicable.   |
| 10.11 Short-circuit rating  |                   |    | Is the panel builder's responsibility. The specifications for the switchgear must be observed.    |
| 10.12 Electromagnetic compatibility   |                   |    | Is the panel builder's responsibility. The specifications for the switchgear must be<br>observed. |

The device meets the requirements, provided the information in the instruction leaflet (IL) is observed.

#### **Technical data ETIM 7.0**


Sensors (EG000026) / Drive head for position switches/hinge switches (EC001483)

Electric engineering, automation, process control engineering / Binary sensor technology, safety-related sensor technology / Position switch / Drive head for position switches (ecl@ss10.0.1-27-27-06-04 [BAA083012])

Type of control element

Rotary lever

#### **Dimensions**



## **Assets (links)**

Declaration of CE Conformity 00002833