## DATASHEET - NZM3-4-XKV2P-K



Link kit, +cover, +heat sink, 4p, /2p

NZM3-4-XKV2P-K Catalog No. 142271

0004356084



#### **EL-Nummer** (Norway)

Part no.

#### **Delivery program** Number of poles 2 pole DC link kit Accessories Number of conductors 4 Jumper kit with cover IP2X and heat sink 550 (40 °C,) Rated current I<sub>n</sub> А 468 (65 °C) For use with N3-4-...-S1(-S15)-DC Notes

Model contains parts for upper switch side for 4 pole switches N...-DC that are used as 2 pole switches for DC.

The links each connect contacts in series.

Incoming unit and outgoer at bottom or top, user-definable.

See figure connection type.


## **Design verification as per IEC/EN 61439**

| IEC/EN 61439 design verification  |  |
|---|--|
|   |  |
| 10.2 Strength of materials and parts  |  |
| 10.2.2 Corrosion resistance   | Meets the product standard's requirements.   |
| 10.2.3.1 Verification of thermal stability of enclosures  | Meets the product standard's requirements.   |
| 10.2.3.2 Verification of resistance of insulating materials to normal heat  | Meets the product standard's requirements.   |
| 10.2.3.3 Verification of resistance of insulating materials to abnormal heat<br>and fire due to internal electric effects | Meets the product standard's requirements.   |
| 10.2.4 Resistance to ultra-violet (UV) radiation  | Meets the product standard's requirements.   |
| 10.2.5 Lifting  | Does not apply, since the entire switchgear needs to be evaluated.   |
| 10.2.6 Mechanical impact  | Does not apply, since the entire switchgear needs to be evaluated.   |
| 10.2.7 Inscriptions   | Meets the product standard's requirements.   |
| 10.3 Degree of protection of ASSEMBLIES   | Does not apply, since the entire switchgear needs to be evaluated.   |
| 10.4 Clearances and creepage distances  | Meets the product standard's requirements.   |
| 10.5 Protection against electric shock  | Does not apply, since the entire switchgear needs to be evaluated.   |
| 10.6 Incorporation of switching devices and components  | Does not apply, since the entire switchgear needs to be evaluated.   |
| 10.7 Internal electrical circuits and connections   | Is the panel builder's responsibility.   |
| 10.8 Connections for external conductors  | Is the panel builder's responsibility.   |
| 10.9 Insulation properties  |  |
| 10.9.2 Power-frequency electric strength  | Is the panel builder's responsibility.   |
| 10.9.3 Impulse withstand voltage  | Is the panel builder's responsibility.   |
| 10.9.4 Testing of enclosures made of insulating material  | Is the panel builder's responsibility.   |
| 10.10 Temperature rise  | The panel builder is responsible for the temperature rise calculation. Eaton will provide heat dissipation data for the devices. |
| 10.11 Short-circuit rating  | Is the panel builder's responsibility. The specifications for the switchgear must be observed.                                   |
| 10.12 Electromagnetic compatibility   | Is the panel builder's responsibility. The specifications for the switchgear must be observed.                                   |
| 10.13 Mechanical function   | The device meets the requirements, provided the information in the instruction leaflet (IL) is observed.                         |
|   |  |


## **Technical data ETIM 7.0**

Low-voltage industrial components (EG000017) / Wiring set for power circuit breaker (EC002050)

Electric engineering, automation, process control engineering / Low-voltage switch technology / Circuit breaker (LV < 1 kV) / Wiring set for circuit breaker (ecl@ss10.0.1-27-37-04-24 [ACN957011])



## Dimensions



# Additional product information (links)

### IL01208003Z (AWA1230-2722) Jumper kit for N2(3)-DC switch-disconnector, with shroud

IL01208003Z (AWA1230-2722) Jumper kit for N2(3)-DC switch-disconnector, with shroud

ftp://ftp.moeller.net/DOCUMENTATION/AWA\_INSTRUCTIONS/IL01208003Z2012\_08.pdf