

Label; emergency switching off; yellow; H x W = 50 x 33 mm; with IEC60417-5638 symbol



Part no. **M22-XZK-ESS**
180470

| General specifications | | |
|--|--|--|
| Product name | | Eaton Moeller® series M22 Accessory Emergency-Stop label |
| Part no. | | M22-XZK-ESS |
| EAN | | 4015081756353 |
| Product Length/Depth | | 50 millimetre |
| Product height | | 1 millimetre |
| Product width | | 33 millimetre |
| Product weight | | 0.002 kilogram |
| Certifications | | DNV GL LR |
| Product Tradename | | M22 |
| Product Type | | Accessory |
| Product Sub Type | | Emergency-Stop label |
| Features & Functions | | |
| Color | | Yellow |
| Inscription | | EMERGENCY STOP |
| Language | | Other |
| RAL-number | | 1004 |
| Shape | | Rectangular |
| General information | | |
| Degree of protection | | IP66 |
| Size | | 33 x 50 mm |
| Communication | | |
| Connection to SmartWire-DT | | No |
| Design verification | | |
| 10.2.2 Corrosion resistance | | Meets the product standard's requirements. |
| 10.2.3.1 Verification of thermal stability of enclosures | | Meets the product standard's requirements. |
| 10.2.3.2 Verification of resistance of insulating materials to normal heat | | Meets the product standard's requirements. |
| 10.2.3.3 Resist. of insul. mat. to abnormal heat/fire by internal elect. effects | | Meets the product standard's requirements. |
| 10.2.5 Lifting | | Does not apply, since the entire switchgear needs to be evaluated. |
| 10.2.6 Mechanical impact | | Does not apply, since the entire switchgear needs to be evaluated. |
| 10.2.7 Inscriptions | | Meets the product standard's requirements. |
| 10.3 Degree of protection of assemblies | | Does not apply, since the entire switchgear needs to be evaluated. |
| 10.4 Clearances and creepage distances | | Meets the product standard's requirements. |
| 10.5 Protection against electric shock | | Does not apply, since the entire switchgear needs to be evaluated. |
| 10.6 Incorporation of switching devices and components | | Does not apply, since the entire switchgear needs to be evaluated. |
| 10.7 Internal electrical circuits and connections | | Is the panel builder's responsibility. |
| 10.8 Connections for external conductors | | Is the panel builder's responsibility. |
| 10.9.2 Power-frequency electric strength | | Is the panel builder's responsibility. |
| 10.9.3 Impulse withstand voltage | | Is the panel builder's responsibility. |
| 10.9.4 Testing of enclosures made of insulating material | | Is the panel builder's responsibility. |
| 10.10 Temperature rise | | Not applicable. |
| 10.11 Short-circuit rating | | Is the panel builder's responsibility. The specifications for the switchgear must be observed. |
| 10.12 Electromagnetic compatibility | | Is the panel builder's responsibility. The specifications for the switchgear must be observed. |
| 10.13 Mechanical function | | The device meets the requirements, provided the information in the instruction leaflet (IL) is observed. |

Technical data ETIM 9.0

| | | | |
|--|--|----|-------------------------|
| Low-voltage industrial components (EG000017) / Text plate for command devices (EC000624) | | | |
| Electric engineering, automation, process control engineering / Low-voltage switch technology / Command and alarm device / Identification plate for command devices (ecl@ss13-27-37-12-25 [AKF043019]) | | | |
| Literal imprint | | | Emergency Stop |
| Language of the imprint | | | Other |
| Imprint ISO symbols | | | Symbol "Emergency Stop" |
| Colour | | | Yellow |
| Shape | | | Rectangular |
| Width | | mm | 33 |
| Height | | mm | 1 |
| Outer diameter | | mm | 0 |