Pushbutton, RMQ-Titan, Extended, maintained, green, Blank, Bezel: titanium



Part no. M22-DRH-G 216669

EL Number (Norway) 4355629

General specifications	
Product name	Eaton Moeller® series M22 Pushbutton
Part no.	M22-DRH-G
EAN	4015082166694
Product Length/Depth	30 millimetre
Product Lengtly Depart	35 millimetre
Product width	30 millimetre
Product width Product weight	
	0.013 kilogram
Certifications	EN 60947-5 IEC 60947-5 CSA Std. C22.2 No. 14-05 CSA Std. C22.2 No. 94-91 UL 508 VDE CSA UL CSA-C22.2 No. 14-05 VDE 0660 CSA-C22.2 No. 94-91 CSA File No.: 012528 UL Category Control No.: NKCR IEC/EN 60947-5 CE IEC/EN 60947 CSA Class No.: 3211-03 UL File No.: E29184 GL DNV
	LR
Product Tradename	M22
Product Type	Pushbutton
Product Sub Type	None
Features & Functions	
Bezel color	Titanium
Bezel material	Plastic
Design	Extended Classical
Fitted with:	Front ring
Functions	Stay-put/spring-return function can be changed on device
Inscription	Blank
General information	
Degree of protection	NEMA 13 IP66 NEMA 3R NEMA 4X IP67 IP69K NEMA 12
Degree of protection (front side)	IP67/IP69K NEMA 4X
Lifespan, mechanical	1,000,000 Operations (AC operated)
Opening diameter	22.5 mm
	1800 Operations/h
Operating frequency	
Operating frequency Product category	RMQ-Titan
	RMQ-Titan Front dimensions: 22 x 22 mm

Ambient operating temperature - min Ambient operating temperature - max 70 °C Ambient storage temperature - max 80 °C Climatic proding Demphese constant, to IEC 80982-278 Dem	Mounting position	As required
Ambient coperating temperature - min Ambient coperating temperature - max Olimate proofing Demphast. containt, to IEC 00008-2-78 Dump heat. cyclic. To IEC 00008-2-79 Dump heat. cyclic. To IEC 000	Shock resistance Shock resistance	
Ambient paperature umperature - max Ambient storage temperature - min Ambient storage temperature - max Climatic proporting Damp heat, constant, in IEC 50008-2-30 Damp heat,	Climatic environmental conditions	
Ambient papersting temperature - minx Ambient storage temperature - minx Ambient storage temperature - minx Climatic proofing Damp heat, constant, to IEC 80809-279 Damp heat, constant, to IEC 80809-279 Damp heat, constant, to IEC 80809-290 Damp heat, constant,	Ambient operating temperature - min	-25 °C
Ambient storage temperature - max Climaise proofing Commenciation Commenciation Commenciation Commenciation Commenciation Commenciation Commenciation Actuator Actuator force Actuator force Actuator force Actuator force Contects Force for passitive opening - min Design verification Commenciation commenciation commenciation force Actuator function Contects Force to passitive opening - min Design verification Contects Force for passitive opening - min Design verification Contects Force for passitive opening - min Design verification Contects Force for passitive opening - min Design verification Contects Force for passitive opening - min Design verification Contects Force for passitive opening - min Design verification Contects Force for passitive opening - min Design verification Contects Force for passitive opening - min Design verification Contects Force for passitive opening - min Design verification Contects Force for passitive opening - min Design verification Design verification Contects Force for passitive opening - min Design verification Contects Force for passitive opening - min Design verification Design verification Contects Force for passitive opening - min Design verification Design verification Design verification ON Contects Force for passitive opening - min Design verification ON Contects Force for passitive opening - min Design verification ON Contects Force for passitive opening - min Design verification ON Contects Force for passitive opening - min Design verification ON Contects Force for passitive opening - min Design verification On Actuation of passitive opening - min Design verification of resistance of insulation antarial to normal heat Design opening - pole, current dependent Pvid Design opening - pole, current dependen		70 °C
Ambient storage temperature - max Climate profiling Damp heat, cycle, to IIC 60008-2-78 Damp heat, cycle, to IIC 60008-		-40 °C
Communication Commercian to SmartWire-DT Actuator Actuator color Actuator color Actuator color Actuator function Contacts Force for possible opening - min Design verification Equipment heat dissipation, current-dependent Pvid Heat dissipation project purposity prices Equipment heat dissipation, current-dependent Pvid Heat dissipation project purposity prices Equipment heat dissipation, current-dependent Pvid Heat dissipation project purposity prices Equipment heat dissipation, current-dependent Pvid Heat dissipation project purposity prices Equipment heat dissipation, current-dependent Pvid Heat dissipation project purposity prices Equipment heat dissipation, current-dependent Pvid Heat dissipation project purposity prices Equipment heat dissipation, current-dependent Pvid Reted dissipation project purposity prices Equipment heat dissipation, non-current-dependent Pvid Reted dissipation project purposity prices pric		80 °C
Connection to SmartWre-DT Connection to SmartWre-DT Actuator Actuator price Contacts Force for positive opening - min Design verification Equipment hear dissipation, carrent-dependent Pvid Actuator price Equipment hear dissipation, per pole, current-dependent Pvid Actuator price Back dissipation acpairs price Back dissipation actual price Back dissipation per pole, current-dependent Pvid Actuator price Back dissipation pre pole, current-dependent Pvid Actuator price Back dissipation pre pole, current-dependent Pvid Actuator price Back dissipation pre pole, current-dependent Pvid Back dissipation pre pole, current-dependent Pvid Back dissipation pre pole, current-dependent Pvi Back dissipation pre pole, current-dependent Pvi Back dissipation of thermal stability of enclosures Meets the product standard's requirements. Meets the product standa	Climatic proofing	
Connection to SmartWire-DT Actuating force Actuating function Actuating function Actuating function Bailtrained Switching function latching Contacts Force for positive opening - min Design verification Equipment heat dissipation, current-dependent Prid Heat dissipation capportly Pfals UW Rated operational current for specified heat dissipation (In) Rated dissipation open plot, current-dependent Prid Rated dissipation or prio, current-dependent Prid Rated operational current for specified heat dissipation (In) Rated dissipation or specification 10.2.2 Carrosion resistance Meats the product standard's requirements. 10.2.3.1 Verification of thermal stability of enclosures Meats the product standard's requirements. 10.2.3.2 Verification of resistance of insulating material stor normal heat 10.2.3.2 Verification of resistance of insulating material stor normal heat 10.2.3.2 Verification of resistance of insulating material stor normal heat 10.2.3.2 Verification of resistance of insulating material to the prior of the control of the prior of the pri		Damp heat, cyclic, to IEC 60068-2-30
Actuator force Actuator function Equipment head designation appending minim Design verification Equipment head designation, current-dependent Pvid Heat dissipation appending period OW Heat dissipation appending Pvid Heat dissipation in appending the state of t		
Actuating force 5 N Actuator recolor Actuator function Maintained Switching function latching Contacts Force for positive opening - min Design verification Equipment head dissipation, current-dependent Prid 0W Heat dissipation capacity Pdiss 0W Heat dissipation per pole, current-dependent Prid 0W Heat dissipation, non-current-dependent Prid 0W Static heat dissipation, non-current-dependent Prid 0W Static heat dissipation, non-current-dependent Prid 0W Heat dissipation of resistance of insulating materials to normal heat 0W 102.2 Corresion resistance 0W 102.3.1 Verification of themal stability of enclosures 0W 102.3.2 Verification of themal stability of enclosures 0W 102.3.3 Resist of insul. mat. to abnormal heat/fire by internal elect. effects 0W 102.4.2 Verification of themal stability of enclosures 0W 102.5.1 Uting 0Dees not apply, since the entire switchgear needs to be evaluated. 102.5 Uting 0Dees not apply, since the entire switchgear needs to be evaluated. 102.5 Mechanical impact 0Dees not apply, since the entire switchgear needs to be evaluated. 102.5 Mechanical impact 0Dees not apply, since the entire switchgear needs to be evaluated. 102.6 Mechanical impact 0Dees not apply, since the entire switchgear needs to be evaluated. 102.6 Nechanical impact 0Dees not apply, since the entire switchgear needs to be evaluated. 102.6 Nechanical impact 0Dees not apply, since the entire switchgear needs to be evaluated. 103.0 Dees not apply, since the entire switchgear needs to be evaluated. 103.0 Dees not apply, since the entire switchgear needs to be evaluated. 104.0 Per ances of responsibility. 105.0 Dees not apply, since the entire switchgear needs to be evaluated. 105.0 Temperature rise 0W 105.0 Temperature rise 0W 106.1 Temperature rise 0W 107.1 Internal electrical circuits and connections 1W 108.0 Temperature rise 1W 109.1 Temperature rise 1W 109.1 Tem	Connection to SmartWire-DT	
Actuator color Actuator function Contacts Force for positive opening - min Design verification Equipment heat dissipation, current-dependent Pvid Heat dissipation per pole, current-dependent Pvid Heat dissipation per pole, current-dependent Pvid Heat dissipation, non-current dopendent Pvid Heat dissipation, non-current dopendent Pvid Heat dissipation, non-current-dependent Pvid Heat dissipation, non-current dissipation, non-current-dependent Pvid Heat dissipation, non-current dissipation languare real to non-current dissipation non-current	Actuator	
Actuator function Contacts Force for positive opening - min Design verification Equipment heat dissipation, current-dependent Pvid Heat dissipation per pole, current-dependent Pvid Rated operational current or specified heat dissipation (In) Static heat dissipation, non-current-dependent Pvis Heat dissipation or concernent dependent Pvid Heat dissipation or current-dependent Pvis Heat dissipation, non-current-dependent Pvis Heat dissipation, non-current-dependent Pvis Heat dissipation or non-current-dependent Pvis Heat dissipation or on-current-dependent Pvis Heat dissipation or on-current-dependent Pvis Heat dissipation or on-current-dependent Pvis Heat dissipation or non-current-dependent Pvis Heat dissipation or on-current-dependent Pvis Heat dissipation, non-current-dependent Pvis Heat dissipation or devict dissipation (In) Static heat dissipation, non-current-dependent Pvis Heat dissipation or devicts and collection or female stability of enclosures Heat dissipation or female stability of evolution or female stability of evolution or female stability or requirements. Heat dissipation or female repeat to the evaluated. Does not apply, since the entire switchgear needs to be evaluated. Heat dissipation of switching devices and components Heat dissipation of switching devices and components Heat dissipation or female switchgear needs to be evaluated. Heat dissipation of switching devices and components Heat dissipation or sponsibility. Heat dissipation or switching devices and components Heat dissipation or female stabil	Actuating force	5 N
Contacts Force for positive opening - min Design verification Quy Heat dissipation, current-dependent Pvid Heat dissipation capacity Pdiss Heat dissipation per pole, current-dependent Pvid Rated operational current for specified heat dissipation (in) Static heat dissipation, non-current-dependent Pvid Astactic heat dissipation, non-current-dependent Pvid Bated operational current for specified heat dissipation (in) Astactic heat dissipation, non-current-dependent Pvs Design verification of themsel stability of enclosures Meets the product standard's requirements. Does not apply, since the entire switchgear needs to be evaluated. Does not apply, since the entire switchgear needs to be evaluated. Meets the product standard's requirements. Meets the panel builder's responsibility. Meets th	Actuator color	Green
Force for positive opening - min Design verification Equipment heat dissipation, current-dependent Pvid Heat dissipation appairy Plais OW Hoat dissipation per pole, current-dependent Pvid Asted operational current for specified heat dissipation (In) Static heat dissipation, non-current-dependent Pvs 10.2.2 Corrosion resistance 10.2.3.1 Varification of thermal stability of enclosures 10.2.3.2 Varification of thermal stability of enclosures 10.2.3.3 Presist of insul. mat. to abnormal heat fire by internal elect. effects 10.2.4 Resistance to ultra-violet (UV) radiation 10.2.5 Lifting 10.2.6 Mechanical impact 10.2.7 Inscriptions 10.3 Degree of protection of assemblies 10.4 Clearances and creepage distances 10.5 Protection against electric shock 10.6 Incorporation of switching devices and components 10.7 Internal electrical icruits and connections 10.8 Connections for external conductors 10.9 Protection against electric strength 10.9 Report frequency electric strength 10.9 Report frequency electric strength 10.9 Is product standard of s requirements. 10.9 Does not apply, since the entire switchgear needs to be evaluated. 10.9 Internal electrical icruits and connections 1.5 Is the panel builder's responsibility. 1.6 Incorporation of switching devices and components 1.6 Incorporation of switching devices and components 1.7 Internal electrical icruits and connections 1.8 It panel builder's responsibility. 1.9 Is the panel build	Actuator function	
Design verification Equipment heat dissipation, current-dependent Pvid Heat dissipation capacity Pdiss 0 W Rated operational current for specified heat dissipation (In) Static heat dissipation, per pole, current-dependent Pvid 0 UW Rated operational current for specified heat dissipation (In) 10.2.2 Corrosion resistance 10.2.3.1 Varification of thermal stability of enclosures 10.2.3.2 Varification of thermal stability of enclosures 10.2.3.2 Varification of thermal stability of enclosures 10.2.3.3 Varification of thermal stability of enclosures 10.2.4 Resistance to ultra-violet (UV) radiation 10.2.5 Lifting 10.2.6 Mechanical impact 10.2.6 Mechanical impact 10.2.7 Inscriptions 10.3 Degree of protection of assemblies 10.3 Degree of protection of assemblies 10.4 Clearances and creepage distances 10.5 Protection against electric shock 10.6 Incorporation of switching devices and components 10.5 Protection against electric shock 10.6 Incorporation of switching devices and components 10.7 Internal electrical circuits and connections 10.8 Connections for external conductors 10.9 Protection of one external conductors 10.9 Protection of one external conductors 10.9 Internal electrical circuits and connections 10.9 Protection of one external conductors 10.9 Internal electrical circuits and connections 10.9 Internal electrical circuits and co	Contacts	
Equipment heat dissipation, current-dependent Pvid Heat dissipation capacity Pdiss OW Rated operational current for specified heat dissipation (In) Static heat dissipation, non-current-dependent Pvid And operational current for specified heat dissipation (In) Static heat dissipation, non-current-dependent Pvs OW OV 10.22 Corrosion resistance Meets the product standard's requirements. 10.23.31 Verification of thermal stability of enclosures Meets the product standard's requirements. 10.23.32 Verification of resistance of insulating materials to normal heat 10.23.33 Resist, of insul. mat. to abnormal heat/fire by internal elect. effects 10.24 Resistance to ultra-violet (UV) radiation 10.25 Lifting Obes not apply, since the entire switchgear needs to be evaluated. 10.26 Mechanical impact 10.27 Inscriptions Meets the product standard's requirements. 10.30 Degree of protection of assemblies Does not apply, since the entire switchgear needs to be evaluated. 10.4 Clearances and creepage distances Meets the product standard's requirements. 10.5 Protection against electric shock Does not apply, since the entire switchgear needs to be evaluated. 10.6 Incorporation of switching devices and components 10.7 Internal electric alcricuits and connections Is the panel builder's responsibility. 10.9 Power-frequency electric strength Is the panel builder's responsibility. 10.9.4 Testing of enclosures made of insulating material 10.10 Temperature rise Not applicable. 10.11 Short-circuit rating List the panel builder's responsibility. The specifications for the switchgear must be observed. 10.13 Mechanical function The device meets the requirements, provided the information in the instruction	Force for positive opening - min	0 N
Heat dissipation capacity Pdiss Heat dissipation per pole, current-dependent Pvid OW Rated operational current for specified heat dissipation (In) OA Static heat dissipation, non-current-dependent Pvs OW 10.22 Corrosion resistance Meets the product standard's requirements. 10.23.1 Verification of thermal stability of enclosures Meets the product standard's requirements. 10.23.2 Verification of resistance of insulating materials to normal heat Meets the product standard's requirements. 10.23.3 Resist. of insul. mat. to abnormal heat/fire by internal elect. effects Meets the product standard's requirements. 10.24 Resistance to ultra-violet (UV) radiation Please enquire Does not apply, since the entire switchgear needs to be evaluated. 10.25 Mechanical impact Does not apply, since the entire switchgear needs to be evaluated. 10.27 Inscriptions Meets the product standard's requirements. 10.3 Degree of protection of assemblies Does not apply, since the entire switchgear needs to be evaluated. 10.4 Clearances and creepage distances Meets the product standard's requirements. 10.5 Protection against electric shock Does not apply, since the entire switchgear needs to be evaluated. 10.6 Incorporation of switching devices and components Does not apply, since the entire switchgear needs to be evaluated. 10.7 Internal electrical circuits and connections Is the panel builder's responsibility. 10.8 Connections for external conductors Is the panel builder's responsibility. 10.9.3 Impulse withstand voltage Is the panel builder's responsibility. 10.9.4 Testing of enclosures made of insulating material 10.10 Temperature rise Not applicable. 10.11 Short-circuit rating Does not apply are the entire switchgear must be observed. 10.13 Mechanical function The device meets the requirements, provided the information in the instruction	Design verification	
Heat dissipation per pole, current-dependent Pvid Rated operational current for specified heat dissipation (In) Static heat dissipation, non-current-dependent Pvs 0 W 10.22 Corrosion resistance Meets the product standard's requirements. 10.2.3.1 Verification of thermal stability of enclosures Meets the product standard's requirements. 10.2.3.2 Verification of resistance of insulating materials to normal heat 10.2.3.3 Verification of resistance of insulating materials to normal heat 10.2.3.3 Resist, of insul, mat, to abnormal heat/fire by internal elect, effects 10.2.4 Resistance to ultra-violet (UV) radiation 10.2.5 Lifting Does not apply, since the entire switchgear needs to be evaluated. 10.2.6 Mechanical impact Does not apply, since the entire switchgear needs to be evaluated. 10.2.7 Inscriptions Meets the product standard's requirements. 10.3 Degree of protection of assemblies Does not apply, since the entire switchgear needs to be evaluated. 10.4 Clearances and creepage distances Meets the product standard's requirements. 10.5 Protection against electric shock Does not apply, since the entire switchgear needs to be evaluated. 10.6 Incorporation of switching devices and components Does not apply, since the entire switchgear needs to be evaluated. 10.1 Internal electrical circuits and connections Is the panel builder's responsibility. 10.9.2 Power-frequency electric strength Is the panel builder's responsibility. 10.9.3 Temperature rise Not applicable 10.10 Temperature rise Not applicable 10.11 Short-circuit rating Is the panel builder's responsibility. The specifications for the switchgear must be observed. 10.12 Electromagnetic compatibility Is the panel builder's responsibility. The specifications for the switchgear must be observed. 10.13 Mechanical function The device meets the requirements, provided the information in the instruction	Equipment heat dissipation, current-dependent Pvid	0 W
Rated operational current for specified heat dissipation (In) Static heat dissipation, non-current-dependent Pvs 0 W 10.22 Corrosion resistance Meets the product standard's requirements. 10.23.1 Verification of thermal stability of enclosures Meets the product standard's requirements. 10.23.2 Verification of resistance of insulating materials to normal heat 10.23.3 Resist of insul. mat. to abnormal heat/fire by internal elect. effects 10.24. Resistance to ultra-violet (UV) radiation 10.25. Lifting Does not apply, since the entire switchgear needs to be evaluated. 10.27 Inscriptions Meets the product standard's requirements. 10.30 Degree of protection of assemblies Does not apply, since the entire switchgear needs to be evaluated. 10.4 Clearances and creapage distances Meets the product standard's requirements. 10.5 Protection against electric shock Does not apply, since the entire switchgear needs to be evaluated. 10.6 Incorporation of switching devices and components 10.7 Internal electrical circuits and connections Is the panel builder's responsibility. 10.9.2 Power-frequency electric strength Is the panel builder's responsibility. 10.9.2 Power-frequency electric strength Is the panel builder's responsibility. 10.9.4 Testing of enclosures made of insulating material 10.11 Short-circuit rating 10.12 Electromagnetic compatibility Is the panel builder's responsibility. The specifications for the switchgear must be observed. 10.13 Mechanical function The device meets the requirements, provided the information in the instruction	Heat dissipation capacity Pdiss	0 W
Static heat dissipation, non-current-dependent Pvs 10.22 Corrosion resistance 10.23.1 Verification of thermal stability of enclosures 10.23.2 Verification of resistance of insulating materials to normal heat 10.23.3 Resist. of insul. mat. to abnormal heat/fire by internal elect. effects 10.24 Resistance to ultra-violet (UV) radiation 10.25 Lifting 10.26 Mechanical impact 10.27 Inscriptions 10.3 Degree of protection of assemblies 10.4 Clearances and creepage distances 10.5 Protection against electric shock 10.6 Incorporation of switching devices and components 10.7 Internal electrical circuits and connections 10.8 Connections for external conductors 10.9 Power-frequency electric strength 10.9 A Testing of enclosures made of insulating material 10.10 Temperature rise 10.11 Electromagnetic compatibility 10.12 Electromagnetic compatibility 10.13 Mechanical function 10.13 Mechanical function 10.14 Mechanical function 10.15 Interporation of switching devices and components 10.16 Incorporation of switching devices and components 10.17 Internal electrical circuits and connections 10.18 Lengent Builder's responsibility. 10.19 Internal electric strength 10.10 Temperature rise 10.10 Temperature rise 10.11 Short-circuit rating 10.12 Electromagnetic compatibility 10.13 Mechanical function 10.14 Mechanical function 10.15 Letting device meets the requirements, provided the information in the instruction	Heat dissipation per pole, current-dependent Pvid	0 W
10.2.2 Corrosion resistance 10.2.3.1 Verification of thermal stability of enclosures 10.2.3.2 Verification of thermal stability of enclosures 10.2.3.2 Verification of resistance of insulating materials to normal heat 10.2.3.3 Resist, of insul, mat. to abnormal heat/fire by internal elect. effects 10.2.4 Resistance to ultra-violet (UV) radiation 10.2.5 Lifting 10.2.6 Mechanical impact 10.2.7 Inscriptions 10.3 Degree of protection of assemblies 10.3 Degree of protection of assemblies 10.4 Dearances and creepage distances 10.5 Protection against electric shock 10.5 Protection against electric shock 10.6 Incorporation of switching devices and components 10.7 Internal electrical circuits and connections 10.8 Connections for external conductors 10.9.2 Power-frequency electric strength 10.9.3 Impulse withstand voltage 10.9.4 Testing of enclosures made of insulating material 10.10 Temperature rise 10.11 Short-circuit rating 10.12 Electromagnetic compatibility 10.13 Mechanical function 10.13 Mechanical function 10.13 Mechanical function 10.14 Meets the product standard's requirements. 10.15 Meets the product standard's requirements. 10.6 Incorporation of switching devices and components 10.6 Incorporation of switching devices and components 10.7 Internal electrical circuits and connections 10.8 Connections for external conductors 10.9 Power-frequency electric strength 10.9 Power-frequency electric strength 10.9 In the panel builder's responsibility. 10.9 Temperature rise 10.10 Temperature rise 10.11 Short-circuit rating 10.12 Electromagnetic compatibility 10.13 Mechanical function 10.13 Mechanical function 10.14 Mechanical function 10.15 Mechanical function 10.16 Meets the product standard's requirements. 10.17 Meets the product standard's requirements. 10.18 Meets the product standard's requirements. 10.19 Meets the product st	Rated operational current for specified heat dissipation (In)	0 A
10.2.3.1 Verification of thermal stability of enclosures 10.2.3.2 Verification of resistance of insulating materials to normal heat 10.2.3.3 Resist. of insul. mat. to abnormal heat/fire by internal elect. effects 10.2.4 Resistance to ultra-violet (UV) radiation 10.2.5 Lifting 10.2.5 Lifting 10.2.6 Mechanical impact 10.2.7 Inscriptions 10.2.7 Inscriptions 10.3 Degree of protection of assemblies 10.4 Clearances and creepage distances 10.5 Protection against electric shock 10.6 Incorporation of switching devices and components 10.7 Internal electrical circuits and connections 10.8 Connections for external conductors 10.9.2 Power-frequency electric strength 10.9.3 Impulse withstand voltage 10.9.4 Testing of enclosures made of insulating material 10.10 Temperature rise 10.11 Short-circuit rating 10.12 Electromagnetic compatibility 10.13 Mechanical function 10.13 Mechanical function Meets the product standard's requirements. Meets the product standard's requirements. Meets the product standard's requirements. Does not apply, since the entire switchgear needs to be evaluated. Does not apply, since the entire switchgear needs to be evaluated. Does not apply, since the entire switchgear needs to be evaluated. Is the panel builder's responsibility. 10.5 The panel builder's responsibility. 10.6 The panel builder's responsibility. 10.7 Internal electrical circuits and connections 10.8 The panel builder's responsibility. 10.9 Temperature rise 10.9 The panel builder's responsibility. 10.10 Temperature rise 10.11 Short-circuit rating 10.12 Electromagnetic compatibility 10.13 Mechanical function The device meets the requirements, provided the information in the instruction	Static heat dissipation, non-current-dependent Pvs	0 W
102.3.2 Verification of resistance of insulating materials to normal heat 102.3.3 Resist. of insul. mat. to abnormal heat/fire by internal elect. effects 102.4 Resistance to ultra-violet (UV) radiation 102.5 Lifting 102.6 Mechanical impact 102.7 Inscriptions 103.0 Does not apply, since the entire switchgear needs to be evaluated. 104.1 Does not apply, since the entire switchgear needs to be evaluated. 105.2 Inscriptions 105.3 Degree of protection of assemblies 105.4 Clearances and creepage distances 105.5 Protection against electric shock 105.6 Incorporation of switching devices and components 106.6 Incorporation of switching devices and components 107.1 Internal electrical circuits and connections 108.0 Connections for external conductors 109.1 Sy Power-frequency electric strength 109.2 Power-frequency electric strength 109.3 Impulse withstand voltage 109.4 Testing of enclosures made of insulating material 109.4 Testing of enclosures made of insulating into the switchgear must be observed. 109.1 She panel builder's respon	10.2.2 Corrosion resistance	Meets the product standard's requirements.
10.2.3 Resist. of insul. mat. to abnormal heat/fire by internal elect. effects 10.2.4 Resistance to ultra-violet (UV) radiation 10.2.5 Lifting 10.2.6 Mechanical impact 10.2.6 Mechanical impact 10.2.7 Inscriptions 10.3 Degree of protection of assemblies 10.4 Clearances and creepage distances 10.5 Protection against electric shock 10.6 Incorporation of switching devices and components 10.7 Internal electrical circuits and connections 10.8 Connections for external conductors 10.9 Power-frequency electric strength 10.9.1 Testing of enclosures made of insulating material 10.10 Temperature rise 10.11 Short-circuit rating 10.12 Electromagnetic compatibility 10.13 Mechanical function 10.13 Mechanical function Meets the product standard's requirements. Does not apply, since the entire switchgear needs to be evaluated. Does not apply, since the entire switchgear needs to be evaluated. Does not apply, since the entire switchgear needs to be evaluated. Is the panel builder's responsibility. Is the panel builder's responsibility. The specifications for the switchgear must be observed. Is the panel builder's responsibility. The specifications for the switchgear must be observed. In the device meets the requirements, provided the information in the instruction	10.2.3.1 Verification of thermal stability of enclosures	Meets the product standard's requirements.
10.2.4 Resistance to ultra-violet (UV) radiation Please enquire 10.2.5 Lifting Does not apply, since the entire switchgear needs to be evaluated. 10.2.6 Mechanical impact Does not apply, since the entire switchgear needs to be evaluated. 10.2.7 Inscriptions Meets the product standard's requirements. 10.3 Degree of protection of assemblies 10.4 Clearances and creepage distances Meets the product standard's requirements. 10.5 Protection against electric shock Does not apply, since the entire switchgear needs to be evaluated. 10.6 Incorporation of switching devices and components 10.7 Internal electrical circuits and connections Is the panel builder's responsibility. 10.8 Connections for external conductors Is the panel builder's responsibility. 10.9.2 Power-frequency electric strength Is the panel builder's responsibility. 10.9.3 Impulse withstand voltage Is the panel builder's responsibility. 10.9.4 Testing of enclosures made of insulating material 10.10 Temperature rise Not applicable. 10.11 Short-circuit rating Is the panel builder's responsibility. The specifications for the switchgear must be observed. 10.12 Electromagnetic compatibility Is the panel builder's responsibility. The specifications for the switchgear must be observed.	10.2.3.2 Verification of resistance of insulating materials to normal heat	Meets the product standard's requirements.
10.2.5 Lifting Does not apply, since the entire switchgear needs to be evaluated. 10.2.6 Mechanical impact Does not apply, since the entire switchgear needs to be evaluated. 10.2.7 Inscriptions Meets the product standard's requirements. 10.3 Degree of protection of assemblies Does not apply, since the entire switchgear needs to be evaluated. 10.4 Clearances and creepage distances Meets the product standard's requirements. 10.5 Protection against electric shock Does not apply, since the entire switchgear needs to be evaluated. 10.6 Incorporation of switching devices and components Does not apply, since the entire switchgear needs to be evaluated. 10.7 Internal electrical circuits and connections Is the panel builder's responsibility. 10.8 Connections for external conductors Is the panel builder's responsibility. 10.9.2 Power-frequency electric strength Is the panel builder's responsibility. 10.9.3 Impulse withstand voltage Is the panel builder's responsibility. 10.9.4 Testing of enclosures made of insulating material Is the panel builder's responsibility. 10.10 Temperature rise Not applicable. 10.11 Short-circuit rating Is the panel builder's responsibility. The specifications for the switchgear must be observed. 10.12 Electromagnetic compatibility Is the panel builder's responsibility. The specifications for the switchgear must be observed. 10.13 Mechanical function The device meets the requirements, provided the information in the instruction	10.2.3.3 Resist. of insul. mat. to abnormal heat/fire by internal elect. effects	Meets the product standard's requirements.
10.2.6 Mechanical impact 10.2.7 Inscriptions Meets the product standard's requirements. 10.3 Degree of protection of assemblies Does not apply, since the entire switchgear needs to be evaluated. 10.4 Clearances and creepage distances Meets the product standard's requirements. 10.5 Protection against electric shock Does not apply, since the entire switchgear needs to be evaluated. 10.6 Incorporation of switching devices and components Does not apply, since the entire switchgear needs to be evaluated. 10.7 Internal electrical circuits and connections Is the panel builder's responsibility. 10.8 Connections for external conductors Is the panel builder's responsibility. 10.9.2 Power-frequency electric strength Is the panel builder's responsibility. 10.9.3 Impulse withstand voltage Is the panel builder's responsibility. 10.9.4 Testing of enclosures made of insulating material Is the panel builder's responsibility. 10.10 Temperature rise Not applicable. 10.11 Short-circuit rating Is the panel builder's responsibility. The specifications for the switchgear must be observed. 10.12 Electromagnetic compatibility Is the panel builder's responsibility. The specifications for the switchgear must be observed. 10.13 Mechanical function The device meets the requirements, provided the information in the instruction	10.2.4 Resistance to ultra-violet (UV) radiation	Please enquire
10.27 Inscriptions 10.3 Degree of protection of assemblies 10.4 Clearances and creepage distances 10.5 Protection against electric shock 10.6 Incorporation of switching devices and components 10.7 Internal electrical circuits and connections 10.8 Connections for external conductors 10.9.2 Power-frequency electric strength 10.9.3 Impulse withstand voltage 10.9.4 Testing of enclosures made of insulating material 10.11 Short-circuit rating 10.12 Electromagnetic compatibility 10.12 Electromagnetic compatibility 10.13 Mechanical function Meets the product standard's requirements. Does not apply, since the entire switchgear needs to be evaluated. Does not apply, since the entire switchgear needs to be evaluated. Is the panel builder's responsibility. In the panel builder's responsibility. In the panel builder's responsibility. In the panel builder's responsibility observed.	10.2.5 Lifting	Does not apply, since the entire switchgear needs to be evaluated.
10.3 Degree of protection of assemblies 10.4 Clearances and creepage distances Meets the product standard's requirements. 10.5 Protection against electric shock 10.6 Incorporation of switching devices and components 10.7 Internal electrical circuits and connections 10.8 Connections for external conductors 10.9 Power-frequency electric strength 10.9.2 Power-frequency electric strength 10.9.3 Impulse withstand voltage 10.9.4 Testing of enclosures made of insulating material 10.10 Temperature rise 10.11 Short-circuit rating 10.12 Electromagnetic compatibility 10.13 Mechanical function Does not apply, since the entire switchgear needs to be evaluated. Does not apply, since the entire switchgear needs to be evaluated. Does not apply, since the entire switchgear needs to be evaluated. Does not apply, since the entire switchgear needs to be evaluated. Does not apply, since the entire switchgear needs to be evaluated. Does not apply, since the entire switchgear needs to be evaluated. Does not apply, since the entire switchgear needs to be evaluated. Is the panel builder's responsibility. Is the panel builder's responsibility. Is the panel builder's responsibility. Is the panel builder's responsibility. The specifications for the switchgear must be observed. Is the panel builder's responsibility. The specifications for the switchgear must be observed.	10.2.6 Mechanical impact	Does not apply, since the entire switchgear needs to be evaluated.
10.4 Clearances and creepage distances 10.5 Protection against electric shock 10.6 Incorporation of switching devices and components 10.7 Internal electrical circuits and connections 10.8 Connections for external conductors 10.9.2 Power-frequency electric strength 10.9.3 Impulse withstand voltage 10.9.4 Testing of enclosures made of insulating material 10.10 Temperature rise 10.11 Short-circuit rating 10.12 Electromagnetic compatibility 10.13 Mechanical function Meets the product standard's requirements. Does not apply, since the entire switchgear needs to be evaluated. 10 be evaluated. 10 be not apply, since the entire switchgear needs to be evaluated. Is the panel builder's responsibility. In the specifications for the switchgear must be observed. In the device meets the requirements, provided the information in the instruction	10.2.7 Inscriptions	Meets the product standard's requirements.
Does not apply, since the entire switchgear needs to be evaluated. 10.6 Incorporation of switching devices and components 10.7 Internal electrical circuits and connections 10.8 Connections for external conductors 10.9.2 Power-frequency electric strength 10.9.3 Impulse withstand voltage 10.9.4 Testing of enclosures made of insulating material 10.10 Temperature rise 10.11 Short-circuit rating 10.12 Electromagnetic compatibility 10.13 Mechanical function 10.13 Mechanical function 10.15 Protection against electric shock Does not apply, since the entire switchgear needs to be evaluated. 10.15 the panel builder's responsibility. Is the panel builder's responsibility. The specifications for the switchgear must be observed. Is the panel builder's responsibility. The specifications for the switchgear must be observed. 10.13 Mechanical function 10.14 Edvice meets the requirements, provided the information in the instruction	10.3 Degree of protection of assemblies	Does not apply, since the entire switchgear needs to be evaluated.
10.6 Incorporation of switching devices and components 10.7 Internal electrical circuits and connections 1.8 the panel builder's responsibility. 10.8 Connections for external conductors 1.9 2 Power-frequency electric strength 1.9 3 Impulse withstand voltage 1.9 4 Testing of enclosures made of insulating material 1.0 10 Temperature rise 1.0 1.1 Short-circuit rating 1.0 1.2 Electromagnetic compatibility 1.0 1.3 Mechanical function 1.1 Mechanical function 1.2 Does not apply, since the entire switchgear needs to be evaluated. 1.3 the panel builder's responsibility. 1.4 Is the panel builder's responsibility. 1.5 Is the panel builder's responsibility. 1.6 Is the panel builder's responsibility. 1.7 Internal electrical circuits and connections 1.8 the panel builder's responsibility. 1.9 Is the panel builder's responsibility. The specifications for the switchgear must be observed. 1.0 1.1 Short-circuit rating 1.0 1.2 Electromagnetic compatibility 1.3 Mechanical function 1.4 Evice meets the requirements, provided the information in the instruction	10.4 Clearances and creepage distances	Meets the product standard's requirements.
10.7 Internal electrical circuits and connections 10.8 Connections for external conductors 10.9.2 Power-frequency electric strength 10.9.3 Impulse withstand voltage 10.9.4 Testing of enclosures made of insulating material 10.10 Temperature rise 10.11 Short-circuit rating 10.12 Electromagnetic compatibility 10.13 Mechanical function 10.13 Mechanical function 10.14 Steppens builder's responsibility. The specifications for the switchgear must be observed. 10.15 When panel builder's responsibility. The specifications for the switchgear must be observed. 10.16 Temperature rise 10.17 Electromagnetic compatibility 10.18 Steppens builder's responsibility. The specifications for the switchgear must be observed. 10.19 The device meets the requirements, provided the information in the instruction	10.5 Protection against electric shock	Does not apply, since the entire switchgear needs to be evaluated.
10.7 Internal electrical circuits and connections 10.8 Connections for external conductors 10.9.2 Power-frequency electric strength 10.9.3 Impulse withstand voltage 10.9.4 Testing of enclosures made of insulating material 10.10 Temperature rise 10.11 Short-circuit rating 10.12 Electromagnetic compatibility 10.13 Mechanical function 10.13 Mechanical function 10.14 Steppens builder's responsibility. The specifications for the switchgear must be observed. 10.15 When panel builder's responsibility. The specifications for the switchgear must be observed. 10.16 Temperature rise 10.17 Electromagnetic compatibility 10.18 Steppens builder's responsibility. The specifications for the switchgear must be observed. 10.19 The device meets the requirements, provided the information in the instruction		Does not apply, since the entire switchgear needs to be evaluated.
10.8 Connections for external conductors 10.9.2 Power-frequency electric strength 10.9.3 Impulse withstand voltage 10.9.4 Testing of enclosures made of insulating material 10.10 Temperature rise 10.11 Short-circuit rating 10.12 Electromagnetic compatibility 10.13 Mechanical function Is the panel builder's responsibility. Is the panel builder's responsibility. Not applicable. Is the panel builder's responsibility. The specifications for the switchgear must be observed. 10.12 Electromagnetic compatibility The device meets the requirements, provided the information in the instruction		Is the panel builder's responsibility.
10.9.2 Power-frequency electric strength 10.9.3 Impulse withstand voltage 10.9.4 Testing of enclosures made of insulating material 10.10 Temperature rise 10.11 Short-circuit rating 10.12 Electromagnetic compatibility 10.13 Mechanical function 10.13 Mechanical function 10.14 Is the panel builder's responsibility. The specifications for the switchgear must be observed. 10.15 the panel builder's responsibility. The specifications for the switchgear must be observed. 10.15 He device meets the requirements, provided the information in the instruction		
10.9.3 Impulse withstand voltage 10.9.4 Testing of enclosures made of insulating material 10.10 Temperature rise 10.11 Short-circuit rating 10.12 Electromagnetic compatibility 10.13 Mechanical function 10.13 Mechanical function Is the panel builder's responsibility. The specifications for the switchgear must be observed. 10.13 Mechanical function The device meets the requirements, provided the information in the instruction		
10.9.4 Testing of enclosures made of insulating material 10.10 Temperature rise Not applicable. 10.11 Short-circuit rating Is the panel builder's responsibility. The specifications for the switchgear must be observed. 10.12 Electromagnetic compatibility Is the panel builder's responsibility. The specifications for the switchgear must be observed. 10.13 Mechanical function The device meets the requirements, provided the information in the instruction		
10.10 Temperature rise Not applicable. 10.11 Short-circuit rating Is the panel builder's responsibility. The specifications for the switchgear must be observed. 10.12 Electromagnetic compatibility Is the panel builder's responsibility. The specifications for the switchgear must be observed. 10.13 Mechanical function The device meets the requirements, provided the information in the instruction		
10.11 Short-circuit rating Is the panel builder's responsibility. The specifications for the switchgear must be observed. 10.12 Electromagnetic compatibility Is the panel builder's responsibility. The specifications for the switchgear must be observed. 10.13 Mechanical function The device meets the requirements, provided the information in the instruction		
10.12 Electromagnetic compatibility Is the panel builder's responsibility. The specifications for the switchgear must be observed. 10.13 Mechanical function The device meets the requirements, provided the information in the instruction	·	Is the panel builder's responsibility. The specifications for the switchgear must be
10.13 Mechanical function The device meets the requirements, provided the information in the instruction	10.12 Electromagnetic compatibility	Is the panel builder's responsibility. The specifications for the switchgear must be
	10.13 Mechanical function	

Technical data ETIM 9.0

Low-voltage industrial components (EG000017) / Front element for push button (EC000221)

Electric engineering, automation, process control engineering / Low-voltage switch technology / Command and alarm device / Front element for push-button actuators (ecl@ss13-27-37-12-10 [AKF028019])

[AKF028019])	
Colour button	Green
Number of command positions	1
Construction type lens	Round

Hole diameter	m	nm	22.5
Width opening	m	mm	0
Height opening	m	mm	0
Type of button			High
Suitable for illumination			No
With protective cover			No
Labelled			No
Switching function latching			Yes
Spring-return			No
With front ring			Yes
Material front ring			Plastic
Colour front ring			Titanium
Degree of protection (IP), front side			IP67/IP69K
Degree of protection (NEMA), front side			4X