Light element, LED, blue, base fixing, 12-30VAC/DC, spring clamp connection



M22-CLEDC-B Part no.

EL Number (Norway)	218062 4355779	
General specifications		
Product name		Eaton Moeller® series M22 Accessory LED
Part no.		M22-CLEDC-B
EAN		4015082180621
Product Length/Depth		39 millimetre
Product height		39 millimetre
Product width		10 millimetre
Product weight		0.01 kilogram
Compliances		CE Marked
Certifications		EN 60947-5 CSA Std. C22.2 No. 94-91 CSA Std. C22.2 No. 14-05 VDE IEC 60947-5

CSA-C22.2 No. 94-91 CSA UL CSA File No.: 012528 UL File No.: E29184 IEC/EN 60947-5 CSA Class No.: 3211-03 IEC 60947-5-1 CSA-C22.2 No. 14-05

UL Category Control No.: NKCR

M22 Accessory

UL 508

LED

Cage Clamp is a registered trademark of Wago Kontakttechnik GmbH/Minden, Germany

Fitted with: Light color **General information** Diode Light source Blue

IP20 100,000 h (at 25°C, according to EN60064)

0.8 N·m Ш

6000 V AC AC/DC

Ambient conditions, mechanical

Rated impulse withstand voltage (Uimp)

Mounting position Shock resistance

Product Tradename

Product Sub Type **Catalog Notes**

Features & Functions

Degree of protection

Lifespan, electrical

Overvoltage category

Operating torque

Pollution degree

Voltage type

Product Type

As required

30 g, Mechanical, According to IEC/EN 60068-2-27, Sinusoidal shock 11 ms Mechanical, According to IEC/EN 60068-2-27

1/3

Climatic environmental conditions

Ambient operating temperature - min Ambient operating temperature - max

Ambient storage temperature - min Ambient storage temperature - max

Climatic proofing

-25 °C

70 °C

40 °C 80 °C

> Damp heat, constant, to IEC 60068-2-78 Damp heat, cyclic, to IEC 60068-2-30

Ferninal capacity localid 0.7 - 2.6 mar'	Terminal capacities	
Power consumption Max. 0.26 W	Terminal capacity (solid)	0.75 - 2.5 mm ²
Power consumption Bated insulation voltage (U) 500 V 5	Terminal capacity (stranded)	0.5 - 2.5 mm ²
Rand parational current (1e) - min Rand oparational veltage (Ue) et AC - max Rand oparational veltage (Ue) et AC - max Rand oparational veltage (Ue) et AC - min Rand oparational veltage (Ue) et DC - min 12 V Communication Communication Commercian type Base fixing Commercian type Base fixing Commercian type Commercian Commercian type C	Electrical rating	
Reted operational current liel - min Based operational current liel - max Based operational current liel - max Rated operational voltage lilled at AC - min Rated operational voltage lilled at AC - min Based operational voltage lilled at AC - min Commercian to SmartWire-DT Commercian to SmartWire-DT Commercian to SmartWire-DT Commercian type ContractS Force for positive operating - min Design verification Convertion type Contracts Force for positive operating - min Design verification OW Heat dissipation current-dependent Pord OW Heat dissipation current-dependent Pord OW Heat dissipation or purity - min - which is a significant lilled by the product standard's requirements. Market operational current for specified head assignation (b) OA State loser dissipation on or thermal stability of enclosures Meets the product standard's requirements. 10.2.3.1 Verification of resistance or insulating material is to normal heat 10.2.3.2 Verification of resistance or insulating materials to normal heat 10.2.3.2 Verification of resistance or insulating materials is normal heat 10.2.3.1 Series or protection of assamblies Does not apply, since the entire switchippear needs to be evaluated. 10.2.5 Lifting Does not apply, since the entire switchippear needs to be evaluated. 10.2.6 Incorporation of switching devices and components 10.3.1 Degree of protection of assamblies Does not apply, since the entire switchippear needs to be evaluated. 10.5 Protection applies delection shock Meets the product standard's requirements. 10.6 Connections for ordernal candicutors 10.7 Incorrection of switching devices and components 10.8 Connections for ordernal candicutors 10.9 Protection of particution of assamblies 10.9 Protection	Power consumption	Max. 0.26 W
Rand operational current (le) - max Sand operational voltage (Ue) at AC - max 30 V Rand operational voltage (Ue) at AC - max Rand operational voltage (Ue) at AC - max Rand operational voltage (Ue) at AC - max Rand operational voltage (Ue) at DC - min Commercion to SmartWire-DT Commercion to SmartWire-DT Commercion to SmartWire-DT Commercion to SmartWire-DT Company (Ue) at DC - min Design verification Equipment hear dissipation, current dependent Prid OW Retail dissipation current dependent Prid OW Rand operational current for specified heart dissipation (In) Rand dissipation, current-dependent Prid OW Rand operational current for specified heart dissipation (In) Rand dissipation, on-current-dependent Prid OAS W Rand operational current for specified heart dissipation (In) Rand dissipation, on-current-dependent Prid OAS W Rand operational current for specified heart dissipation (In) Rand dissipation of thermal stability of enclusures Meets the product standard's requirements. Meets the product standard's requirements. 102.2.3 I Verification of thermal stability of enclusures Meets the product standard's requirements. 102.3.1 Resist, of Insalt, mat, to abnormal heart Viro by internal elect. effects Meets the product standard's requirements. 102.5 Itiming Oes not apply, since the entire swritchipper needs to be evaluated. 102.6 Meets the product standard's requirements. 102.6 Protection operated electric shock Does not apply, since the entire swritchipper needs to be evaluated. 103.6 Protection against electric shock Does not apply, since the entire swritchipper needs to be evaluated. 104.6 Incerporation of swritching devices and components 105.7 Internal electric all circuits and commercions 106.8 Commercions of external conductors 107.1 Internal electric all circuits and commercions 108.1 Resident and protect standard's requirements. 109.2	Rated insulation voltage (Ui)	500 V
Rated operational voltage (Ue) at AC - mix Rated operational voltage (Ue) at AC - mix Rated operational voltage (Ue) at DC - mix Commercion to SmartWire-DT Commercion to SmartWire-DT Commercion type Contacts Force for positive opening - min Design verification Commercion type Contacts Force for positive opening - min ON Design verification Commercion type Contacts Force for positive opening - min ON Rated dissipation cupacity Pdias OW Heat dissipation capacity Pdias OW Rated dissipation capacity Pdias OW Rated perational current for perification of the series stability of enclosures All Perification of the terms stability of enclosures 10.2.3 Verification of resistance of insulating materials to normal heat 10.2.3.2 Verification of resistance of insulating materials to normal heat 10.2.3 Verification of resistance in ensulating materials to normal heat 10.2.3 Recision of resistance in ensulating materials to normal heat 10.2.4 Recisional impact 10.2.5 Lifting Once not apply, since the centre exvictopear needs to be evaluated. 10.2.5 Necholance impact 10.2.6 Recisional impact 10.2.6 Recisional impact 10.2.7 Inscriptions Meets the product standard's requirements. 10.2.8 Descriptions Meets the product standard's requirements. 10.2.9 Inscriptions Meets the product standard's requirements. 10.2.9 Inscriptions Meets the product standard's requirements. 10.2.9 Inscriptions of the entire exvitchegear needs to be evaluated. 10.2.1 Inscriptions of the entire exvitchegear needs to be evaluated. 10.2.2 Inscriptions of extension of switching devices and connections 10.2.2 Inscriptions of extension of exten	Rated operational current (le) - min	5 mA
Rated operational voltage (Ue) at DC - mix Rated operational current for apending - min Rated operational current for apending - min Rated dissipation, current-dependent Pvid Rated operational current for apending heat dissipation (In) Rated dissipation per pole, current-dependent Pvid Rated operational current for apending heat dissipation (In) Rated operational current for apending heat dissipation (In) Rated operational current for apending heat dissipation (In) Rated operational current for apending materials to morral heat Rated operational current for apending materials to morral heat Rated operational voltage (Ue) rated at Rated Rate	Rated operational current (le) - max	14 mA
Retot operational voltage (Ue) at DC - mins Communication Commercion to Smart/Wire-DT Connection type Base fixing Contacts Force for positive opening - min Design verification Equipment heat dissipation, current-dependent Pvid Pest dissipation or apacity Pdiss Heat dissipation or apacity Pdiss Heat dissipation or per polic, current-dependent Pvid OW Retated operational current or specified heat dissipation (In) Static heat dissipation, non-current-dependent Pvid OW Retated operational current or specified heat dissipation (In) Static heat dissipation, non-current-dependent Pvid OW Static heat dissipation, non-current-dependent Pvid OASW 10.2.2 Forcesion resistance Mests the product standard's requirements. 102.2.3 Verification of resistance of insulating materials to normal heat 102.3.2 Verification of resistance of insulating materials to normal heat 102.3.2 Positication of resistance of insulating materials to normal heat 102.3.2 Positication of resistance of insulating materials to normal heat 102.4.3 Positication of resistance of insulating materials to normal heat 102.5 Ufficial on the ministry of th	Rated operational voltage (Ue) at AC - max	30 V
Rated operational voltage (Ue) at DC - min Commercion to SmartWire-DT Connection type Contacts Force for positive opening - min Design verification Equipment heat dissipation, current-dependent Pvid Heat dissipation per pole, current-dependent Pvid DW Heat dissipation non-current-dependent Pvid Rated operational current for specified heat dissipation (In) Static heat dissipation resistance Meats the product standard's requirements. 10.2.2 Force for positive of including materials to normal heat 10.2.3 Verification of termal stability of enclosures Meats the product standard's requirements. Does not apply, since the entire switchpear needs to be evaluated. Meats the product standard's requirements. Does not apply, since the entire switchpear needs to be evaluated. Meats the product standard's requirements. The panel builder's responsibility. Is the panel builder's responsibility. Is the panel builder's responsibility. Is	Rated operational voltage (Ue) at AC - min	12 V
Connection to SmartWire-DT Connection Contacts Force for positive opening - min Design verification Equipment heat dissipation, current-dependent Pvid W Heat dissipation capacity Pdiss W Rated operational current for specified heat dissipation (n) Rated deperational current for specified heat dissipation (n) Rated deperation of desirations Rests the product standard's requirements. Rest the product standard's requirements. R	Rated operational voltage (Ue) at DC - max	30 V
Connection to SmartWire-DT Connection type Contacts Force for positive opening - min Design verification Equipment heat dissipation, current-dependent Pvid Heat dissipation capacity Pdiss Heat dissipation per pole, current-dependent Pvid Heat dissipation, non-current-dependent Pvid Heat dissipation per pole, current-dependent Pvid Heat dissipation, non-current-dependent Pvid Heat dissipation in the manual per pole per pol per p	Rated operational voltage (Ue) at DC - min	12 V
Connection type Contacts Force for positive opening - min Design verification Equipment heat dissipation, current-dependent Pvid Heat dissipation per pole, current-dependent Pvid Heat dissipation per pole, current-dependent Pvid Authority of the dissipation per pole, current-dependent Pvid Bated operational current for specified heat dissipation (In) Static heat dissipation, non-current-dependent Pvis Authority of the dissipation, non-current-dependent Pvis Bated operational current for specified heat dissipation (In) Static heat dissipation, non-current-dependent Pvis Authority of the dissipation, non-current-dependent Pvis Bated operational current for specified heat dissipation (In) Static heat dissipation, non-current-dependent Pvis Do 2, Authority of the dissipation, non-current-dependent Pvis Meets the product standard's requirements. Does not apply, since the entries evritchpear needs to be evaluated. Does not apply, since the entries evritchpear needs to be ovaluated. Does not apply, since the entries evritchpear needs to be ovaluated. Authority of the dissipation of severichpear needs to be ovaluated. Does not apply, since the entries evritchpear needs to be ovaluated. Does not apply, since the entries evritchpear needs to be ovaluated. Does not apply, since the entries evritchpear needs to be ovaluated. Does not apply, since the entries evritchpear needs to be ovaluated. Does not apply, since the entries evritchpear needs to be ovaluated. Does not apply, since the entries evritchpear needs to be ovaluated. In 18 the panel builder's re	Communication	
Contacts Force for positive opening - min Design verification Equipment heat dissipation, current-dependent Pvid Heat dissipation per pole, current-dependent Pvid Rated operational current for specified heat dissipation (In) Retes the product standard's requirements. Meets the product standard's requirements. Meets the product standard's requirements. Does not apply, since the entire switchgear needs to be evaluated. In) 2.5 Lifting Does not apply, since the entire switchgear needs to be evaluated. Meets the product standard's requirements. Does not apply, since the entire switchgear needs to be evaluated. Retes the product standard's requirements. Does not apply, since the entire switchgear needs to be evaluated. Does not apply, since the entire switchgear needs to be evaluated. Retes the product standard's requirements. Does not apply, since the entire switchgear needs to be evaluated. Retes the product standard's requirements. Does not apply, since the entire switchgear needs to be evaluated. Retes the panel builder's responsibility. Reterior responsibility. R	Connection to SmartWire-DT	No
Perior for positive opening - min Design verification Equipment heat dissipation, current-dependent Pvid Heat dissipation capacity Pelas OW Heat dissipation per pola, current-dependent Pvid Rated operational current for specified heat dissipation (In) Static heat dissipation, non-current-dependent Pvid Rated operational current for specified heat dissipation (In) Static heat dissipation, non-current-dependent Pvs 0.45 W 10.22 Corrosion resistance Meets the product standard's requirements. 10.23.1 Verification of thermal stability of enclosures Meets the product standard's requirements. 10.23.2 Verification of resistance of insulating materials to normal heat 10.23.2 Verification of thermal stability of enclosures 10.24 Resistance to ultra-violet (UV) radiation 10.25 Lifting Does not apply, since the entire switchgear needs to be evaluated. 10.27 Inscriptions 10.28 Dees not apply, since the entire switchgear needs to be evaluated. 10.29 Protection against electric shock Does not apply, since the entire switchgear needs to be evaluated. 10.4 Clearances and creepage distances 10.5 Protection against electric shock Does not apply, since the entire switchgear needs to be evaluated. 10.6 Connections for external connections 10.7 Internal electrical circuits and connections 10.8 Connections of assembling 10.9 Power-frequency electric strength 10.9 Power-frequency electric strength 10.9 Temperature rise The panel builder's responsibility. 10.1 Short-circuit rating 10.1 Electromagnetic compatibility 10.1 Short-circuit rating 10.1 Short-circuit rating 10.2 Device the entire switchgear for the temperature rise calculation. Eaton will provide heat dissipation data for the devices. 10.11 Short-circuit rating 10.10 Temperature rise The panel builder's responsibility. The specifications for the switchgear must be observed. 10.13 Mechanical function The device meets the requirements, provided the information in the instruction	Connection type	Base fixing
Perior for positive opening - min Design verification Equipment heat dissipation, current-dependent Pvid Heat dissipation capacity Pelas OW Heat dissipation per pola, current-dependent Pvid Rated operational current for specified heat dissipation (In) Static heat dissipation, non-current-dependent Pvid Rated operational current for specified heat dissipation (In) Static heat dissipation, non-current-dependent Pvs 0.45 W 10.22 Corrosion resistance Meets the product standard's requirements. 10.23.1 Verification of thermal stability of enclosures Meets the product standard's requirements. 10.23.2 Verification of resistance of insulating materials to normal heat 10.23.2 Verification of thermal stability of enclosures 10.24 Resistance to ultra-violet (UV) radiation 10.25 Lifting Does not apply, since the entire switchgear needs to be evaluated. 10.27 Inscriptions 10.28 Dees not apply, since the entire switchgear needs to be evaluated. 10.29 Protection against electric shock Does not apply, since the entire switchgear needs to be evaluated. 10.4 Clearances and creepage distances 10.5 Protection against electric shock Does not apply, since the entire switchgear needs to be evaluated. 10.6 Connections for external connections 10.7 Internal electrical circuits and connections 10.8 Connections of assembling 10.9 Power-frequency electric strength 10.9 Power-frequency electric strength 10.9 Temperature rise The panel builder's responsibility. 10.1 Short-circuit rating 10.1 Electromagnetic compatibility 10.1 Short-circuit rating 10.1 Short-circuit rating 10.2 Device the entire switchgear for the temperature rise calculation. Eaton will provide heat dissipation data for the devices. 10.11 Short-circuit rating 10.10 Temperature rise The panel builder's responsibility. The specifications for the switchgear must be observed. 10.13 Mechanical function The device meets the requirements, provided the information in the instruction	Contacts	
Design verification Equipment heat dissipation, current-dependent Pvid 0W Heat dissipation capacity Pdiss 0W Rated operational current for specified heat dissipation (In) Static heat dissipation, un-current-dependent Pvid 0W Rated operational current for specified heat dissipation (In) 10.2.2 Corrosion resistance Meets the product standard's requirements. 10.2.3 Verification of thermal stability of enclosures Meets the product standard's requirements. 10.2.3 Verification of resistance of insulating materials to normal heat Meets the product standard's requirements. 10.2.3 Verification of translation and heat fire by internal elect. effects Meets the product standard's requirements. 10.2.4 Resistance to ultra-violet (IVV) radiation Meets the product standard's requirements. 10.2.5 Lifting Des not apply, since the entire switchgear needs to be evaluated. 10.2.5 Lifting Des not apply, since the entire switchgear needs to be evaluated. 10.2.6 Meets the product standard's requirements. 10.3 Degree of protection of assemblies Des not apply, since the entire switchgear needs to be evaluated. 10.4 Clearances and creepage distances Meets the product standard's requirements. 10.5 Protection against electric shock Des not apply, since the entire switchgear needs to be evaluated. 10.6 Connections of assemblies Des not apply, since the entire switchgear needs to be evaluated. 10.7 Internal electric slicicuits and components Des not apply, since the entire switchgear needs to be evaluated. 10.8 Connections for external conductors Is the panel builder's responsibility. 10.9 Power-frequency electric strength Is the panel builder's responsibility. 10.9 Power-frequency electric strength Is the panel builder's responsibility. 10.9 Power-frequency electric strength Is the panel builder's responsibility. 10.1 Thermal electric in circuit rating Is the panel builder's responsibility. 10.2 Electromagnetic compatibility 10.3 Meets have product data for the devices. 10.1 Short-circuit rating Is the panel builde	Force for positive opening - min	0 N
Equipment heat dissipation, current-dependent Pvid Heat dissipation capacity Pdiss 0 W Heat dissipation per pole, current-dependent Pvid 0 DW Rated operational current for specified heat dissipation (In) 0 A Static heat dissipation, non-current-dependent Pvid 0 DA Static heat dissipation of thermal stability of enclosures 0 DA Meets the product standard's requirements. 0 DA Static heat the product standard's	Design verification	
Heat dissipation capacity Pdiss Heat dissipation per pole, current-dependent Pvid Rated operational current for specified heat dissipation (In) Static heat dissipation, non-current-dependent Pvs 0.45 W 0.45 W 0.22 Corrosion resistance 10.23.1 Verification of thermal stability of enclosures 10.23.2 Verification of thermal stability of enclosures 10.23.3 Resist, of insul, mat, to abnormal heat/fire by internal elect. effects 10.24 Resistance to ultra-violet (UV) radiation 10.25 Lifting 10.26 Mechanical impact 10.27 Inscriptions 10.30 Degree of protection of assemblies 10.30 Degree of protection of assemblies 10.40 Clearances and creepage distances 10.54 Protection against electric shock 10.55 Incorporation of switching devices and components 10.56 Incorporation of switching devices and components 10.56 Incorporation of switching devices and components 10.56 Incorporation of switching devices and components 10.57 Instrail electrical circuits and connections 10.58 Instrail electrical circuits and connections 10.59 Power-frequency electric strength 10.51 Instrail electrical circuits are dominated in the panel builder's responsibility. 10.52 Power-frequency electric strength 10.53 Impulse withstand voltage 10.54 Instrail electrical circuits are dominated in the panel builder's responsibility. 10.55 Incorporation of exitering devices and components 10.56 Incorporation of switching devices and components 10.57 Instrail electrical circuits and connections 10.58 Instrail electrical circuits and connections 10.59 Instrail electrical circuits and connections 10.50 Instrail electrical circuits and connections 10.51 Instrail electrical circuits and connections 10.52 Instrail electrical circuits and connections 10.53 Inspect electric strength 10.54 Instrail electrical circuits and connections 10.55 Instrail electrical circuits and connections 10.56 Incorporation of switching electric strength 10.57 Instrail electrical circuits and connections 10.58 Instrail electrical circuits and con	•	0 W
Heat dissipation per pole, current-dependent Pvid Rated operational current for specified heat dissipation (In) Static heat dissipation, non-current-dependent Pvs 10.2.2 Corrosion resistance Meets the product standard's requirements. 10.2.3.1 Verification of thermal stability of enclosures 10.2.3.2 Verification of resistance of insulating materials to normal heat 10.2.3.2 Verification of resistance of insulating materials to normal heat 10.2.3.2 Verification of resistance of insulating materials to normal heat 10.2.3.3 Resist of insul, mat to abnormal heat/fire by internal elect. effects 10.2.4 Resistance to ultra-violet (UV) radiation Meets the product standard's requirements. 10.2.5 Lifting Does not apply, since the entire switchgear needs to be evaluated. 10.2.7 Inscriptions Meets the product standard's requirements. 10.3 Degree of protection of assemblies Does not apply, since the entire switchgear needs to be evaluated. 10.4 Clearances and creepage distances Meets the product standard's requirements. 10.5 Protection against electric shock Does not apply, since the entire switchgear needs to be evaluated. 10.6 Incorporation of switching devices and components Does not apply, since the entire switchgear needs to be evaluated. 10.7 Internal electrical circuits and connections Is the panel builder's responsibility. 10.9.2 Power-frequency electric strength Is the panel builder's responsibility. 10.9.3 Impulse withstand voltage Is the panel builder's responsibility. 10.9.4 Testing of enclosures made of insulating material 10.10 Temperature rise The panel builder's responsibility. 10.11 Short-circuit rating 10.12 Electromagnetic compatibility 10.13 Mechanical function The device meets the requirements, provided the information in the instruction		
Rated operational current for specified heat dissipation (In) Static heat dissipation, non-current-dependent Pvs 10.22 Corrosion resistance Meets the product standard's requirements. 10.23.1 Verification of thermal stability of enclosures Meets the product standard's requirements. 10.23.2 Nerification of resistance of insulating materials to normal heat 10.23.3 Resist. of insul. mat. to abnormal heat/fire by internal elect. effects 10.24 Resistance to ultra-violet (UV) radiation 10.25 Litting Does not apply, since the entire switchgear needs to be evaluated. 10.27 Inscriptions Does not apply, since the entire switchgear needs to be evaluated. 10.27 Inscriptions Meets the product standard's requirements. 10.3 Degree of protection of assemblies Does not apply, since the entire switchgear needs to be evaluated. 10.4 Clearances and creepage distances Meets the product standard's requirements. 10.5 Protection against electric shock Does not apply, since the entire switchgear needs to be evaluated. 10.6 Incorporation of switching devices and components Does not apply, since the entire switchgear needs to be evaluated. 10.7 Internal electrical circuits and connections Is the panel builder's responsibility. 10.9.2 Power-frequency electric strength Is the panel builder's responsibility. 10.9.3 Impulse withstand voltage Is the panel builder's responsibility. 10.9.4 Testing of enclosures made of insulating material 10.10 Temperature rise The panel builder's responsibility. The specifications for the switchgear must be observed. 10.11 Short-circuit rating Let the panel builder's responsibility. The specifications for the switchgear must be observed. 10.13 Mechanical function The device meets the requirements, provided the information in the instruction	·	
Static heat dissipation, non-current-dependent Pvs 10.2.2 Corrosion resistance 10.2.3.1 Verification of thermal stability of enclosures 10.2.3.2 Verification of resistance of insulating materials to normal heat 10.2.3.3 Resists. of insul. mat. to abnormal heat/fire by internal elect. effects 10.2.4 Resistance to ultra-violet (UV) radiation 10.2.5 Lifting 10.2.5 Lifting 10.2.5 Undershaped of protection of assemblies 10.2.7 Inscriptions 10.3 Degree of protection of assemblies 10.3 Degree of protection of assemblies 10.4 Clearances and creepage distances 10.5 Protection against electric shock 10.6 Incorporation of switching devices and components 10.7 Internal electrical circuits and connections 10.9 Connections for external conductors 10.9.2 Power-frequency electric strength 10.9.3 Impulse withstand voltage 10.9.4 Testing of enclosures made of insulating material 10.10 Temperature rise 10.11 Short-circuit rating 10.13 Mechanical function 10.13 Mechanical function 10.13 Mechanical function 10.14 Electromagnetic compatibility 10.15 Mechanical function 10.16 Meets the product standard's requirements. 10.45 Weets the product standard's requirements. 10.5 Protection against electric shock 10.6 Does not apply, since the entire switchgear needs to be evaluated. 10.7 Internal electrical circuits and connections 10.9 Internal electrical circuits and connections 10.9 Internal electrical circuits and connections 10.9 Internal electrical circuits and connections 10.10 Temperature rise entire switchgear needs to be evaluated. 10.10 Temperature rise 10.11 Short-circuit rating 10.12 Electromagnetic compatibility. 10.13 Mechanical function 10.14 Meets the product standard's requirements. 10.15 Meets the product standard's requirements. 10.16 Meets the product standard's requirements. 10.17 Internal electrical circuits and connections 10.18 the panel builder's responsibility. 10.19 Temperature rise 10.10 Temperature rise 10.11 Short-circuit rating 10.12 Electromagnetic compatibility		
10.2.2 Corrosion resistance 10.2.3.1 Verification of thermal stability of enclosures 10.2.3.2 Verification of thermal stability of enclosures 10.2.3.3 Resist. of insul. mat. to abnormal heat/fire by internal elect. effects 10.2.4 Resistance to ultra-violet (UV) radiation 10.2.5 Lifting 10.2.6 Mechanical impact 10.2.7 Inscriptions 10.3 Dees not apply, since the entire switchgear needs to be evaluated. 10.4 Clearances and creepage distances 10.5 Protection against electric shock 10.6 Incorporation of switching devices and components 10.7 Internal electrical circuits and connections 10.8 Connections for external conductors 10.9 Power-frequency electric strength 10.9.4 Testing of enclosures made of insulating material 10.10 Temperature rise 10.11 Short-circuit rating 10.12 Electromagnetic compatibility 10.13 Mechanical function Meets the product standard's requirements. Meets the product standard's requirements. Does not apply, since the entire switchgear needs to be evaluated. Does not apply, since the entire switchgear needs to be evaluated. Does not apply, since the entire switchgear needs to be evaluated. Does not apply, since the entire switchgear needs to be evaluated. Does not apply, since the entire switchgear needs to be evaluated. Does not apply, since the entire switchgear needs to be evaluated. 10.5 Protection against electric shock Does not apply, since the entire switchgear needs to be evaluated. 10.6 Incorporation of switching devices and components 10.8 Connections for external conductors 1 sthe panel builder's responsibility. 10.9.2 Power-frequency electric strength 1 sthe panel builder's responsibility. 10.9.4 Testing of enclosures made of insulating material 1 sthe panel builder's responsibility. 10.10 Temperature rise The panel builder's responsibility. The specifications for the switchgear must be observed. 10.12 Electromagnetic compatibility 1 sthe panel builder's responsibility. The specifications for the switchgear must be observed.		
10.2.3.1 Verification of thermal stability of enclosures 10.2.3.2 Verification of resistance of insulating materials to normal heat 10.2.3.2 Resist. of insul. mat. to abnormal heat/fire by internal elect. effects 10.2.4 Resistance to ultra-violet (UV) radiation 10.2.5 Lifting 10.2.6 Mechanical impact 10.2.7 Inscriptions 10.3.0 Begree of protection of assemblies 10.4 Clearances and creepage distances 10.5 Protection against electric shock 10.6 Incorporation of switching devices and components 10.6 Incorporation of switching devices and components 10.7 Internal electrical circuits and connections 10.8 Connections for external conductors 10.9 Power-frequency electric strength 10.9.2 Power-frequency electric strength 10.9.3 Impulse withstand voltage 10.10 Temperature rise 10.11 Short-circuit rating 10.12 Electromagnetic compatibility 10.13 Mechanical function Meets the product standard's requirements. Does not apply, since the entire switchgear needs to be evaluated. Does not apply, since the entire switchgear needs to be evaluated. Does not apply, since the entire switchgear needs to be evaluated. Does not apply, since the entire switchgear needs to be evaluated. Does not apply, since the entire switchgear needs to be evaluated. Does not apply, since the entire switchgear needs to be evaluated. Does not apply, since the entire switchgear needs to be evaluated. Does not apply, since the entire switchgear needs to be evaluated. Does not apply, since the entire switchgear needs to be evaluated. Does not apply, since the entire switchgear needs to be evaluated. Does not apply, since the entire switchgear needs to be evaluated. Does not apply, since the entire switchgear needs to be evaluated. Does not apply, si		
10.2.32 Verification of resistance of insulating materials to normal heat 10.2.33 Resist. of insul. mat. to abnormal heat/fire by internal elect. effects Meets the product standard's requirements. 10.2.4 Resistance to ultra-violet (UV) radiation Meets the product standard's requirements. 10.2.5 Lifting Does not apply, since the entire switchgear needs to be evaluated. 10.2.6 Mechanical impact Does not apply, since the entire switchgear needs to be evaluated. 10.2.7 Inscriptions Meets the product standard's requirements. 10.3 Degree of protection of assemblies Does not apply, since the entire switchgear needs to be evaluated. 10.4 Clearances and creepage distances Meets the product standard's requirements. 10.5 Protection against electric shock Does not apply, since the entire switchgear needs to be evaluated. 10.6 Incorporation of switching devices and components Does not apply, since the entire switchgear needs to be evaluated. 10.7 Internal electrical circuits and connections Is the panel builder's responsibility. 10.9.2 Power-frequency electric strength Is the panel builder's responsibility. 10.9.3 Impulse withstand voltage Is the panel builder's responsibility. 10.9.4 Testing of enclosures made of insulating material Is the panel builder's responsibility. 10.10 Temperature rise The panel builder's responsibility. 10.11 Short-circuit rating Is the panel builder's responsibility. The specifications for the switchgear must be observed. 10.12 Electromagnetic compatibility The device meets the requirements, provided the information in the instruction		
10.2.3.3 Resist. of insul. mat. to abnormal heat/fire by internal elect. effects 10.2.4 Resistance to ultra-violet (UV) radiation Meets the product standard's requirements. 10.2.5 Lifting Does not apply, since the entire switchgear needs to be evaluated. 10.2.6 Mechanical impact Does not apply, since the entire switchgear needs to be evaluated. 10.2.7 Inscriptions Meets the product standard's requirements. 10.3 Degree of protection of assemblies Does not apply, since the entire switchgear needs to be evaluated. 10.4 Clearances and creepage distances Meets the product standard's requirements. 10.5 Protection against electric shock Does not apply, since the entire switchgear needs to be evaluated. 10.6 Incorporation of switching devices and components Does not apply, since the entire switchgear needs to be evaluated. 10.7 Internal electrical circuits and connections Is the panel builder's responsibility. 10.9.2 Power-frequency electric strength Is the panel builder's responsibility. 10.9.3 Impulse withstand voltage Is the panel builder's responsibility. 10.9.4 Testing of enclosures made of insulating material 10.10 Temperature rise The panel builder's responsibility. 10.11 Short-circuit rating 10.12 Electromagnetic compatibility 10.13 Mechanical function The device meets the requirements, provided the information in the instruction		
10.24 Resistance to ultra-violet (UV) radiation Meets the product standard's requirements. 10.25 Lifting Does not apply, since the entire switchgear needs to be evaluated. 10.26 Mechanical impact Does not apply, since the entire switchgear needs to be evaluated. 10.27 Inscriptions Meets the product standard's requirements. 10.3 Degree of protection of assemblies Does not apply, since the entire switchgear needs to be evaluated. Meets the product standard's requirements. Meets the product standard's requirements. Does not apply, since the entire switchgear needs to be evaluated. 10.5 Protection against electric shock Does not apply, since the entire switchgear needs to be evaluated. 10.6 Incorporation of switching devices and components 10.7 Internal electrical circuits and connections 10.8 Connections for external conductors 10.9.2 Power-frequency electric strength 10.9.3 Impulse withstand voltage 10.9.4 Testing of enclosures made of insulating material 10.9.4 Testing of enclosures made of insulating material 10.10 Temperature rise 10.11 Short-circuit rating 10.12 Electromagnetic compatibility 10.13 Mechanical function Meets the product standard's requirements. Does not apply, since the entire switchgear needs to be evaluated. Does not apply, since the entire switchgear needs to be evaluated. Does not apply, since the entire switchgear needs to be evaluated. Does not apply, since the entire switchgear needs to be evaluated. Is the panel builder's responsibility. Is the panel builder's responsibility. Is the panel builder's responsibility. 10.11 Short-circuit rating Is the panel builder's responsibility. The specifications for the switchgear must be observed. 10.13 Mechanical function The device meets the requirements, provided the information in the instruction	·	
10.2.5 Lifting Does not apply, since the entire switchgear needs to be evaluated. 10.2.6 Mechanical impact Does not apply, since the entire switchgear needs to be evaluated. 10.2.7 Inscriptions Meets the product standard's requirements. Does not apply, since the entire switchgear needs to be evaluated. 10.4 Clearances and creepage distances Meets the product standard's requirements. Does not apply, since the entire switchgear needs to be evaluated. 10.5 Protection against electric shock Does not apply, since the entire switchgear needs to be evaluated. 10.6 Incorporation of switching devices and components Does not apply, since the entire switchgear needs to be evaluated. 10.7 Internal electrical circuits and connections 10.8 Connections for external conductors 10.9.2 Power-frequency electric strength 10.9.3 Impulse withstand voltage 10.9.4 Testing of enclosures made of insulating material 10.9.4 Testing of enclosures made of insulating material 10.10 Temperature rise The panel builder's responsibility. 10.11 Short-circuit rating Is the panel builder's responsibility. The specifications for the switchgear must be observed. 10.12 Electromagnetic compatibility Is the panel builder's responsibility. The specifications for the switchgear must be observed. 10.13 Mechanical function The device meets the requirements, provided the information in the instruction		
10.26 Mechanical impact 10.2.7 Inscriptions Meets the product standard's requirements. 10.3 Degree of protection of assemblies 10.4 Clearances and creepage distances Meets the product standard's requirements. 10.5 Protection against electric shock 10.6 Incorporation of switching devices and components 10.7 Internal electrical circuits and connections 10.8 Connections for external conductors 10.9.2 Power-frequency electric strength 10.9.3 Impulse withstand voltage 10.9.4 Testing of enclosures made of insulating material 10.10 Temperature rise 10.11 Short-circuit rating 10.12 Electromagnetic compatibility 10.13 Mechanical function The device meets the requirements, provided the information in the instruction		
10.27 Inscriptions 10.3 Degree of protection of assemblies 10.4 Clearances and creepage distances 10.5 Protection against electric shock 10.6 Incorporation of switching devices and components 10.7 Internal electrical circuits and connections 10.8 Connections for external conductors 10.9 Power-frequency electric strength 10.9.3 Impulse withstand voltage 10.9.4 Testing of enclosures made of insulating material 10.10 Temperature rise 10.11 Short-circuit rating 10.12 Electromagnetic compatibility 10.13 Mechanical function Meets the product standard's requirements. Does not apply, since the entire switchgear needs to be evaluated. Does not apply, since the entire switchgear needs to be evaluated. Is the panel builder's responsibility. Is the panel builder's responsibility. Is the panel builder's responsibility. In panel builder's responsibility. The specifications for the switchgear must be observed. In the panel builder's responsibility. The specifications for the switchgear must be observed. In the panel builder's responsibility. The specifications for the switchgear must be observed.	•	11.7
10.3 Degree of protection of assemblies 10.4 Clearances and creepage distances Meets the product standard's requirements. 10.5 Protection against electric shock Does not apply, since the entire switchgear needs to be evaluated. 10.6 Incorporation of switching devices and components Does not apply, since the entire switchgear needs to be evaluated. 10.7 Internal electrical circuits and connections Is the panel builder's responsibility. 10.8 Connections for external conductors Is the panel builder's responsibility. 10.9.2 Power-frequency electric strength Is the panel builder's responsibility. 10.9.4 Testing of enclosures made of insulating material 10.10 Temperature rise The panel builder's responsibility. 10.11 Short-circuit rating Is the panel builder is responsibility. The specifications for the switchgear must be observed. 10.12 Electromagnetic compatibility Is the panel builder's responsibility. The specifications for the switchgear must be observed. 10.13 Mechanical function The device meets the requirements, provided the information in the instruction	·	
10.4 Clearances and creepage distances 10.5 Protection against electric shock 10.6 Incorporation of switching devices and components 10.7 Internal electrical circuits and connections 10.8 Connections for external conductors 10.9 Power-frequency electric strength 10.9.4 Testing of enclosures made of insulating material 10.10 Temperature rise 10.11 Short-circuit rating 10.12 Electromagnetic compatibility 10.13 Mechanical function Meets the product standard's requirements. Does not apply, since the entire switchgear needs to be evaluated. 10.6 Does not apply, since the entire switchgear needs to be evaluated. Is the panel builder's responsibility. The panel builder is responsibility. Is the panel builder is responsibility. Is the panel builder's responsibility. Is the panel builder's responsibility. The panel builder's responsibility. The specifications for the switchgear must be observed. Is the panel builder's responsibility. The specifications for the switchgear must be observed. The device meets the requirements, provided the information in the instruction	· ·	· · · · · · · · · · · · · · · · · · ·
Does not apply, since the entire switchgear needs to be evaluated. 10.6 Incorporation of switching devices and components 10.7 Internal electrical circuits and connections 10.8 Connections for external conductors 10.9.2 Power-frequency electric strength 10.9.3 Impulse withstand voltage 10.9.4 Testing of enclosures made of insulating material 10.10 Temperature rise 10.11 Short-circuit rating 10.12 Electromagnetic compatibility 10.13 Mechanical function Does not apply, since the entire switchgear needs to be evaluated. 10 be evaluated. 10 be not apply, since the entire switchgear needs to be evaluated. 10 be evaluated. 10 the panel builder's responsibility. 10 the panel builder's responsibility. 10 the panel builder's responsibility. 10 the panel builder is responsibility. 10 the panel builder is responsibility. 10 the panel builder's responsibility. The specifications for the switchgear must be observed. 10.13 Mechanical function The device meets the requirements, provided the information in the instruction		11.77
10.7 Internal electrical circuits and connections 1s the panel builder's responsibility. 10.8 Connections for external conductors 1s the panel builder's responsibility. 10.9.2 Power-frequency electric strength 1s the panel builder's responsibility. 10.9.3 Impulse withstand voltage 1s the panel builder's responsibility. 1s the panel builder's responsibility. 1s the panel builder's responsibility. 1c the panel builder's responsibility. 1c the panel builder is responsibility. The specifications for the switchgear must be observed. 1c the panel builder's responsibility. The specifications for the switchgear must be observed. 1c the panel builder's responsibility. The specifications for the switchgear must be observed. 1c the panel builder's responsibility. The specifications for the switchgear must be observed. 1c the panel builder's responsibility. The specifications for the switchgear must be observed. 1c the panel builder's responsibility. The specifications for the switchgear must be observed. 1c the panel builder's responsibility. The specifications for the switchgear must be observed.	· ·	Does not apply, since the entire switchgear needs to be evaluated.
10.7 Internal electrical circuits and connections 1s the panel builder's responsibility. 10.8 Connections for external conductors 1s the panel builder's responsibility. 10.9.2 Power-frequency electric strength 1s the panel builder's responsibility. 10.9.3 Impulse withstand voltage 1s the panel builder's responsibility. 1s the panel builder's responsibility. 1s the panel builder's responsibility. 1c the panel builder's responsibility. 1c the panel builder is responsibility. The specifications for the switchgear must be observed. 1c the panel builder's responsibility. The specifications for the switchgear must be observed. 1c the panel builder's responsibility. The specifications for the switchgear must be observed. 1c the panel builder's responsibility. The specifications for the switchgear must be observed. 1c the panel builder's responsibility. The specifications for the switchgear must be observed. 1c the panel builder's responsibility. The specifications for the switchgear must be observed. 1c the panel builder's responsibility. The specifications for the switchgear must be observed.	10.6 Incorporation of switching devices and components	Does not apply, since the entire switchgear needs to be evaluated.
10.9.2 Power-frequency electric strength 10.9.3 Impulse withstand voltage 10.9.4 Testing of enclosures made of insulating material 10.10 Temperature rise 10.11 Short-circuit rating 10.12 Electromagnetic compatibility 10.13 Mechanical function 10.13 Mechanical function Is the panel builder's responsibility. Is the panel builder is responsibility. The panel builder is responsibility. The specifications for the switchgear must be observed. 10.12 Electromagnetic compatibility The device meets the requirements, provided the information in the instruction	10.7 Internal electrical circuits and connections	Is the panel builder's responsibility.
10.9.3 Impulse withstand voltage 10.9.4 Testing of enclosures made of insulating material 10.10 Temperature rise 10.11 Short-circuit rating 10.12 Electromagnetic compatibility 10.13 Mechanical function Is the panel builder's responsibility. The panel builder is responsible for the temperature rise calculation. Eaton will provide heat dissipation data for the devices. Is the panel builder's responsibility. The specifications for the switchgear must be observed. 10.12 Electromagnetic compatibility The device meets the requirements, provided the information in the instruction	10.8 Connections for external conductors	Is the panel builder's responsibility.
10.9.4 Testing of enclosures made of insulating material 10.10 Temperature rise The panel builder is responsibility. The panel builder is responsible for the temperature rise calculation. Eaton will provide heat dissipation data for the devices. 10.11 Short-circuit rating Is the panel builder's responsibility. The specifications for the switchgear must be observed. 10.12 Electromagnetic compatibility Is the panel builder's responsibility. The specifications for the switchgear must be observed. 10.13 Mechanical function The device meets the requirements, provided the information in the instruction	10.9.2 Power-frequency electric strength	Is the panel builder's responsibility.
10.10 Temperature rise The panel builder is responsible for the temperature rise calculation. Eaton will provide heat dissipation data for the devices. 10.11 Short-circuit rating Is the panel builder's responsibility. The specifications for the switchgear must be observed. 10.12 Electromagnetic compatibility Is the panel builder's responsibility. The specifications for the switchgear must be observed. 10.13 Mechanical function The device meets the requirements, provided the information in the instruction		Is the panel builder's responsibility.
provide heat dissipation data for the devices. 10.11 Short-circuit rating Is the panel builder's responsibility. The specifications for the switchgear must be observed. 10.12 Electromagnetic compatibility Is the panel builder's responsibility. The specifications for the switchgear must be observed. 10.13 Mechanical function The device meets the requirements, provided the information in the instruction	10.9.4 Testing of enclosures made of insulating material	Is the panel builder's responsibility.
observed. 10.12 Electromagnetic compatibility Is the panel builder's responsibility. The specifications for the switchgear must be observed. 10.13 Mechanical function The device meets the requirements, provided the information in the instruction	10.10 Temperature rise	
observed. 10.13 Mechanical function The device meets the requirements, provided the information in the instruction	10.11 Short-circuit rating	
	10.12 Electromagnetic compatibility	
	10.13 Mechanical function	

Technical data ETIM 9.0

Low-voltage industrial components (EG000017) / Lamp holder block for control circuit devices (EC000204)

Electric engineering, automation, process control engineering / Low-voltage switch technology / Command and alarm device / Bulb socket block for command and alarm devices (ecl@ss13-27-37-12-09 [AKF027019])

(601@3313-27-37-12-03 [AIXI 027013])	
Transformer integrated	No
With integrated voltage decreasing resistor	No
With light source	Yes

With integrated diode		Yes
Lamp holder		None
Rated voltage Ue at AC 50 Hz	V	12 - 30
Rated voltage Ue at AC 60 Hz	V	12 - 30
Rated voltage Ue at DC	V	12 - 30
Voltage type for actuating		AC/DC
Lamp type		LED
Connection type auxiliary circuit		Spring clamp connection
Colour light source		Blue
Type of fastening		Floor fastening