

Part no. M22-WRS-A1 229092

General specifications	
Product name	Eaton Moeller® series M22 Key-operated actuator
Part no.	M22-WRS-A1
EAN	4015082290924
Product Length/Depth	70 millimetre
Product height	30 millimetre
Product width	30 millimetre
Product weight	0.031 kilogram
Compliances	CE Marked
Certifications	IEC 60947-5 EN 60947-5 UL 508 CSA Std. C22.2 No. 94-91 CSA Std. C22.2 No. 14-05 VDE CSA-C22.2 No. 14-05 CSA Class No.: 3211-03 CE IEC/EN 60947 UL Category Control No.: NKCR CSA UL IEC/EN 60947-5 VDE 0660 CSA File No.: 012528 CSA-C22.2 No. 94-91 UL File No.: E29184 DNV LR GL
Product Tradename	M22
Product Type	Key-operated actuator
Product Sub Type	None
Catalog Notes	Key withdraw convertible with coding adapters M22-XC Not suitable for master key systems
Features & Functions	
Bezel color	Titanium
Bezel material	Plastic
Design	Key operated Classical
Fitted with:	Front ring
Functions	Stay-put/spring-return function, can be changed with coding parts M22-XC-Y
General information	
Accessories	1 key included with supplied equipment.
Degree of protection	NEMA 4X, 13
Degree of protection (front side)	IP66
Lifespan, mechanical	100,000 Operations
Opening diameter	22.5 mm
Operating frequency	100 Operations/h
Operating torque	0.5 N·m
Product category	RMQ-Titan
Size	Front diameter: 29.7 mm
Switching angle	60 °
Type	Key-operated button
Ambient conditions, mechanical	no, operated sales.
Mounting position	As required
Shock resistance	Mechanical, According to IEC/EN 60068-2-27

Climatic environmental conditions  Ambient operating temperature - min  Ambient operating temperature - max  Climatic proofing  Communication  Connection to SmartWire-DT  Actuator  Actuator  Actuator function  Actuator function  Actuator fype Number of switch positions  Force for positive opening - min  Actuators  Ambient operating temperature - min  -25 °C  70 °C  Damp heat, cyclic, to IEC 60068-2-30  Damp heat, constant, to IEC 60068-2-78  Yes With SWD-RMQ connections  Yes With SWD-RMQ connections  Switching function latching Key withdrawable in position 0 Maintained  Key  Contacts  Force for positive opening - min  O N		30 g, Mechanical, According to IEC/EN 60068-2-27, Sinusoidal shock 11 ms
Ambient operating temperature - max Climatic procluing Communication Commonication Com	Climatic environmental conditions	
Communication Connection to SmartNive-DT Actuator Actuator Actuator incline Actuator inclin	Ambient operating temperature - min	-25 °C
Damp heat, crestant, pa IIC 00005-2-78   Communication   Ves		70 °C
Communication Connection to SmartWire-DT Vas With SWD-RMD connections  Actuator Of Black Actuator function Actuator function Actuator function Actuator function Actuator function Actuator function Actuator type A	Climatic proofing	Damp heat, cyclic, to IEC 60068-2-30
Contactor Actuator color Actuator (color Actuator function Actuator (color Actuator function Actuator		Damp heat, constant, to IEC 60068-2-78
Actuator color Actuator function Actuator Actuator function Actuator Actuat	Communication	
Actuator color Actuator function  Actuator type  Actuator type  Nambur of swritch positions  Contacts  Force for positive opening - min  Dosign verification  Equipment heat dissipation, current-dependent Pvid  Heat dissipation capacity Pdiss  OW  Heat dissipation per pole, current-dependent Pvid  Heat dissipation per pole, current-dependent Pvid  Heat dissipation per pole, current-dependent Pvid  Match dissipation capacity Pdiss  OW  Rated operational current dependent Pvid  Astic head dissipation, non-current-dependent Pvid  OW  Rated operational current dependent Pvid  Rated product standard's requirements.  Meets the product standard's requirements.  10.2.3 Verification of thermal stability of enclosures  Meets the product standard's requirements.  10.2.3 Verification of resistance of insulating materials to normal heat  10.2.3 Verification of resistance of insulating materials to normal heat  10.2.3 Position of resistance of insulating materials to normal heat  10.2.3 Position of resistance of insulating materials to normal heat  10.2.3 Position of resistance of insulating materials to normal heat  10.2.3 Position of resistance of insulating materials to normal heat  10.2.3 Position of resistance of insulating materials to normal heat  10.2.4 Serial product standard's requirements.  10.2.5 Lifting  Does not apply, since the entire switchgear needs to be evaluated.  10.2.6 Mechanical impact  10.2.6 Mechanical impact  Does not apply, since the entire switchgear needs to be evaluated.  10.4 Clearances and crepage distances  Meets the product standard's requirements.  10.5 Protocion of assemblies  Does not apply, since the entire switchgear needs to be evaluated.  10.6 Clearances and crepage distances  Meets the product standard's requirements.  10.7 Internal electric al circuits and connections  Internal electric al circuits	Connection to SmartWire-DT	
Actuator type Actuator type Nomber of switch positions 2  Contacts Force for positive opening - min Design verification Equipment heat dissipation, current -dependent Pvid Heat dissipation expectly Pdiss OW Heat dissipation current to specified heat dissipation (II) Statish heat dissipation, current-dependent Pvid OW Heat dissipation on expectly Pdiss OW Heat dissipation expectly Pdiss OW Heat the product standard's requirements. Wheat the product standard's requirements. Heat the product standard's requirements. Does not apply, since the entire switchgear needs to be evaluated. Heat the product standard's requirements. Does not apply, since the entire switchgear needs to be evaluated. Heat the product standard's requirements. Heat the product standard's requirements. Does not apply, since the entire switchgear needs to be evaluated. Heat the product standard's requirements. Heat the panel builder's responsibility. Let papen builder's responsibility. Let papen builder's responsibility. Let the panel builder's responsibility. Let	Actuator	
Actuator type  Actuator type  Key Number of switch positions  Contacts  Force for positive opening - min  Design verification  Equipment heat dissipation, current-dependent Pvid  Heat dissipation capacity Pdiss  Read operational current for specified heat dissipation (in)  Rated operational current for specified heat	Actuator color	Black
Number of switch positions   2	Actuator function	Key withdrawable in position 0
Contacts Force for positive opening - min  Design verification  Equipment heat dissipation, current-dependent Pvid  Heat dissipation per pole, current-dependent Pvid  Reted operational current for specified heat dissipation (In)  Rated operation of hermal stability of enclosures  Meets the product standard's requirements.  Meets the product standard's	Actuator type	Кеу
Porce for positive opening - min  Design verification  Equipment heat dissipation, current-dependent Pvid  Heat dissipation, capacity Pdiss  OW  Rated operational current for specified heat dissipation (In)  Static heat dissipation, non-current-dependent Pvis  10.2.2 Corrosion resistance  Meets the product standard's requirements.  10.2.3.1 Verification of thermal stability of enclosures  10.2.3.2 Verification of resistance of insulating materials to normal heat  10.2.3.3 Resist. of insul. mat. to abnormal heat/fire by internal elect. effects  10.2.4.4 Resistance to ultra-violet (UV) radiation  10.2.5 Lifting  Does not apply, since the entire switchgear needs to be evaluated.  10.2.7 Internal electrical circuits and connections  10.3.0 Egree of protection against electric shock  10.5 Fortection against electric shock  10.5 Georgonation of switching devices and components  10.7 Internal electrical circuits and connections  10.8 Georgonation of switching devices and components  10.9 Does not apply, since the entire switchgear needs to be evaluated.  10.7 Internal electrical circuits and connections  10.8 Georgonation of switching devices and components  10.9 Georgonation of switching devices and components  10.9 Does not apply, since the entire switchgear needs to be evaluated.  10.7 Internal electrical circuits and connections  10.8 Georgonation of switching devices and components  10.9 Georgonation of switching devices and components  10.9 Internal electrical circuits and connections  10.9 Internal electrical circuits and connections  10.9 Internal electrical circuits and connections  10.1 Internal electrical circuits and connections  10.2 Internal electrical circuits and connections  10.3 Insupulse withstand voltage  10.4 Testing of enclosures made of insulating material  10.5 Electromagnetic compatibility.  10.6 Ecopromagnetic compatibility.  10.7 Internal electrical circuit rating  10.8 Testing of enclosures made of insulating material  10.9 Testing of enclosures made of insulating material  10.1 Electromagn	Number of switch positions	2
Design verification  Equipment heat dissipation, current-dependent Pvid  Heat dissipation capacity Pdiss  OW  Rated operational current for specified heat dissipation (In)  State heat dissipation, per pole, current-dependent Pvid  Rated operational current for specified heat dissipation (In)  OA  State heat dissipation, non-current-dependent Pvs  OW  10.22 Corrosion resistance  10.23.1 Verification of thermal stability of enclosures  Meets the product standard's requirements.  Meets the product standard's requirements.  10.23.2 Verification of resistance of insulating materials to normal heat  10.24. Resistance to ultra-violet (UV) radiation  10.25 Lifting  Does not apply, since the entire switchgear needs to be evaluated.  10.25 Inscriptions  Meets the product standard's requirements.  10.3 Degree of protection of assemblies  10.4 Clearances and creepage distances  Meets the product standard's requirements.  10.5 Protection against electric shock  Does not apply, since the entire switchgear needs to be evaluated.  Meets the product standard's requirements.  10.5 Protection against electric shock  Does not apply, since the entire switchgear needs to be evaluated.  10.6 Incorporation of switching devices and components  Does not apply, since the entire switchgear needs to be evaluated.  10.7 Internal electrical circuits and connections  10.8 Connections for external conductors  Some of apply, since the entire switchgear needs to be evaluated.  10.9.2 Power-frequency electric strength  10.9.2 Power-frequency electric strength  10.9.3 Impulse withstand voltage  10.9.4 Testing of enclosures made of insulating material  10.10 Temporature rise  10.11 Short-circuit rating  Lis the panel builder's responsibility.  10.12 Electromagnetic compatibility  10.13 Mechanical function  The device meets the requirements, provided the information in the instruction  10.13 Mechanical function	Contacts	
Equipment heat dissipation, current-dependent Pvid Heat dissipation capacity Pdiss  Heat dissipation per pole, current-dependent Pvid  Rated operational current for specified heat dissipation (In)  Static heat dissipation, non-current-dependent Pvs  OW  10.2 Corrosion resistance  Meets the product standard's requirements.  10.2.3.1 Verification of thermal stability of enclosures  Meets the product standard's requirements.  10.2.3.2 Verification of resistance of insulating materials to normal heat  10.2.3.3 Resist, of insul. mat. to abnormal heat/fire by internal elect. effects  Meets the product standard's requirements.  10.2.4 Resistance to ultra-violet (UV) radiation  Please enquire  10.2.5 Litting  Does not apply, since the entire switchgear needs to be evaluated.  10.2.7 Inscriptions  Meets the product standard's requirements.  10.3 Degree of protection of assemblies  Does not apply, since the entire switchgear needs to be evaluated.  10.4 Clearances and creepage distances  Meets the product standard's requirements.  10.5 Frotection against electric shock  Does not apply, since the entire switchgear needs to be evaluated.  10.6 Incorporation of switching devices and components  10.7 Internal electrical circuits and connections  10.8 Connections for external conductors  10.9 Expendentions for external conductors  10.9 Power-frequency electric strength  10.9 Power-frequency electric strength  10.9 Power-frequency electric strength  10.9 Temperature rise  Not applicable.  10.11 Short-circuit rating  Not applicable.  10.12 Electromagnetic compatibility  10.13 Mechanical function  The device meets the requirements, provided the information in the instruction	Force for positive opening - min	0 N
Heat dissipation capacity Pdiss  Heat dissipation per pole, current-dependent Pvid  Rated operational current for specified hear dissipation (In)  Static heat dissipation, non-current-dependent Pvs  OW  10.22 Corrosion resistance  Meets the product standard's requirements.  10.23.1 Verification of thermal stability of enclosures  Meets the product standard's requirements.  10.23.2 Verification of resistance of insulating materials to normal heat  10.23.3 Resist. of insul. mat. to abnormal heat/fire by internal elect. effects  Meets the product standard's requirements.  10.24. Resistance to ultra-violet (UV) radiation  Please enquire  10.25. Lifting  Does not apply, since the entire switchgear needs to be evaluated.  10.26 Mechanical impact  Does not apply, since the entire switchgear needs to be evaluated.  10.27 Inscriptions  Meets the product standard's requirements.  10.3 Degree of protection of assemblies  Does not apply, since the entire switchgear needs to be evaluated.  10.4 Clearances and creepage distances  Meets the product standard's requirements.  10.5 Protection against electric shock  Does not apply, since the entire switchgear needs to be evaluated.  10.6 Incorporation of switching devices and components  Does not apply, since the entire switchgear needs to be evaluated.  10.7 Internal electrical circuits and connections  Is the panel builder's responsibility.  10.8 Connections for external conductors  Is the panel builder's responsibility.  10.9.4 Testing of enclosures made of insulating material  10.10 Temperature rise  Not applicable.  10.11 Electromagnetic compatibility  Is the panel builder's responsibility. The specifications for the switchgear must be observed.  10.13 Mechanical function  The device meets the requirements, provided the information in the instruction	Design verification	
Heat dissipation per pole, current-dependent Pvid Rated operational current for specified heat dissipation (In)  Static heat dissipation, non-current-dependent Pvs  10.22 Corrosion resistance  10.23.1 Verification of thermal stability of enclosures  10.23.2 Verification of thermal stability of enclosures  10.23.2 Verification of resistance of insulating materials to normal heat  10.23.3 Resist. of insul. mat. to abnormal heat/fire by internal elect. effects  10.24.3 Resistance to ultra-violet (UV) radiation  10.25 Lifting  10.25 Lifting  10.25 Lifting  10.26 Mechanical impact  10.27 Inscriptions  10.3 Degree of protection of assemblies  10.4 Clearances and creepage distances  10.5 Protection against electric shock  10.6 Incorporation of switching devices and components  10.7 Internal electrical circuits and connections  10.8 Connections for external conductors  10.9 Power-frequency electric strength  10.9 Power-frequency electric strength  10.9 Power-frequency electric strength  10.10 Temperature rise  10.11 Short-circuit rating  10.12 Electromagnetic compatibility  10.15 Interparature rise  10.13 Mechanical function  10.16 Repare to the entire switchgear needs to be evaluated by explaining the specifications for the switchgear must be observed.  10.10 Temperature rise  10.11 Short-circuit rating  10.12 Electromagnetic compatibility  10.15 Internal electric actions  10.16 Internal electric strength  10.17 Internal electric strength  10.18 Internal electric strength  10.19 Interparature rise  10.10 Temperature rise  10.11 Short-circuit rating  10.12 Electromagnetic compatibility  10.15 Internal electric strength  10.16 Temperature rise  10.17 Internal electric strength  10.18 Temperature rise  10.19 Temperature rise  10.19 Temperature rise  10.10 Temperature rise  10.10 Temperature rise  10.11 Short-circuit rating  10.12 Electromagnetic compatibility  10.13 Mechanical function  10.14 Mechanical function	Equipment heat dissipation, current-dependent Pvid	0 W
Rated operational current for specified heat dissipation (In)  Static heat dissipation, non-current-dependent Pvs  0 W  10.2.2 Corrosion resistance  Meets the product standard's requirements.  10.2.3.1 Verification of thermal stability of enclosures  Meets the product standard's requirements.  10.2.3.2 Verification of resistance of insulating materials to normal heat  10.2.3.3 Resist of insul. mat. to abnormal heat/fire by internal elect. effects  10.2.3 Resist or insul. mat. to abnormal heat/fire by internal elect. effects  10.2.5 Lifting  10.2.5 Lifting  10.2.6 Mechanical impact  10.2.7 Inscriptions  10.3 Degree of protection of assemblies  10.3 Degree of protection of assemblies  10.4 Clearances and creepage distances  10.5 Protection against electric shock  10.6 Incorporation of switching devices and components  10.7 Internal electrical circuits and connections  10.8 Connections for external conductors  10.9 Power-frequency electric strength  10.9 Power-frequency electric strength  10.9.4 Testing of enclosures made of insulating material  10.10 Temperature rise  10.11 Short-circuit rating  10.12 Electromagnetic compatibility  10.13 Mechanical function  10.15 Lectromagnetic compatibility  10.10 Reparature rise  10.11 Short-circuit rating  10.13 Mechanical function  The device meets the requirements,  OW  10.13 Mechanical function  10.14 Meets the product standard's requirements.  0.4  0.5  0.5  0.6  0.7  0.8  0.8  0.9  0.9  0.9  0.9  0.9  0.9	Heat dissipation capacity Pdiss	0 W
Static heat dissipation, non-current-dependent Pvs  10.2.2 Corrosion resistance  10.2.3.1 Verification of thermal stability of enclosures  10.2.3.2 Verification of resistance of insulating materials to normal heat  10.2.3.3 Resists of insul. mat. to abnormal heat/fire by internal elect. effects  10.2.4 Resistance to ultra-violet (UV) radiation  10.2.5 Lifting  10.2.5 Lifting  10.2.6 Mechanical impact  10.2.7 Inscriptions  10.3.1 Perotection against electric shock  10.4 Clearances and creepage distances  10.5 Protection against electric shock  10.5 Protection against electric shock  10.5 Incorporation of switching devices and components  10.5 Roonections for external conductors  10.8 Connections for external conductors  10.9 Power-frequency electric strength  10.9 Testing of enclosures made of insulating material  10.10 Temperature rise  10.11 Short-circuit rating  10.12 Electromagnetic compatibility  10.13 Mechanical function  10.13 Mechanical function  10.13 Mechanical function  10.13 Mechanical function  10.14 Clearances and creepage distances  10.15 Protection against electric shock  10.16 Incorporation of switching devices and components  10.17 Internal electrical circuits and connections  10.18 Lift panel builder's responsibility.  10.19 Temperature rise  10.10 Temperature rise  10.11 Short-circuit rating  10.12 Electromagnetic compatibility  10.13 Mechanical function  10.13 Mechanical function  10.13 Mechanical function  10.13 Mechanical function  10.14 Meets the product standard's requirements.  Meets the product standard's requi	Heat dissipation per pole, current-dependent Pvid	0 W
10.2.2 Corrosion resistance  10.2.3.1 Verification of thermal stability of enclosures  10.2.3.2 Verification of thermal stability of enclosures  10.2.3.2 Resistance of insulating materials to normal heat  10.2.3.3 Resist. of insul. mat. to abnormal heat/fire by internal elect. effects  10.2.4 Resistance to ultra-violet (UV) radiation  10.2.5 Lifting  10.2.6 Mechanical impact  10.2.6 Inscriptions  10.3 Degree of protection of assemblies  10.4 Clearances and creepage distances  10.4 Protection against electric shock  10.5 Protection against electric shock  10.6 Incorporation of switching devices and components  10.7 Internal electrical circuits and connections  10.8 Connections for external conductors  10.9.2 Power-frequency electric strength  10.9.3 Inpulse withstand voltage  10.1 Short-circuit rating  10.10 Temperature rise  10.11 Short-circuit rating  10.12 Electromagnetic compatibility  10.13 Mechanical function  Meets the product standard's requirements.  Meets the product standard's requirements to be evaluated.  Does not apply, since the entire switchgear needs to be evaluated.  Does not apply, since the entire switchgear needs to be evaluated.  Does not apply, since the entire switchgear needs to be evaluated.  Does not apply, since the entire switchgear needs to be evaluated.  In the panel builder's responsibility.  Is the panel builder's responsibility.  In the panel builder's responsibility.  In the panel builder's responsibility. The specifications for the switchgear must be observed.  In the panel builder's responsibility. The specifications for the switchgear must be observed.  In the device meets the requirements, provided the information in the instruction	Rated operational current for specified heat dissipation (In)	0 A
10.2.3.1 Verification of thermal stability of enclosures  10.2.3.2 Verification of resistance of insulating materials to normal heat  10.2.3.2 Resist. of insul. mat. to abnormal heat/fire by internal elect. effects  10.2.4 Resistance to ultra-violet (UV) radiation  10.2.5 Lifting  10.2.5 Lifting  10.2.6 Mechanical impact  10.2.7 Inscriptions  10.3.1 Degree of protection of assemblies  10.4 Clearances and creepage distances  10.4 Clearances and creepage distances  10.5 Protection against electric shock  10.6 Incorporation of switching devices and components  10.7 Internal electrical circuits and connections  10.8 Connections for external conductors  10.9.2 Power-frequency electric strength  10.9.3 Impulse withstand voltage  10.9.4 Testing of enclosures made of insulating material  10.9.1 Testing of enclosures made of insulating material  10.9.1 Electromagnetic compatibility  10.9.2 Responsibility  10.9.3 Impulse virtnangenic compatibility  10.9.4 Testing of enclosures made of insulating material  10.10 Impure the panel builder's responsibility.  10.10 Temperature rise  10.11 Short-circuit rating  10.12 Electromagnetic compatibility  10.13 Mechanical function  10.13 Mechanical function  10.13 Mechanical function  10.14 Revice meets the requirements, provided the information in the instruction	Static heat dissipation, non-current-dependent Pvs	0 W
10.2.32 Verification of resistance of insulating materials to normal heat 10.2.33 Resist. of insul. mat. to abnormal heat/fire by internal elect. effects 10.2.4 Resistance to ultra-violet (UV) radiation 10.2.5 Lifting 10.2.5 Lifting 10.2.5 Mechanical impact 10.2.6 Mechanical impact 10.2.7 Inscriptions 10.3 Degree of protection of assemblies 10.3 Degree of protection of assemblies 10.4 Clearances and creepage distances 10.5 Protection against electric shock 10.6 Incorporation of switching devices and components 10.7 Internal electrical circuits and connections 10.8 Connections for external conductors 10.9.2 Power-frequency electric strength 10.9.3 Impulse withstand voltage 10.9.3 Impulse withstand voltage 10.9.4 Testing of enclosures made of insulating material 10.10 Temperature rise 10.11 Short-circuit rating 10.12 Electromagnetic compatibility 10.13 Mechanical function 10.14 Resistance of insulating material insulating material insulating material insulating material insulating material insulating material 10.10 Temperature rise 10.11 Short-circuit rating 10.12 Electromagnetic compatibility 10.13 Mechanical function 10.13 Mechanical function 10.14 Mechanical function 10.15 Mechanical function 10.16 Incorporation of switching devices and components 10.16 Incorporation of switching devices and components 10.17 Internal electric strength 10.18 the panel builder's responsibility. 10.19 Expensibility 10.19 The device meets the product standard's requirements. 10.19 Legical function 10.10 Temperature rise 10.11 Short-circuit rating 10.12 Electromagnetic compatibility 10.13 Mechanical function 10.14 Mechanical function 10.15 Mechanical function 10.16 Incorporation of switching devices and components 10.17 Incorporation of switching and components 10.18 Characteric strength 10.19 The device meets the product standard's requirements. 10.19 Desort apply, since the entire switchgear needs to be evaluated. 10.19 Desort	10.2.2 Corrosion resistance	Meets the product standard's requirements.
10.2.3.3 Resist. of insul. mat. to abnormal heat/fire by internal elect. effects  10.2.4 Resistance to ultra-violet (UV) radiation  10.2.5 Lifting  10.2.6 Mechanical impact  10.2.6 Mechanical impact  10.2.7 Inscriptions  10.3 Degree of protection of assemblies  10.3 Degree of protection of assemblies  10.4 Clearances and creepage distances  10.5 Protection against electric shock  10.6 Incorporation of switching devices and components  10.7 Internal electrical circuits and connections  10.8 Connections for external conductors  10.9.2 Power-frequency electric strength  10.9.3 Impulse withstand voltage  10.9.4 Testing of enclosures made of insulating material  10.10 Temperature rise  10.11 Short-circuit rating  10.12 Electromagnetic compatibility  10.13 Mechanical function  10.13 Mechanical function  The device meets the requirements.  Meets the product standard's requirements.  Does not apply, since the entire switchgear needs to be evaluated.  Does not apply, since the entire switchgear needs to be evaluated.  Does not apply, since the entire switchgear needs to be evaluated.  Does not apply, since the entire switchgear needs to be evaluated.  Is the panel builder's responsibility.  Is the panel builder's responsibility. The specifications for the switchgear must be observed.  Is the panel builder's responsibility. The specifications for the switchgear must be observed.	10.2.3.1 Verification of thermal stability of enclosures	Meets the product standard's requirements.
10.2.4 Resistance to ultra-violet (UV) radiation  10.2.5 Lifting  10.2.6 Mechanical impact  10.2.6 Mechanical impact  10.2.7 Inscriptions  10.3 Degree of protection of assemblies  10.3 Degree of protection of assemblies  10.4 Clearances and creepage distances  10.5 Protection against electric shock  10.6 Incorporation of switching devices and components  10.7 Internal electrical circuits and connections  10.8 Connections for external conductors  10.9 Power-frequency electric strength  10.9.3 Impulse withstand voltage  10.9.4 Testing of enclosures made of insulating material  10.10 Temperature rise  10.11 Short-circuit rating  10.12 Electromagnetic compatibility  10.13 Mechanical function  10.14 Response builder's responsibility. The specifications for the switchgear must be observed.  10.10 Temperature frequency electric strength  10.11 Short-circuit rating  10.12 Electromagnetic compatibility  10.13 Mechanical function  10.14 Response to the entire switchgear needs to be evaluated.  10.15 the panel builder's responsibility.  10.16 Incorporation of switching devices and components  10.17 Internal electrical circuits and connections  10.18 the panel builder's responsibility.  10.19 Temperature rise  10.10 Temperature rise  10.11 Short-circuit rating  10.12 Electromagnetic compatibility  10.13 Mechanical function  10.14 Response to the entire switchgear needs to be evaluated.  10.15 He panel builder's responsibility. The specifications for the switchgear must be observed.  10.19 Temperature rise response made of insulations for the switchgear must be observed.	10.2.3.2 Verification of resistance of insulating materials to normal heat	Meets the product standard's requirements.
10.2.5 Lifting  Does not apply, since the entire switchgear needs to be evaluated.  10.2.6 Mechanical impact  Does not apply, since the entire switchgear needs to be evaluated.  10.2.7 Inscriptions  Meets the product standard's requirements.  Does not apply, since the entire switchgear needs to be evaluated.  10.4 Clearances and creepage distances  Meets the product standard's requirements.  10.5 Protection against electric shock  Does not apply, since the entire switchgear needs to be evaluated.  10.6 Incorporation of switching devices and components  Does not apply, since the entire switchgear needs to be evaluated.  10.7 Internal electrical circuits and connections  Is the panel builder's responsibility.  10.8 Connections for external conductors  Is the panel builder's responsibility.  10.9.2 Power-frequency electric strength  Is the panel builder's responsibility.  10.9.3 Impulse withstand voltage  Is the panel builder's responsibility.  10.9.4 Testing of enclosures made of insulating material  10.10 Temperature rise  Not applicable.  10.11 Short-circuit rating  Is the panel builder's responsibility. The specifications for the switchgear must be observed.  10.12 Electromagnetic compatibility  The device meets the requirements, provided the information in the instruction	10.2.3.3 Resist. of insul. mat. to abnormal heat/fire by internal elect. effects	Meets the product standard's requirements.
10.2.6 Mechanical impact  10.2.7 Inscriptions  Meets the product standard's requirements.  10.3 Degree of protection of assemblies  10.4 Clearances and creepage distances  10.5 Protection against electric shock  10.6 Incorporation of switching devices and components  10.7 Internal electrical circuits and connections  10.8 Connections for external conductors  10.9.2 Power-frequency electric strength  10.9.3 Impulse withstand voltage  10.9.4 Testing of enclosures made of insulating material  10.10 Temperature rise  10.11 Short-circuit rating  10.12 Electromagnetic compatibility  10.13 Mechanical function  Does not apply, since the entire switchgear needs to be evaluated.  Does not apply, since the entire switchgear needs to be evaluated.  Does not apply, since the entire switchgear needs to be evaluated.  Does not apply, since the entire switchgear needs to be evaluated.  Is the panel builder's responsibility.  Is the panel builder's responsibility.  Is the panel builder's responsibility.  In the panel builder's responsibility.  10.11 Short-circuit rating  Is the panel builder's responsibility. The specifications for the switchgear must be observed.  10.12 Electromagnetic compatibility  The device meets the requirements, provided the information in the instruction	10.2.4 Resistance to ultra-violet (UV) radiation	Please enquire
10.27 Inscriptions  Meets the product standard's requirements.  10.3 Degree of protection of assemblies  Does not apply, since the entire switchgear needs to be evaluated.  Meets the product standard's requirements.  Meets the product standard's requirements.  Does not apply, since the entire switchgear needs to be evaluated.  Does not apply, since the entire switchgear needs to be evaluated.  Does not apply, since the entire switchgear needs to be evaluated.  Does not apply, since the entire switchgear needs to be evaluated.  In the panel builder's responsibility.  Does not apply, since the entire switchgear needs to be evaluated.  In the panel builder's responsibility.  Does not apply, since the entire switchgear needs to be evaluated.  In the panel builder's responsibility.  Does not apply, since the entire switchgear needs to be evaluated.  In the panel builder's responsibility.  Does not apply, since the entire switchgear needs to be evaluated.  In the panel builder's responsibility.  Does not apply, since the entire switchgear needs to be evaluated.  In the panel builder's responsibility.  Does not apply, since the entire switchgear needs to be evaluated.  In the panel builder's responsibility.  Does not apply, since the entire switchgear needs to be evaluated.  In the panel builder's responsibility.  In the device meets the requirements, provided the information in the instruction	10.2.5 Lifting	Does not apply, since the entire switchgear needs to be evaluated.
Does not apply, since the entire switchgear needs to be evaluated.  10.4 Clearances and creepage distances  Meets the product standard's requirements.  10.5 Protection against electric shock  Does not apply, since the entire switchgear needs to be evaluated.  10.6 Incorporation of switching devices and components  Does not apply, since the entire switchgear needs to be evaluated.  10.7 Internal electrical circuits and connections  Is the panel builder's responsibility.  10.8 Connections for external conductors  Is the panel builder's responsibility.  10.9.2 Power-frequency electric strength  Is the panel builder's responsibility.  10.9.3 Impulse withstand voltage  Is the panel builder's responsibility.  10.9.4 Testing of enclosures made of insulating material  10.10 Temperature rise  Not applicable.  10.11 Short-circuit rating  Is the panel builder's responsibility. The specifications for the switchgear must be observed.  10.12 Electromagnetic compatibility  The device meets the requirements, provided the information in the instruction	10.2.6 Mechanical impact	Does not apply, since the entire switchgear needs to be evaluated.
10.4 Clearances and creepage distances  10.5 Protection against electric shock  10.6 Incorporation of switching devices and components  10.7 Internal electrical circuits and connections  10.8 Connections for external conductors  10.9.2 Power-frequency electric strength  10.9.3 Impulse withstand voltage  10.9.4 Testing of enclosures made of insulating material  10.10 Temperature rise  10.11 Short-circuit rating  10.12 Electromagnetic compatibility  10.13 Mechanical function  Meets the product standard's requirements.  Does not apply, since the entire switchgear needs to be evaluated.  Is the panel builder's responsibility.  The specifications for the switchgear must be observed.  Is the panel builder's responsibility. The specifications for the switchgear must be observed.  The device meets the requirements, provided the information in the instruction	10.2.7 Inscriptions	Meets the product standard's requirements.
Does not apply, since the entire switchgear needs to be evaluated.  10.6 Incorporation of switching devices and components  Does not apply, since the entire switchgear needs to be evaluated.  10.7 Internal electrical circuits and connections  Is the panel builder's responsibility.  10.8 Connections for external conductors  Is the panel builder's responsibility.  10.9.2 Power-frequency electric strength  Is the panel builder's responsibility.  10.9.3 Impulse withstand voltage  Is the panel builder's responsibility.  10.9.4 Testing of enclosures made of insulating material  10.10 Temperature rise  Not applicable.  10.11 Short-circuit rating  Is the panel builder's responsibility. The specifications for the switchgear must be observed.  10.12 Electromagnetic compatibility  Is the panel builder's responsibility. The specifications for the switchgear must be observed.  10.13 Mechanical function  The device meets the requirements, provided the information in the instruction	10.3 Degree of protection of assemblies	Does not apply, since the entire switchgear needs to be evaluated.
10.6 Incorporation of switching devices and components  10.7 Internal electrical circuits and connections  1s the panel builder's responsibility.  10.8 Connections for external conductors  1s the panel builder's responsibility.  10.9.2 Power-frequency electric strength  1s the panel builder's responsibility.  1o.9.3 Impulse withstand voltage  1s the panel builder's responsibility.  1o.9.4 Testing of enclosures made of insulating material  1s the panel builder's responsibility.  1o.10 Temperature rise  Not applicable.  1o.11 Short-circuit rating  1s the panel builder's responsibility. The specifications for the switchgear must be observed.  1o.12 Electromagnetic compatibility  Is the panel builder's responsibility. The specifications for the switchgear must be observed.  1o.13 Mechanical function  The device meets the requirements, provided the information in the instruction	10.4 Clearances and creepage distances	Meets the product standard's requirements.
10.7 Internal electrical circuits and connections  10.8 Connections for external conductors  10.9.2 Power-frequency electric strength  10.9.3 Impulse withstand voltage  10.9.4 Testing of enclosures made of insulating material  10.10 Temperature rise  10.11 Short-circuit rating  10.12 Electromagnetic compatibility  10.13 Mechanical function  Is the panel builder's responsibility.  Is the panel builder's responsibility.  Not applicable.  Is the panel builder's responsibility. The specifications for the switchgear must be observed.  10.12 Electromagnetic compatibility  The device meets the requirements, provided the information in the instruction	10.5 Protection against electric shock	Does not apply, since the entire switchgear needs to be evaluated.
10.8 Connections for external conductors  10.9.2 Power-frequency electric strength  10.9.3 Impulse withstand voltage  10.9.4 Testing of enclosures made of insulating material  10.10 Temperature rise  10.11 Short-circuit rating  10.12 Electromagnetic compatibility  10.13 Mechanical function  Is the panel builder's responsibility.  Is the panel builder's responsibility.  Not applicable.  Is the panel builder's responsibility. The specifications for the switchgear must be observed.  10.12 Electromagnetic compatibility  The device meets the requirements, provided the information in the instruction	10.6 Incorporation of switching devices and components	Does not apply, since the entire switchgear needs to be evaluated.
10.9.2 Power-frequency electric strength  10.9.3 Impulse withstand voltage  10.9.4 Testing of enclosures made of insulating material  10.9.4 Testing of enclosures made of insulating material  10.10 Temperature rise  Not applicable.  10.11 Short-circuit rating  10.12 Electromagnetic compatibility  Is the panel builder's responsibility. The specifications for the switchgear must be observed.  10.13 Mechanical function  The device meets the requirements, provided the information in the instruction	10.7 Internal electrical circuits and connections	Is the panel builder's responsibility.
10.9.3 Impulse withstand voltage  10.9.4 Testing of enclosures made of insulating material  10.10 Temperature rise  10.11 Short-circuit rating  10.12 Electromagnetic compatibility  10.13 Mechanical function  Is the panel builder's responsibility. The specifications for the switchgear must be observed.  10.13 Mechanical function  The device meets the requirements, provided the information in the instruction		
10.9.4 Testing of enclosures made of insulating material  10.10 Temperature rise  Not applicable.  10.11 Short-circuit rating  Is the panel builder's responsibility. The specifications for the switchgear must be observed.  10.12 Electromagnetic compatibility  Is the panel builder's responsibility. The specifications for the switchgear must be observed.  10.13 Mechanical function  The device meets the requirements, provided the information in the instruction	10.9.2 Power-frequency electric strength	Is the panel builder's responsibility.
10.10 Temperature rise  10.11 Short-circuit rating  1s the panel builder's responsibility. The specifications for the switchgear must be observed.  10.12 Electromagnetic compatibility  1s the panel builder's responsibility. The specifications for the switchgear must be observed.  10.13 Mechanical function  The device meets the requirements, provided the information in the instruction	10.9.3 Impulse withstand voltage	Is the panel builder's responsibility.
10.11 Short-circuit rating  Is the panel builder's responsibility. The specifications for the switchgear must be observed.  10.12 Electromagnetic compatibility  Is the panel builder's responsibility. The specifications for the switchgear must be observed.  10.13 Mechanical function  The device meets the requirements, provided the information in the instruction	10.9.4 Testing of enclosures made of insulating material	Is the panel builder's responsibility.
observed.  10.12 Electromagnetic compatibility  Is the panel builder's responsibility. The specifications for the switchgear must be observed.  10.13 Mechanical function  The device meets the requirements, provided the information in the instruction	10.10 Temperature rise	Not applicable.
observed.  10.13 Mechanical function  The device meets the requirements, provided the information in the instruction	10.11 Short-circuit rating	
	10.12 Electromagnetic compatibility	
	10.13 Mechanical function	

## **Technical data ETIM 9.0**

Low-voltage industrial components (EG000017) / Front element for selector switch (EC000222)

Electric engineering, automation, process control engineering / Low-voltage switch technology / Command and alarm device / Front element for selector switches (ecl@ss13-27-37-12-13 [AKF031019])

[AKF031019])	
Number of switch positions	2
Type of control element	Key
Suitable for illumination	No
Colour control element	Black
Colour indicator light cap	Other

Construction type lens		Round
,,		
Hole diameter	mm	22.5
Width opening	mm	0
Height opening	mm	0
Switching function latching		Yes
Spring-return		No
With front ring		Yes
Material front ring		Plastic
Colour front ring		Titanium
Degree of protection (IP), front side		IP66
Degree of protection (NEMA)		4X, 13