## **DATASHEET - PLS6-C4/3-MW**



Miniature circuit breaker (MCB), 4 A, 3p, characteristic: C

Part no. PLS6-C4/3-MW Catalog No. 242941



Similar to illustration

| Delivery program                                     |                 |    |  |  |  |
|--|-----------------|----|--|--|--|
| Basic function                                       |                 |    | Miniature circuit-breakers                             |  |  |
| Number of poles                                      |                 |    | 3 pole   |  |  |
| Tripping characteristic                              |                 |    | С  |  |  |
| Application  |                 |    | Switchgear for residential and commercial applications |  |  |
| Rated current  | In              | Α  | 4  |  |  |
| Rated switching capacity according to IEC/EN 60898-1 | I <sub>cn</sub> | kA | 6  |  |  |
| Product range  |                 |    | PLS6   |  |  |

## **Technical data**

**Electrical** 

|--|

## Design verification as per IEC/EN 61439

| lesign verification as per IEC/EN 61439   |                   |    |  |
|---|-------------------|----|--|
| echnical data for design verification   |                   |    |  |
| Rated operational current for specified heat dissipation  | In                | Α  | 4  |
| Heat dissipation per pole, current-dependent  | P <sub>vid</sub>  | W  | 0  |
| Equipment heat dissipation, current-dependent   | P <sub>vid</sub>  | W  | 4.4  |
| Static heat dissipation, non-current-dependent  | P <sub>vs</sub>   | W  | 0  |
| Heat dissipation capacity   | P <sub>diss</sub> | W  | 0  |
| Operating ambient temperature min.  |                   | °C | -25  |
| Operating ambient temperature max.  |                   | °C | 75   |
|   |                   |    | linear, per +1 °C, results in a 0.5% reduction of current carrying capacity  |
| C/EN 61439 design verification  |                   |    |  |
| 10.2 Strength of materials and parts  |                   |    |  |
| 10.2.2 Corrosion resistance   |                   |    | Meets the product standard's requirements.   |
| 10.2.3.1 Verification of thermal stability of enclosures  |                   |    | Meets the product standard's requirements.   |
| 10.2.3.2 Verification of resistance of insulating materials to normal heat  |                   |    | Meets the product standard's requirements.   |
| 10.2.3.3 Verification of resistance of insulating materials to abnormal heat and fire due to internal electric effects $$ |                   |    | Meets the product standard's requirements.   |
| 10.2.4 Resistance to ultra-violet (UV) radiation  |                   |    | Meets the product standard's requirements.   |
| 10.2.5 Lifting  |                   |    | Does not apply, since the entire switchgear needs to be evaluated.   |
| 10.2.6 Mechanical impact  |                   |    | Does not apply, since the entire switchgear needs to be evaluated.   |
| 10.2.7 Inscriptions   |                   |    | Meets the product standard's requirements.   |
| 10.3 Degree of protection of ASSEMBLIES   |                   |    | Does not apply, since the entire switchgear needs to be evaluated.   |
| 10.4 Clearances and creepage distances  |                   |    | Meets the product standard's requirements.   |
| 10.5 Protection against electric shock  |                   |    | Does not apply, since the entire switchgear needs to be evaluated.   |
| 10.6 Incorporation of switching devices and components  |                   |    | Does not apply, since the entire switchgear needs to be evaluated.   |
| 10.7 Internal electrical circuits and connections   |                   |    | Is the panel builder's responsibility.   |
| 10.8 Connections for external conductors  |                   |    | Is the panel builder's responsibility.   |
| 10.9 Insulation properties  |                   |    |  |
| 10.9.2 Power-frequency electric strength  |                   |    | Is the panel builder's responsibility.   |
| 10.9.3 Impulse withstand voltage  |                   |    | Is the panel builder's responsibility.   |
| 10.9.4 Testing of enclosures made of insulating material  |                   |    | Is the panel builder's responsibility.   |
| 10.10 Temperature rise  |                   |    | The panel builder is responsible for the temperature rise calculation. Eaton will provide heat dissipation data for the devices. |

| 10.11 Short-circuit rating          | Is the panel builder's responsibility. The specifications for the switchgear must be observed.           |
|-------------------------------------|--|
| 10.12 Electromagnetic compatibility | Is the panel builder's responsibility. The specifications for the switchgear must be observed.           |
| 10.13 Mechanical function           | The device meets the requirements, provided the information in the instruction leaflet (IL) is observed. |

## **Technical data ETIM 7.0**

| IECIIIICAI UALA LIIIVI 7.0  |    |     |          |  |  |  |
|---|----|-----|----------|--|--|--|
| Circuit breakers and fuses (EG000020) / Miniature circuit breaker (MCB) (EC00004  | 2) |     |          |  |  |  |
| Electric engineering, automation, process control engineering / Electrical installation, device / Miniature circuit breaker system (MCB) / Miniature circuit breaker (MCB) (ecl@ss10.0.1-27-14-19-01 [AAB905014]) |    |     |          |  |  |  |
| Release characteristic  |    |     | C        |  |  |  |
| Number of poles (total)   |    |     | 3        |  |  |  |
| Number of protected poles   |    |     | 3        |  |  |  |
| Rated current   |    | Α   | 4        |  |  |  |
| Rated voltage   |    | V   | 400      |  |  |  |
| Rated insulation voltage Ui   |    | V   | 440      |  |  |  |
| Rated impulse withstand voltage Uimp  |    | kV  | 4        |  |  |  |
| Rated short-circuit breaking capacity Icn EN 60898 at 230 V   |    | kA  | 6        |  |  |  |
| Rated short-circuit breaking capacity Icn EN 60898 at 400 V   |    | kA  | 6        |  |  |  |
| Rated short-circuit breaking capacity Icu IEC 60947-2 at 230 V  |    | kA  | 0        |  |  |  |
| Rated short-circuit breaking capacity Icu IEC 60947-2 at 400 V $$   |    | kA  | 0        |  |  |  |
| Voltage type  |    |     | AC       |  |  |  |
| Frequency   |    | Hz  | 50 - 60  |  |  |  |
| Current limiting class  |    |     | 3        |  |  |  |
| Suitable for flush-mounted installation   |    |     | No       |  |  |  |
| Concurrently switching N-neutral  |    |     | No       |  |  |  |
| Over voltage category   |    |     | 3        |  |  |  |
| Pollution degree  |    |     | 2        |  |  |  |
| Additional equipment possible   |    |     | Yes      |  |  |  |
| Width in number of modular spacings   |    |     | 3        |  |  |  |
| Built-in depth  |    | mm  | 70.5     |  |  |  |
| Degree of protection (IP)   |    |     | IP20     |  |  |  |
| Ambient temperature during operating  |    | °C  | -25 - 75 |  |  |  |
| Connectable conductor cross section multi-wired   |    | mm² | 1 - 25   |  |  |  |
| Connectable conductor cross section solid-core  |    | mm² | 1 - 25   |  |  |  |