# **DATASHEET - PLS6-D15/3N-MW**



### Miniature circuit breaker (MCB), 15A, 3pole+N, type D characteristic

Powering Business Worldwide\*

Part no. PLS6-D15/3N-MW Catalog No. 243040

Similar to illustration

| livery |  |  |
|--------|--|--|
|        |  |  |
|        |  |  |
|        |  |  |

| Basic function                                       |                 |    | Miniature circuit-breakers                             |
|--|-----------------|----|--|
| Number of poles                                      |                 |    | 3 pole+N   |
| Tripping characteristic                              |                 |    | D  |
| Application  |                 |    | Switchgear for residential and commercial applications |
| Rated current  | In              | Α  | 15   |
| Rated switching capacity according to IEC/EN 60898-1 | I <sub>cn</sub> | kA | 6  |
| Product range  |                 |    | PLS6   |

## **Technical data**

**Electrical** 

|--|

# Design verification as per IEC/EN 61439

| Jesigii verilication as per ieu/en 01439   |                   |    |  |
|--|-------------------|----|--|
| Fechnical data for design verification   |                   |    |  |
| Rated operational current for specified heat dissipation   | In                | Α  | 15   |
| Heat dissipation per pole, current-dependent   | P <sub>vid</sub>  | W  | 0  |
| Equipment heat dissipation, current-dependent  | P <sub>vid</sub>  | W  | 6.7  |
| Static heat dissipation, non-current-dependent   | P <sub>vs</sub>   | W  | 0  |
| Heat dissipation capacity  | P <sub>diss</sub> | W  | 0  |
| Operating ambient temperature min.   |                   | °C | -25  |
| Operating ambient temperature max.   |                   | °C | 75   |
|  |                   |    | linear, per +1 °C, results in a 0.5% reduction of current carrying capacity  |
| C/EN 61439 design verification   |                   |    |  |
| 10.2 Strength of materials and parts   |                   |    |  |
| 10.2.2 Corrosion resistance  |                   |    | Meets the product standard's requirements.   |
| 10.2.3.1 Verification of thermal stability of enclosures   |                   |    | Meets the product standard's requirements.   |
| 10.2.3.2 Verification of resistance of insulating materials to normal heat   |                   |    | Meets the product standard's requirements.   |
| 10.2.3.3 Verification of resistance of insulating materials to abnormal heat and fire due to internal electric effects |                   |    | Meets the product standard's requirements.   |
| 10.2.4 Resistance to ultra-violet (UV) radiation   |                   |    | Meets the product standard's requirements.   |
| 10.2.5 Lifting   |                   |    | Does not apply, since the entire switchgear needs to be evaluated.   |
| 10.2.6 Mechanical impact   |                   |    | Does not apply, since the entire switchgear needs to be evaluated.   |
| 10.2.7 Inscriptions  |                   |    | Meets the product standard's requirements.   |
| 10.3 Degree of protection of ASSEMBLIES  |                   |    | Does not apply, since the entire switchgear needs to be evaluated.   |
| 10.4 Clearances and creepage distances   |                   |    | Meets the product standard's requirements.   |
| 10.5 Protection against electric shock   |                   |    | Does not apply, since the entire switchgear needs to be evaluated.   |
| 10.6 Incorporation of switching devices and components   |                   |    | Does not apply, since the entire switchgear needs to be evaluated.   |
| 10.7 Internal electrical circuits and connections  |                   |    | Is the panel builder's responsibility.   |
| 10.8 Connections for external conductors   |                   |    | Is the panel builder's responsibility.   |
| 10.9 Insulation properties   |                   |    |  |
| 10.9.2 Power-frequency electric strength   |                   |    | Is the panel builder's responsibility.   |
| 10.9.3 Impulse withstand voltage   |                   |    | Is the panel builder's responsibility.   |
| 10.9.4 Testing of enclosures made of insulating material   |                   |    | Is the panel builder's responsibility.   |
| 10.10 Temperature rise   |                   |    | The panel builder is responsible for the temperature rise calculation. Eaton wi provide heat dissipation data for the devices. |

| 10.11 Short-circuit rating          | Is the panel builder's responsibility. The specifications for the switchgear must be observed.           |
|-------------------------------------|--|
| 10.12 Electromagnetic compatibility | Is the panel builder's responsibility. The specifications for the switchgear must be observed.           |
| 10.13 Mechanical function           | The device meets the requirements, provided the information in the instruction leaflet (IL) is observed. |

#### Technical data ETIM 7.0

| lechnical data ETIM 7.0   |                  |             |   |
|---|------------------|-------------|---|
| Circuit breakers and fuses (EG000020) / Miniature circuit breaker (MCB) (EC000042   | 2)               |             |   |
| Electric engineering, automation, process control engineering / Electrical installat (ecl@ss10.0.1-27-14-19-01 [AAB905014]) | ion, device / Mi | niature cir | cuit breaker system (MCB) / Miniature circuit breaker (MCB) |
| Release characteristic  |                  |             | D   |
| Number of poles (total)   |                  |             | 4   |
| Number of protected poles   |                  |             | 3   |
| Rated current   |                  | Α           | 15  |
| Rated voltage   |                  | V           | 400   |
| Rated insulation voltage Ui   |                  | V           | 440   |
| Rated impulse withstand voltage Uimp  |                  | kV          | 4   |
| Rated short-circuit breaking capacity Icn EN 60898 at 230 V   |                  | kA          | 6   |
| Rated short-circuit breaking capacity Icn EN 60898 at 400 V   |                  | kA          | 6   |
| Rated short-circuit breaking capacity Icu IEC 60947-2 at 230 V  |                  | kA          | 0   |
| Rated short-circuit breaking capacity Icu IEC 60947-2 at 400 V  |                  | kA          | 0   |
| Voltage type  |                  |             | AC  |
| Frequency   |                  | Hz          | 50 - 60   |
| Current limiting class  |                  |             | 3   |
| Suitable for flush-mounted installation   |                  |             | No  |
| Concurrently switching N-neutral  |                  |             | Yes   |
| Over voltage category   |                  |             | 3   |
| Pollution degree  |                  |             | 2   |
| Additional equipment possible   |                  |             | Yes   |
| Width in number of modular spacings   |                  |             | 4   |
| Built-in depth  |                  | mm          | 70.5  |
| Degree of protection (IP)   |                  |             | IP20  |
| Ambient temperature during operating  |                  | °C          | -25 - 55  |
| Connectable conductor cross section multi-wired   |                  | mm²         | 1 - 25  |
| Connectable conductor cross section solid-core  |                  | mm²         | 1 - 25  |
|   |                  |             |   |