DATASHEET - +NZM2-4-XKRO

Connection, on rear, top 4p

Part no.

+NZM2-4-XKRO 266766





| General specifications | |
|--|--|
| Product name | Eaton Moeller series NZM connection type |
| Part no. | +NZM2-4-XKR0 |
| EAN | 4015082667665 |
| Product Length/Depth | 140 millimetre |
| Product height | 35 millimetre |
| Product width | 60 millimetre |
| Product weight | 0.422 kilogram |
| Compliances | IEC RoHS conform |
| Product Tradename | NZM |
| Product Type | Accessories |
| Product Sub Type | Connection type |
| Delivery program | |
| Туре | Accessory Connection on rear Terminal |
| Number of poles | Four-pole |
| Amperage Rating | 300 A (Cu), 250 A (AI) |
| Frame | NZM2 |
| Suitable for | Aluminum cable lug Copper cable lugs Four-pole |
| Used with | NZM2-4, PN2-4, N2-4 |
| Technical Data - Mechanical | |
| Mounting position | Fitted above |
| Technical Data - Mechanical - Terminals | |
| Terminal capacity (stranded cable) | 4 mm ² - 70 mm ² (2x) 10 mm ² - 50 mm ² (2x) 10 mm ² - 185 mm ² (1x) 10 mm ² - 50 mm ² (1x) |
| Terminal capacity (copper busbar) | Max. 24 mm x 8 mm Min. 16 mm x 5 mm |
| Terminal capacity (copper strip) | 2 segments of 16 mm x 0.8 mm - 6 segments of 24 mm x 0.5 mm |
| Design verification as per IEC/EN 61439 | |
| 10.2.2 Corrosion resistance | Meets the product standard's requirements. |
| 10.2.3.1 Verification of thermal stability of enclosures | Meets the product standard's requirements. |
| 10.2.3.2 Verification of resistance of insulating materials to normal heat | Meets the product standard's requirements. |
| 10.2.3.3 Resist. of insul. mat. to abnormal heat/fire by internal elect. effects | Meets the product standard's requirements. |
| 10.2.4 Resistance to ultra-violet (UV) radiation | Meets the product standard's requirements. |
| 10.2.5 Lifting | Does not apply, since the entire switchgear needs to be evaluated. |
| 10.2.6 Mechanical impact | Does not apply, since the entire switchgear needs to be evaluated. |
| 10.2.7 Inscriptions | Meets the product standard's requirements. |
| 10.3 Degree of protection of assemblies | Does not apply, since the entire switchgear needs to be evaluated. |
| 10.4 Clearances and creepage distances | Meets the product standard's requirements. |
| 10.5 Protection against electric shock | Does not apply, since the entire switchgear needs to be evaluated. |
| 10.6 Incorporation of switching devices and components | Does not apply, since the entire switchgear needs to be evaluated. |
| 10.7 Internal electrical circuits and connections | Is the panel builder's responsibility. |
| 10.8 Connections for external conductors | Is the panel builder's responsibility. |
| 10.9.2 Power-frequency electric strength | Is the panel builder's responsibility. |
| 10.9.3 Impulse withstand voltage | Is the panel builder's responsibility. |
| 10.9.4 Testing of enclosures made of insulating material | Is the panel builder's responsibility. |

| 10.10 Temperature rise | The panel builder is responsible for the temperature rise calculation. Eaton will provide heat dissipation data for the devices. |
|---|--|
| 10.11 Short-circuit rating | Is the panel builder's responsibility. The specifications for the switchgear must be observed. |
| 10.12 Electromagnetic compatibility | Is the panel builder's responsibility. The specifications for the switchgear must be observed. |
| 10.13 Mechanical function | The device meets the requirements, provided the information in the instruction leaflet (IL) is observed. |
| Additional information | |
| Model | Other |
| Fechnical data ETIM 9.0 | |
| Low-voltage industrial components (EG000017) / Wiring set for power circuit breaker (EC0020 | 50) |

Electric engineering, automation, process control engineering / Low-voltage switch technology / Circuit breaker (LV < 1 kV) / Wiring set for circuit breaker (ecl@ss13-27-37-04-24 [ACN957016])

4

Other

Suitable for number of poles

Model