Tunnel terminal, 3p, 1 switch side, size 4

Part no. NZM4-XKA 266836

EL Number 4358962

(Norway)



General specifications	
Product name	Eaton Moeller series NZM connection type
Part no.	NZM4-XKA
EAN	4015082668365
Product Length/Depth	88 millimetre
Product height	90 millimetre
Product width	159 millimetre
Product weight	2.529 kilogram
Compliances	IEC IEC
Compilances	UL/CSA RoHS conform
Certifications	CSA (Class No. 1432-01) IEC60947 UL (File No. E31593) CSA (File No. 22086) UL489 CE marking CSA certified UL (Category Control Number DIHS) CSA-C22.2 No. 5-09 UL listed
Product Tradename	NZM
Product Type	Accessories
Product Sub Type	Connection type
Delivery program	
Туре	Accessory Tunnel terminal
Number of poles	Three-pole
Amperage Rating	≦ 1400 A
Frame	NZM4
Suitable for	Three-pole Copper cable Aluminum cable
Used with	NZM4, N(S)4
Technical Data - Mechanical - Terminals	
Terminal capacity (stranded cable)	50 mm² - 240 mm² (4x) Max. 500 AWG/kcmil (4x) Max. 500 AWG/kcmil (1x) 50 mm² - 240 mm² (1x)
Design verification as per IEC/EN 61439	
10.2.2 Corrosion resistance	Meets the product standard's requirements.
10.2.3.1 Verification of thermal stability of enclosures	Meets the product standard's requirements.
10.2.3.2 Verification of resistance of insulating materials to normal heat	Meets the product standard's requirements.
10.2.3.3 Resist. of insul. mat. to abnormal heat/fire by internal elect. effects	Meets the product standard's requirements.
10.2.4 Resistance to ultra-violet (UV) radiation	Meets the product standard's requirements.
10.2.5 Lifting	Does not apply, since the entire switchgear needs to be evaluated.
10.2.6 Mechanical impact	Does not apply, since the entire switchgear needs to be evaluated.
10.2.7 Inscriptions	Meets the product standard's requirements.
10.3 Degree of protection of assemblies	Does not apply, since the entire switchgear needs to be evaluated.
10.4 Clearances and creepage distances	Meets the product standard's requirements.
10.5 Protection against electric shock	Does not apply, since the entire switchgear needs to be evaluated.
10.6 Incorporation of switching devices and components	Does not apply, since the entire switchgear needs to be evaluated.
	Is the panel builder's responsibility.
10.7 Internal electrical circuits and connections	is the panel bulluer s responsibility.

10.9.2 Power-frequency electric strength	Is the panel builder's responsibility.
10.9.3 Impulse withstand voltage	Is the panel builder's responsibility.
10.9.4 Testing of enclosures made of insulating material	Is the panel builder's responsibility.
10.10 Temperature rise	The panel builder is responsible for the temperature rise calculation. Eaton will provide heat dissipation data for the devices.
10.11 Short-circuit rating	Is the panel builder's responsibility. The specifications for the switchgear must be observed.
10.12 Electromagnetic compatibility	Is the panel builder's responsibility. The specifications for the switchgear must be observed.
10.13 Mechanical function	The device meets the requirements, provided the information in the instruction leaflet (IL) is observed.
Additional information	
Model	Other

Technical data ETIM 9.0

Low-voltage industrial compone	nts (EG000017) / Wiring set for p	power circuit breaker (EC002050)

Electric engineering, automation, process control engineering / Low-voltage switch technology / Circuit breaker (LV < 1 kV) / Wiring set for circuit breaker (ecl@ss13-27-37-04-24 [ACN957016])

Suitable for number of poles	3
Model	Other