DATASHEET - FAZ-D2/3N

Miniature circuit breaker (MCB), 2 A, 3p+N, characteristic: D



	Part no.	FAZ-D2/3N 278986	
	EL Number (Norway)	1691209	
cations			

(101004)/	
General specifications	
Product name	Eaton Moeller series xEffect - FAZ MCB
Part no.	FAZ-D2/3N
EAN	4015082789862
Product Length/Depth	80 millimetre
Product height	75.5 millimetre
Product width	72 millimetre
Product weight	0.43 kilogram
Compliances	RoHS conform
Certifications	IEC 61373 EN45545-2
Product Tradename	xEffect - FAZ
Product Type	МСВ
Product Sub Type	None
Delivery program	
Application	Switchgear for industrial and advanced commercial applications xEffect - Switchgear for industrial and advanced commercial applications
Number of poles	Three-pole + N
Number of poles (total)	4
Number of poles (protected)	3
Tripping characteristic	D
Release characteristic	D
Amperage Rating	2 A
Туре	FAZ Miniature circuit breaker
Technical Data - Electrical	
Voltage type	AC
Rated operational voltage (Ue) - max	400 V
Rated insulation voltage (Ui)	440 V
Rated impulse withstand voltage (Uimp)	4 kV
Frequency rating - min	50 Hz
Frequency rating - max	60 Hz
Rated switching capacity (IEC/EN 60947-2)	15 kA
Rated short-circuit breaking capacity (EN 60898) at 230 V	10 kA
Rated short-circuit breaking capacity (EN 60898) at 400 V	10 kA
Rated short-circuit breaking capacity (IEC 60947-2) at 230 V	15 kA
Rated short-circuit breaking capacity (IEC 60947-2) at 400 V	15 kA
Overvoltage category	III
Pollution degree	2
Technical Data - Mechanical	
Width in number of modular spacings	4
Built-in depth	70.5 mm
Degree of protection	IP20
Connectable conductor cross section (solid-core) - min	1 mm ²
Connectable conductor cross section (solid-core) - max	25 mm ²
Connectable conductor cross section (multi-wired) - min	1 mm ²
Connectable conductor cross section (multi-wired) - max	25 mm ²
Design verification as per IEC/EN 61439 - technical data	

10.2.2 Corrosion resistanceMeets the product standard's requirements.10.2.3.1 Verification of thermal stability of enclosuresMeets the product standard's requirements.10.2.3.2 Verification of resistance of insulating materials to normal heatMeets the product standard's requirements.10.2.3.3 Resist. of insul. mat. to abnormal heat/fire by internal elect. effectsMeets the product standard's requirements.10.2.4 Resistance to ultra-violet (UV) radiationMeets the product standard's requirements.10.2.5 UffingDoes not apply, since the entire switchgear needs to be evaluated.10.2.7 InscriptionsMeets the product standard's requirements.10.3 Degree of protection of assembliesDoes not apply, since the entire switchgear needs to be evaluated.10.4 Clearances and creepage distancesMeets the product standard's requirements.10.5 Incorporation of switching devices and componentsDoes not apply, since the entire switchgear needs to be evaluated.10.6 Incorporation of switching devices and componentsMeets the panel builder's responsibility.10.8 Connections for external conductorsIs the panel builder's responsibility.10.9.2 Power-frequency electric strengthIs the panel builder's responsibility.10.9.3 Impuse withstand voltageIs the panel builder's responsibility.10.9.4 Testing of enclosures made of insulating materialIs the panel builder's responsibility.10.9.1 Enterning and of insulating materialIs the panel builder's responsibility.10.9.2 Impresture riseIs the panel builder's responsibility.10.9.3 Impuse withstand voltageIs the panel builder's responsibilit			
Equipment heat dissipation, non-variet-dependent 0W Heat dissipation, non-variet-dependent 0W Heat dissipation, non-variet-dependent 0W Ambient operating temperature - max 25 °C Design varification as per IC/CEN 61439 75 °C 102.2 Oursion resistance Meets the product standard's requirements. 102.3 Verification of themal stability of enclosures Meets the product standard's requirements. 102.3 Verification of themal stability of enclosures Meets the product standard's requirements. 102.3 Verification of themal stability of enclosures Meets the product standard's requirements. 102.3 Verification of themal stability of enclosures Meets the product standard's requirements. 102.4 Nextistance to ultra-violation of assemblies Does not apply, since the entrie switchgear needs to be evaluated. 102.5 Units Does not apply, since the entrie switchgear needs to be evaluated. 102.5 Units Does not apply, since the entrie switchgear needs to be evaluated. 102.5 Units Does not apply, since the entrie switchgear needs to be evaluated. 102.5 Units Does not apply, since the entrie switchgear needs to be evaluated. 102.5 Units Does not apply, since the entrie switchgear needs to be evaluated. <tr< td=""><td></td><td></td><td></td></tr<>			
Static hest dissipation, on-current-dependent 0 W Heat dissipation capacity 0 W Ambent operating temperature - min 25 °C Anihent operating temperature - min 7 °C Build temperature - min			
Heat dissipation capacity W Ambient operature - min -25 °C Ambient operature - max 75 °C Design verification as per IEC/EN 61439 Meets the product standard's requirements. 102.2 Droision resistance Meets the product standard's requirements. 102.2.3 Verification of resistance of insubiting materials to normal heat Meets the product standard's requirements. 102.3.2 Verification of resistance of unsubiting materials to normal heat Meets the product standard's requirements. 102.3.2 Verification of resistance of unsubiting materials to normal heat Meets the product standard's requirements. 102.3.2 Verification of resistance of unsubiting materials to normal heat Meets the product standard's requirements. 102.4 Resistance to untra-viole IUV radiation Meets the product standard's requirements. 102.2 Inscription Meets the product standard's requirements. 102.2 Inscription Des not apply, since the entire switchgear needs to be avaluated. 103.2 Operation of assemblies Des not apply, since the entire switchgear needs to be avaluated. 103.2 Description Des not apply, since the entire switchgear needs to be avaluated. 104.2 Description Des not apply, since the entire switchgear needs to be avaluated. 105.2 Protection against electric standard's equirements.	Equipment heat dissipation, current-dependent		
Ambient operating temperature - min Ambient operating temperature - max For C Source of the mail stability of enclosures 102.2 Consisting temperature - max 10.2 Consisting temperature - max 10.2 Consisting temperature - max 10.2 Consisting temperature - max 10.	Static heat dissipation, non-current-dependent	0 W	
Ambient operating temperature - max 73 °C Design verification as per IEC/EN 61439 Meets the product standard's requirements. 102.2.2 Consiston resistance Meets the product standard's requirements. 102.3.2 Verification of thermal stability of enclosures Meets the product standard's requirements. 102.3.2 Verification of resistance of insulating materials to normal heat Meets the product standard's requirements. 102.3.3 Resist. of insul. mat. to abnormal heat/fire by internal elect. effects Meets the product standard's requirements. 102.4 Resistance to ultra-viole(UV) radiation Des not app/, since the arrite switchger needs to be evaluated. 102.5 Mechanical impact Des not app/, since the arrite switchger needs to be evaluated. 102.6 Mechanical impact Des not app/, since the arrite switchger needs to be evaluated. 103.2 Mechanical impact Des not app/, since the arrite switchger needs to be evaluated. 103.6 Incorporation of witching devices and components Des not app/, since the arrite switchger needs to be evaluated. 103.1 Reserved evaluated connocions Is the panel builder's responsibility. 103.2 Power-frequency electric strandard in requirements. Des not app/, since the arrite switchger needs to be evaluated. 103.1 Reserved evaluated connocions Is the panel builder's responsibility.	Heat dissipation capacity	0 W	
Design verification as per IEC/EN 61439 Mests the product standard's requirements. 102.2 Corrosion resistance Mests the product standard's requirements. 102.3.1 Verification of themail stability of enclosures Mests the product standard's requirements. 102.3.2 Verification of translating materials to normal heat Mests the product standard's requirements. 102.3.3 Verification to abnormal heat/fire by internal elect effects Mests the product standard's requirements. 102.4 Resistance to ultra-violet IUV radiation Does not apply, since the entire switchpaar needs to be evaluated. 102.5 Urifing Does not apply, since the entire switchpaar needs to be evaluated. 102.5 Intrag of protection of assemblies Does not apply, since the entire switchpaar needs to be evaluated. 103.0 spree of protection of assemblies Does not apply, since the entire switchpaar needs to be evaluated. 104.0 learances and creepage distances Mests the product standard's requirements. 105.8 protection of switching devices and components Does not apply, since the entire switchpaar needs to be evaluated. 108.4 Concections for external conductors Is the panel builder's reaponsibility. 103.1 Streage that electrical circuits and connections Is the panel builder's reaponsibility. 103.2 Prover-frequency electric strength Is the panel builder'	Ambient operating temperature - min	-25 °C	
10.22 Corrosion resistance Image: Corrosion resistance of insulating materials to normal heat Image: Corrosion resistance of insulating materials to normal heat 10.2.3.1 Varification of resistance of insulating materials to normal heat Image: Corrosion resistance of insulating materials to normal heat 10.2.3.2 Varification of resistance of insulating materials to normal heat Image: Corrosion resistance of insulating materials to normal heat 10.2.3 Resist. of insul. Hait to abnormal heat/fire by internal elect. effects Meets the product standard's requirements. 10.2.4 Resistance to ultra-violet (UV) radiation Image: Corrosion resistance Does not apply, since the entire switchgear needs to be evaluated. 10.2.5 Uniting Image: Corrosion resistance Image: Corrosion resistance Does not apply, since the entire switchgear needs to be evaluated. 10.2.6 Morence in a gainst electric shock Image: Corrosion rapic, since the entire switchgear needs to be evaluated. Does not apply, since the entire switchgear needs to be evaluated. 10.3 Uniternal electrical circuits and connections Image: Corrosion rapic, since the entire switchgear needs to be evaluated. Does not apply, since the entire switchgear needs to be evaluated. 10.3 Uniternal electrical circuits and connections Image: Corrosion resistance of insulating material Image: Corrosion rapic responsibility. Does not apply, since the entire switchgear needs to be evaluated. 10.3 Uniternal elect	Ambient operating temperature - max	75 °C	
102.31 Varification of thermal stability of enclosures Meets the product standard's requirements. 102.3.2 Varification of resistance of insulating materials to normal heat Meets the product standard's requirements. 102.3.3 Resist. of insul. mat. to abnormal heat/fire by internal elect. effects Meets the product standard's requirements. 102.2.5 Lifting Meets the product standard's requirements. 102.5 Rechancel impact Does not apply, since the entire switchgear needs to be evaluated. 102.6 Mechanical impact Does not apply, since the entire switchgear needs to be evaluated. 102.6 Mechanical impact Does not apply, since the entire switchgear needs to be evaluated. 102.6 Mechanical impact Meets the product standard's requirements. 103.6 Degree of protection of assemblies Meets the product standard's requirements. 104.6 Degree of rotoction of assemblies Does not apply, since the entire switchgear needs to be evaluated. 105.8 Protection against electric shock Does not apply, since the entire switchgear needs to be evaluated. 105.8 Protection of switching material Step panel builder's responsibility. 108.2 Dower-frequency electric strength Is the panel builder's responsibility. 108.3 Impute withstand voltage Is the panel builder's responsibility. 10.10 Temperature rise Is the panel builder's responsib	Design verification as per IEC/EN 61439		
102.32 Verification of resistance of insulating materials to normal heat Meets the product standard's requirements. 102.3.3 Resist. of insul.mat. to abnormal heat/fire by internal elect. effects Meets the product standard's requirements. 102.4 Resistance to ultra-violet (UV) radiation Does not apply, since the entire switchgear needs to be evaluated. 102.5 Mining Does not apply, since the entire switchgear needs to be evaluated. 102.5 Michael and the product standard's requirements. Does not apply, since the entire switchgear needs to be evaluated. 102.5 Michael and the product standard's requirements. Does not apply, since the entire switchgear needs to be evaluated. 103.5 Protection against electric shock Does not apply, since the entire switchgear needs to be evaluated. 103.6 Dornection of switching devices and components Does not apply, since the entire switchgear needs to be evaluated. 103.6 Dornection of switching devices and components Is the panel builder's responsibility. 103.8 Oprocefrequery electric strength Is the panel builder's responsibility. 103.9 Dever-frequery electric strength Is the panel builder's responsibility. 103.1 Short-circuit rating Is the panel builder's responsibility. 103.1 Short-circuit rating Is the panel builder's responsibility. The specifications for the switchgear must be observed. 10.12 Electromagnetic compatibility <td>10.2.2 Corrosion resistance</td> <td>Meets the</td> <td>product standard's requirements.</td>	10.2.2 Corrosion resistance	Meets the	product standard's requirements.
102.33 Resist. of insul. mat. to abnormal heat/fire by internal elect. effects Meets the product standard's requirements. 102.4 Resistance to ultra-violet (UV) radiation Does not apply, since the entire switchgear needs to be avaluated. 102.5 Lifting Does not apply, since the entire switchgear needs to be avaluated. 102.7 Inscriptions Does not apply, since the entire switchgear needs to be avaluated. 103.0 Begree of protection of assemblies Does not apply, since the entire switchgear needs to be avaluated. 103.1 Contraction of assemblies Does not apply, since the entire switchgear needs to be avaluated. 104.1 Clearances and creepage distances Does not apply, since the entire switchgear needs to be avaluated. 105.1 Fortection against electric shock Does not apply, since the entire switchgear needs to be avaluated. 105.2 Foreor for extornal conductors Does not apply, since the entire switchgear needs to be avaluated. 105.2 Foreor for extornal conductors Does not apply, since the entire switchgear needs to be avaluated. 105.2 Foreor for extornal conductors Is the panel builder's responsibility. 108.2 Foreor for extornal conductors Is the panel builder's responsibility. 108.2 Foreor foreor for avalue and or insulating material Is the panel builder's responsibility. 109.2 Foreor foreor for avalue avaluated. Is the panel builder's responsibility.<	10.2.3.1 Verification of thermal stability of enclosures	Meets the	product standard's requirements.
102.4 Resistance to ultra-violet (UV) radiation Meets the product standard's requirements. 102.5 Lifting Does not apply, since the entire switchgear needs to be evaluated. 102.7 Inscriptions Does not apply, since the entire switchgear needs to be evaluated. 103.7 Degree of protection of assemblies Does not apply, since the entire switchgear needs to be evaluated. 10.4 Clearances and creepage distances Does not apply, since the entire switchgear needs to be evaluated. 10.5 Protection against electric shock Does not apply, since the entire switchgear needs to be evaluated. 10.6 Incorporation of switching devices and components Does not apply, since the entire switchgear needs to be evaluated. 10.8 Connections for external conductors Events the panel builder's responsibility. 10.8 Connections of external conductors Is the panel builder's responsibility. 10.9.4 Testing of enclosures made of insulating material Events the panel builder's responsibility. 10.9.4 Testing of enclosures made of insulating material Events the panel builder's responsibility. 10.1 Short-circuit rating Events the panel builder's responsibility. 10.11 Short-circuit rating Events the panel builder's responsibility. 10.12 Electromagnetic compatibility Is the panel builder's responsibility. 10.13 Mechanical function Events the	10.2.3.2 Verification of resistance of insulating materials to normal heat	Meets the	product standard's requirements.
102.5 LiftingDoes not apply, since the entire switchgear needs to be evaluated.102.7 InscriptionsDoes not apply, since the entire switchgear needs to be evaluated.10.3 Degree of protection of assembliesDoes not apply, since the entire switchgear needs to be evaluated.10.4 Clearances and creepage distancesMeets the product standard's requirements.10.5 Protection against electric shockDoes not apply, since the entire switchgear needs to be evaluated.10.6 Incorporation of switching devices and componentsDoes not apply, since the entire switchgear needs to be evaluated.10.8 Connections for external conductorsIs the panel builder's responsibility.10.8 Connections for external conductorsIs the panel builder's responsibility.10.9.1 Protection against electric strengthIs the panel builder's responsibility.10.9.2 Power-frequency electric strengthIs the panel builder's responsibility.10.9.3 Impulse withstand voltageIs the panel builder's responsibility.10.9.1 Cherger raiseIs the panel builder's responsibility.10.9.2 Power-frequency electric strengthIs the panel builder's responsibility.10.9.2 Electromagnetic compatibilityIs the panel builder's responsibility.10.9.4 Testing of enclosures made of insulating materialIs the panel builder's responsibility.10.11 Short-circuit ratingIs the panel builder's responsibility.10.12 Electromagnetic compatibilityIs step panel builder's responsibility.10.13 Machanical functionIndexice maets the requirements, provided the information in the instruction elefiet (1) is observed.Additional informat	10.2.3.3 Resist. of insul. mat. to abnormal heat/fire by internal elect. effects	Meets the	product standard's requirements.
10.2.8 Mechanical impact Does not apply, since the entire switchgear needs to be evaluated. 10.2.7 Inscriptions Does not apply, since the entire switchgear needs to be evaluated. 10.4 Clearances and creepage distances Does not apply, since the entire switchgear needs to be evaluated. 10.4 Clearances and creepage distances Does not apply, since the entire switchgear needs to be evaluated. 10.5 Protection against electric shock Does not apply, since the entire switchgear needs to be evaluated. 10.6 Incorporation of switching devices and components Is the panel builder's responsibility. 10.8 Connections for external conductors Is the panel builder's responsibility. 10.9.2 Power-frequency electric strength Is the panel builder's responsibility. 10.9.2 Power-frequency electric strength Is the panel builder's responsibility. 10.9.2 Power-frequency electric strength Is the panel builder's responsibility. 10.9.2 Power-frequency electric strength Is the panel builder's responsibility. 10.9.4 Testing of enclosures made of insulating material Is the panel builder's responsibility. 10.9.1 Temperature rise Is the panel builder's responsibility. 10.11 Short-circuit rating Is the panel builder's responsibility. The specifications for the switchgear must be observed. 10.12 Electromagnetic compatibility Is the	10.2.4 Resistance to ultra-violet (UV) radiation	Meets the	product standard's requirements.
10.2.7 Inscriptions Meets the product standard's requirements. 10.3 Degree of protection of assemblies Dees not apply, since the entire switchgear needs to be evaluated. 10.4 Clearances and creepage distances Dees not apply, since the entire switchgear needs to be evaluated. 10.5 Protection against electric shock Dees not apply, since the entire switchgear needs to be evaluated. 10.6 Incorporation of switching devices and components Dees not apply, since the entire switchgear needs to be evaluated. 10.7 Internal electrical circuits and connections Is the panel builder's responsibility. 10.8 Connections for external conductors Is the panel builder's responsibility. 10.8.2 Power-frequency electric strength Is the panel builder's responsibility. 10.9.3 Impulse withstand voltage Is the panel builder's responsibility. 10.9.4 Testing of enclosures made of insulating material Is the panel builder's responsibility. 10.10 Temperature rise Is the panel builder's responsibility. 10.11 Short-circuit rating Is the panel builder's responsibility. The specifications for the switchgear must be observed. 10.13 Mechanical function It device meets the requirements, provided the information in the instruction leasemape the ling of the temperature first a 1°C increase results in a 0.5% linear reduction of current switching N-neutral Additional equipment possible Concurrently s	10.2.5 Lifting	Does not a	pply, since the entire switchgear needs to be evaluated.
10.3 Degree of protection of assemblies Dees not apply, since the entire switchgear needs to be evaluated. 10.4 Clearances and creepage distances Meets the product standard's requirements. 10.5 Protection against electric shock Dees not apply, since the entire switchgear needs to be evaluated. 10.6 Incorporation of switching devices and components Dees not apply, since the entire switchgear needs to be evaluated. 10.7 Internal electrical circuits and connections Is the panel builder's responsibility. 10.8 Connections for external conductors Is the panel builder's responsibility. 10.8.1 Power-frequency electric strength Is the panel builder's responsibility. 10.9.2 Power-frequency electric strength Is the panel builder's responsibility. 10.9.3 Inpulse withstand voltage Is the panel builder's responsibility. 10.9.4 Testing of enclosures made of insulating material Is the panel builder's responsibility. 10.10 Temperature rise Is the panel builder's responsibility. 10.11 Short-circuit rating Is the panel builder's responsibility. The specifications for the switchgear must be observed. 10.12 Electromagnetic compatibility Is the panel builder's responsibility. The specifications for the switchgear must be observed. Additional information Is the panel builder's responsibility. The specifications for the switchgear must be observed.	10.2.6 Mechanical impact	Does not a	pply, since the entire switchgear needs to be evaluated.
10.4 Clearances and creepage distances Meets the product standard's requirements. 10.5 Protection against electric shock Does not apply, since the entire switchgear needs to be evaluated. 10.7 Internal electrical circuits and components Does not apply, since the entire switchgear needs to be evaluated. 10.8 Connections for external conductors Is the panel builder's responsibility. 10.9.2 Power-frequency electric strength Is the panel builder's responsibility. 10.9.3 Impulse withstand voltage Is the panel builder's responsibility. 10.9.4 Testing of enclosures made of insulating material Is the panel builder's responsibility. 10.10 Temperature rise Is the panel builder's responsibility. 10.11 Short-circuit rating Is the panel builder's responsibility. The specifications for the switchgear must be observed. 10.12 Electromagnetic compatibility Is the panel builder's responsibility. The specifications for the switchgear must be observed. 10.13 Mechanical function Is the panel builder's responsibility. The specifications for the switchgear must be observed. Additional information 3 Current limiting class 3 Features 3 Special features Additional equipment possible Used with Winiature circuit breaker	10.2.7 Inscriptions	Meets the	product standard's requirements.
10.5 Protection against electric shock Does not apply, since the entire switchgear needs to be evaluated. 10.6 Incorporation of switching devices and components Does not apply, since the entire switchgear needs to be evaluated. 10.7 Internal electrical circuits and connections Is the panel builder's responsibility. 10.8 Connections for external conductors Is the panel builder's responsibility. 10.9.2 Power-frequency electric strength Is the panel builder's responsibility. 10.9.3 Inpulse withstand voltage Is the panel builder's responsibility. 10.9.4 Testing of enclosures made of insulating material Is the panel builder's responsibility. 10.10 Temperature rise Is the panel builder's responsibility. 10.11 Short-circuit rating Is the panel builder's responsibility. The specifications for the switchgear must be observed. 10.12 Electromagnetic compatibility Is the panel builder's responsibility. The specifications for the switchgear must be observed. 10.13 Mechanical function Is the panel builder's responsibility. The specifications for the switchgear must be observed. Additional information 3 Current limiting class 3 Features Additional equipment possible Concurrently switching N-neutral Additional equipment possible Concurrently switching N-neutral Additional equipment possible Concurrently switc	10.3 Degree of protection of assemblies	Does not a	pply, since the entire switchgear needs to be evaluated.
10.6 Incorporation of switching devices and components Dees not apply, since the entire switchgear needs to be evaluated. 10.7 Internal electrical circuits and connections Is the panel builder's responsibility. 10.8 Connections for external conductors Is the panel builder's responsibility. 10.9.2 Power-frequency electric strength Is the panel builder's responsibility. 10.9.3 Inpulse withstand voltage Is the panel builder's responsibility. 10.9.4 Testing of enclosures made of insulating material Is the panel builder's responsibility. 10.10 Temperature rise Is the panel builder's responsibility. 10.11 Short-circuit rating Is the panel builder's responsibility. The specifications for the switchgear must be observed. 10.12 Electromagnetic compatibility Is the panel builder's responsibility. The specifications for the switchgear must be observed. 10.13 Mechanical function The device meets the requirements, provided the information in the instruction leafter (IL) is observed. Additional information The device meets the requirements, provided the information in the instruction of correct withing N-neutral Special features Additional equipment possible Concurrently switching N-neutral Muset with Muset with the orice circuit breaker	10.4 Clearances and creepage distances	Meets the	product standard's requirements.
10.7 Internal electrical circuits and connections5 the panel builder's responsibility.10.8 Connections for external conductors16 the panel builder's responsibility.10.9.2 Power-frequency electric strength16 the panel builder's responsibility.10.9.3 Impulse withstand voltage16 the panel builder's responsibility.10.9.4 Testing of enclosures made of insulating material16 the panel builder's responsibility.10.10 Temperature rise16 the panel builder's responsibility.10.11 Short-circuit rating16 the panel builder's responsibility. The specifications for the switchgear must be observed.10.12 Electromagnetic compatibility16 the panel builder's responsibility. The specifications for the switchgear must be observed.10.13 Mechanical function16 the panel builder's responsibility. The specifications for the switchgear must be observed.Additional entires3Current limiting class3Features3Special featuresAdditional equipment possible Concurrently switching N-neutral Anduiten al equipment possible Concurrent systeching N-neutral Additional equipment possible Concurrent systeching N-neutralUsed with10 the temperature rice usuts in a 0.5% linear reduction of concurrent ty switching N-neutral	10.5 Protection against electric shock	Does not a	pply, since the entire switchgear needs to be evaluated.
10.8 Connections for external conductors Is the panel builder's responsibility. 10.9.2 Power-frequency electric strength Is the panel builder's responsibility. 10.9.3 Impulse withstand voltage Is the panel builder's responsibility. 10.9.4 Testing of enclosures made of insulating material Is the panel builder's responsibility. 10.10 Temperature rise The panel builder's responsibility. 10.10 Temperature rise Is the panel builder's responsibility. 10.11 Short-circuit rating Is the panel builder's responsibility. The specifications for the switchgear must be observed. 10.12 Electromagnetic compatibility Is the panel builder's responsibility. The specifications for the switchgear must be observed. 10.13 Mechanical function The device meets the requirements, provided the information in the instruction lesting elements. Additional information Current limiting class 3 Features Additional equipment possible Additional equipment possible Special features Additional equipment possible Additional equipment possible Used with Web with Miniature circuit breaker	10.6 Incorporation of switching devices and components	Does not a	pply, since the entire switchgear needs to be evaluated.
10.3.2 Power-frequency electric strength Is the panel builder's responsibility. 10.9.3 Impulse withstand voltage Is the panel builder's responsibility. 10.9.4 Testing of enclosures made of insulating material Is the panel builder's responsibility. 10.10 Temperature rise Is the panel builder's responsibility. 10.11 Short-circuit rating Is the panel builder's responsibility. The specifications for the switchgear must be observed. 10.12 Electromagnetic compatibility Is the panel builder's responsibility. The specifications for the switchgear must be observed. 10.13 Mechanical function Is the panel builder's responsibility. The specifications for the switchgear must be observed. Additional information Is the panel builder's responsibility. The specifications for the switchgear must be observed. Current limiting class 3 Features Additional equipment possible Concrease results in a 0.5% linear reduction of current wit arrying capacity in carrying capacity in carying capacity in carrying capacity in carry	10.7 Internal electrical circuits and connections	Is the pane	el builder's responsibility.
10.9.3 Impulse withstand voltage Is the panel builder's responsibility. 10.9.4 Testing of enclosures made of insulating material Is the panel builder's responsibility. 10.10 Temperature rise Is the panel builder's responsibility. 10.11 Short-circuit rating Is the panel builder's responsibility. The specifications for the switchgear must be observed. 10.12 Electromagnetic compatibility Is the panel builder's responsibility. The specifications for the switchgear must be observed. 10.13 Mechanical function Is the panel builder's responsibility. The specifications for the switchgear must be observed. Additional information The device meets the requirements, provided the information in the instruction leaflet (IL) is observed. Special features 3 Used with Mbient temperature hint: a 1°C increase results in a 0.5% linear reduction of current carrying capacity	10.8 Connections for external conductors	Is the pane	el builder's responsibility.
10.9.4 Testing of enclosures made of insulating material Is the panel builder's responsibility. 10.10 Temperature rise The panel builder's responsibile for the temperature rise calculation. Eaton will provide heat dissipation data for the devices. 10.11 Short-circuit rating Is the panel builder's responsibility. The specifications for the switchgear must be observed. 10.12 Electromagnetic compatibility Is the panel builder's responsibility. The specifications for the switchgear must be observed. 10.13 Mechanical function Is the panel builder's responsibility. The specifications for the switchgear must be observed. Additional information The device meets the requirements, provided the information in the instruction leafter (ILL) is observed. Features 3 Special features Additional equipment possible Concurrently switching N-neutral Used with Winiature circuit breaker	10.9.2 Power-frequency electric strength	Is the pane	el builder's responsibility.
10.10 Temperature riseThe panel builder is responsible for the temperature rise calculation. Eaton will provide heat dissipation data for the devices.10.11 Short-circuit ratingIs the panel builder's responsibility. The specifications for the switchgear must be observed.10.12 Electromagnetic compatibilityIs the panel builder's responsibility. The specifications for the switchgear must be observed.10.13 Mechanical functionThe device meets the requirements, provided the information in the instruction leaflet (IL) is observed.Additional informationThe device meets the requirements, provided the information in the instruction leaflet (IL) is observed.Features3Special featuresAdditional equipment possible Concurrently switching N-neutral Ambient temperature hint: a 1 °C increase results in a 0.5% linear reduction of current carrying capacityUsed withWiniature circuit breaker	10.9.3 Impulse withstand voltage	Is the pane	el builder's responsibility.
In the second	10.9.4 Testing of enclosures made of insulating material	Is the pane	el builder's responsibility.
10.12 Electromagnetic compatibility observed. 10.13 Mechanical function Is the panel builder's responsibility. The specifications for the switchgear must be observed. Additional information The device meets the requirements, provided the information in the instruction leaflet (IL) is observed. Current limiting class Additional equipment possible Features Additional equipment possible Special features Additional equipment possible Used with Miniature circuit breaker	10.10 Temperature rise		
10.13 Mechanical function The device meets the requirements, provided the information in the instruction leaflet (IL) is observed. Additional information Image: Current limiting class Current limiting class 3 Features Additional equipment possible Concurrently switching N-neutral Special features Ambient temperature hint: a 1°C increase results in a 0.5% linear reduction of current carrying capacity Used with Image: Concurrent beaker	10.11 Short-circuit rating		el builder's responsibility. The specifications for the switchgear must be
Additional information Image: Current limiting class Image: Current limiting class Image: Current limiting class Features 3 Special features Additional equipment possible Concurrently switching N-neutral Used with Image: Current current limiting class	10.12 Electromagnetic compatibility		el builder's responsibility. The specifications for the switchgear must be
Current limiting class 3 Features Additional equipment possible Concurrently switching N-neutral Special features Ambient temperature hint: a 1 °C increase results in a 0.5% linear reduction of current carrying capacity Used with Miniature circuit breaker	10.13 Mechanical function		
Features Additional equipment possible Concurrently switching N-neutral Special features Ambient temperature hint: a 1 °C increase results in a 0.5% linear reduction of current carrying capacity Used with Miniature circuit breaker	Additional information		
Special features Concurrently switching N-neutral Used with Ambient temperature hint: a 1 °C increase results in a 0.5% linear reduction of current carrying capacity	Current limiting class	3	
Used with Miniature circuit breaker	Features		
	Special features		
	Used with		circuit breaker

Technical data ETIM 9.0

Circuit breakers and fuses (EG000020) / Miniature circuit breaker (MCB) (EC000042)

Electric engineering, automation, process control engineering / Electrical installation, device / Miniature circuit breaker system (MCB) / Miniature circuit breaker (MCB) (ecl@ss13-27-14-19-01 [AAB905019])					
Built-in depth	r	mm	70.5		
Release characteristic			D		
Number of poles (total)			4		
Number of protected poles			3		
Rated current	ŀ	A	2		
Rated voltage	١	V	400		
Rated insulation voltage Ui	١	V	440		
Rated impulse withstand voltage Uimp	k	kV	4		
Rated short-circuit breaking capacity Icn according to EN 60898 at 230 V	k	kA	10		
Voltage type			AC		
Rated short-circuit breaking capacity Icn according to EN 60898 at 400 V	k	kA	10		
Rated short-circuit breaking capacity Icu according to IEC 60947-2 at 230 V	k	kA	15		

Rated short-circuit breaking capacity Icu according to IEC 60947-2 at 400 V	kA	15
Frequency	Hz	50 - 60
Power loss	W	3.4
Current limiting class		3
Flush-mounted installation		No
Concurrently switching neutral conductor		Yes
Over voltage category		3
Pollution degree		2
Additional equipment possible		Yes
Width in number of modular spacings		4
Degree of protection (IP)		IP20
Ambient temperature during operating	°C	-25 - 75
Connectable conductor cross section multi-wired	mm²	1 - 25
Connectable conductor cross section solid-core	mm²	1 - 25
Explosion-proof		No