Transformer-protective circuit-breaker, 3p, Ir=1-1.6A, screw connection



Part no. PKZM0-1,6-T

088912

EL Number 4315155

(Norway)

| (Norway) | |
|--|--|
| General specifications | |
| Product name | Eaton Moeller® series PKZM0 Transformer-protective circuit-breaker |
| Part no. | PKZM0-1,6-T |
| EAN | 4015080889120 |
| Product Length/Depth | 76 millimetre |
| Product height | 93 millimetre |
| Product width | 45 millimetre |
| Product weight | 0.283 kilogram |
| Certifications | VDE 0660 IEC/EN 60947 |
| Product Tradename | PKZM0 |
| Product Type | Transformer-protective circuit-breaker |
| Product Sub Type | None |
| Catalog Notes | IE3-ready devices are identified by the logo on their packaging. |
| Features & Functions | |
| Actuator type | Turn button |
| Features | Phase-failure sensitivity (according to IEC/EN 60947-4-1, VDE 0660 Part 102) Complete device with protection unit |
| Fitted with: | Switched-off indicator |
| Functions | Transformer protection For the protection of transformers with a high inrush current |
| Number of poles | Three-pole |
| General information | |
| Connection | Screw terminals |
| Degree of protection | Terminals: IP00 IP20 |
| Lifespan, electrical | 100,000 operations |
| Lifespan, mechanical | 100,000 Operations |
| Mounting position | Can be snapped on to IEC/EN 60715 top-hat rail with 7.5 or 15 mm height. |
| Operating frequency | 40 Operations/h |
| Overvoltage category | III |
| Pollution degree | 3 |
| Product category | Transformer protective circuit breaker |
| Protection | Finger and back-of-hand proof, Protection against direct contact when actuated from front (EN 50274) |
| Rated impulse withstand voltage (Uimp) | 6000 V AC |
| Shock resistance | 25 g, Mechanical, according to IEC/EN 60068-2-27, Half-sinusoidal shock 10 ms |
| Suitable for | Also motors with efficiency class IE3 DIN rail (top hat rail) mounting |
| Temperature compensation | ≤ 0.25 %/K, residual error for T > 40° -25 - 55 °C, Operating range -5 - 40 °C to IEC/EN 60947, VDE 0660 |
| Climatic environmental conditions | |
| Altitude | Max. 2000 m |
| Ambient operating temperature - min | -25 °C |
| Ambient operating temperature - max | 55 °C |
| Ambient operating temperature (enclosed) - min | 25 °C |
| Ambient operating temperature (enclosed) - max | 40 °C |
| Ambient storage temperature - min | 40 °C |
| Ambient storage temperature - max | 80 °C |
| Climatic proofing | Damp heat, cyclic, to IEC 60068-2-30 |

| Terminal capacities | |
|--|--|
| | 1 v /1 - C) mm ² formula to DIN 40000 |
| Terminal capacity (flexible with ferrule) | 1 x (1 - 6) mm², ferrule to DIN 46228 2 x (1 - 6) mm², ferrule to DIN 46228 |
| Terminal capacity (solid) | 1 x (1 - 6) mm² 2 x (1 - 6) mm² |
| Terminal capacity (solid/stranded AWG) | 18 - 10 |
| Stripping length (main cable) | 10 mm |
| Tightening torque | 1.7 Nm, Screw terminals, Main cable |
| | 1 Nm, Screw terminals, Control circuit cables |
| Electrical rating | |
| Rated frequency - min | 50 Hz |
| Rated frequency - max | 60 Hz |
| Rated operational current (le) | 1.6 A |
| Rated operational voltage (Ue) - min | 690 V |
| Rated operational voltage (Ue) - max | 690 V |
| Rated uninterrupted current (Iu) | 1.6 A |
| Short-circuit rating | |
| Rated short-circuit breaking capacity Icu at 400 V AC | 150 kA |
| Rated short-circuit breaking capacity Ics at 400 V AC | 150 kA |
| Rated short-circuit breaking capacity Icu at 440 V AC | 150 kA |
| Rated short-circuit breaking capacity Ics at 440 V AC | 150 kA |
| Rated short-circuit breaking capacity Icu at 500 V AC | 150 kA |
| Rated short-circuit breaking capacity Ics at 500 V AC | 150 kA |
| Rated short-circuit breaking capacity Icu at 690 V AC | 150 kA |
| Rated short-circuit breaking capacity Ics at 690 V AC | 150 kA |
| Short-circuit current | 60 kA DC, up to 250 V DC, Main conducting paths |
| Short-circuit release | 32 A, Irm, Setting range max. Basic device, fixed $20 \times Iu$, Trip Blocks $\pm 20\%$ tolerance, Trip blocks |
| Switching capacity | |
| Switching capacity | 1.6 A, AC-3 up to 690 V 1.6 A (3 contacts in series), DC-5 up to 250V |
| Contacts | |
| Number of auxiliary contacts (change-over contacts) | 0 |
| Number of auxiliary contacts (normally closed contacts) | 0 |
| Number of auxiliary contacts (normally open contacts) | 0 |
| Trip blocks | |
| Overload release current setting - min | 1 A |
| Overload release current setting - max | 1.6 A |
| Design verification | |
| Equipment heat dissipation, current-dependent Pvid | 4.92 W |
| Heat dissipation capacity Pdiss | 0 W |
| Heat dissipation per pole, current-dependent Pvid | 1.64 W |
| Rated operational current for specified heat dissipation (In) | 1.6 A |
| Static heat dissipation, non-current-dependent Pvs | 0 W |
| 10.2.2 Corrosion resistance | Meets the product standard's requirements. |
| 10.2.3.1 Verification of thermal stability of enclosures | Meets the product standard's requirements. |
| 10.2.3.2 Verification of resistance of insulating materials to normal heat | Meets the product standard's requirements. |
| 10.2.3.3 Resist. of insul. mat. to abnormal heat/fire by internal elect. effects | Meets the product standard's requirements. |
| 10.2.4 Resistance to ultra-violet (UV) radiation | Meets the product standard's requirements. |
| 10.2.5 Lifting | Does not apply, since the entire switchgear needs to be evaluated. |
| 10.2.6 Mechanical impact | Does not apply, since the entire switchgear needs to be evaluated. |
| 10.2.7 Inscriptions | Meets the product standard's requirements. |
| 10.2.7 inscriptions 10.3 Degree of protection of assemblies | Does not apply, since the entire switchgear needs to be evaluated. |
| 10.4 Clearances and creepage distances | Meets the product standard's requirements. |
| 10.1 Giodianoos ana Groepaye aistanoes | miceto tile product standard o requirements. |

| 10.6 Incorporation of switching devices and components | Does not apply, since the entire switchgear needs to be evaluated. |
|--|--|
| 10.7 Internal electrical circuits and connections | Is the panel builder's responsibility. |
| 10.8 Connections for external conductors | Is the panel builder's responsibility. |
| 10.9.2 Power-frequency electric strength | Is the panel builder's responsibility. |
| 10.9.3 Impulse withstand voltage | Is the panel builder's responsibility. |
| 10.9.4 Testing of enclosures made of insulating material | Is the panel builder's responsibility. |
| 10.10 Temperature rise | The panel builder is responsible for the temperature rise calculation. Eaton will provide heat dissipation data for the devices. |
| 10.11 Short-circuit rating | Is the panel builder's responsibility. The specifications for the switchgear must b observed. |
| 10.12 Electromagnetic compatibility | Is the panel builder's responsibility. The specifications for the switchgear must b observed. |
| 10.13 Mechanical function | The device meets the requirements, provided the information in the instruction leaflet (IL) is observed. |

Technical data ETIM 9.0

Low-voltage industrial components (EG000017) / Power circuit-breaker for trafo/generator/installation protection (EC000228)

Electric engineering, automation, process control engineering / Low-voltage switch technology / Circuit breaker (LV < 1 kV) / Circuit breaker for power transformer, generator and system protection (ecl@ss13-27-37-04-09 [AJZ716018])

| Rated permanent current lu Rated voltage Rated voltage Rated short-circuit breaking capacity lcu at 400 V, 50 Hz Voerload release current setting Adjustment range short-term delayed short-circuit release Adjustment range undelayed short-circuit release A 0-0 Adjustment range undelayed short-circuit release A 0-0 Adjustment range undelayed short-circuit release A 0-0 Size Constitution No Screw connection Yes Number of auxiliary contacts as normally closed contact Number of auxiliary contacts as normally open contact Number of auxiliary contacts as change-over contact |
|--|
| Rated short-circuit breaking capacity Icu at 400 V, 50 Hz Overload release current setting All 1-1.6 Adjustment range short-term delayed short-circuit release All 0-0 Adjustment range undelayed short-circuit release All 32-32 Power loss Wll 4.92 Device construction Integrated earth fault protection Type of electrical connection of main circuit Suitable for DIN rail (top hat rail) mounting DIN rail (top hat rail) mounting optional Number of auxiliary contacts as normally open contact Number of auxiliary contacts as change-over contact Number of auxiliary contacts as change-over contact Na 1-1.6 All 1-1. |
| Overload release current setting Adjustment range short-term delayed short-circuit release Adjustment range undelayed short-circuit release A 32 - 32 Power loss W 4.92 Device construction Integrated earth fault protection Type of electrical connection of main circuit Suitable for DIN rail (top hat rail) mounting DIN rail (top hat rail) mounting optional Number of auxiliary contacts as normally open contact Number of auxiliary contacts as change-over contact Number of auxiliary contacts as change-over contact A 1 - 1.6 A 0 - 0 A 32 - 32 Built-in device fixed built-in technique No Screw connection Yes O O Number of auxiliary contacts as normally open contact O Number of auxiliary contacts as change-over contact O |
| Adjustment range short-term delayed short-circuit release Adjustment range undelayed short-circuit release A 32 - 32 Power loss W 4.92 Device construction Integrated earth fault protection Type of electrical connection of main circuit Suitable for DIN rail (top hat rail) mounting DIN rail (top hat rail) mounting optional Number of auxiliary contacts as normally open contact Number of auxiliary contacts as change-over contact A 0 - 0 A 32 - 32 W 4.92 Built-in device fixed built-in technique Screw connection Yes O O Number of auxiliary contacts as normally closed contact O Number of auxiliary contacts as change-over contact O Number of auxiliary contacts as change-over contact O |
| Adjustment range undelayed short-circuit release A 32 - 32 Power loss W 4.92 Device construction Integrated earth fault protection Type of electrical connection of main circuit Suitable for DIN rail (top hat rail) mounting DIN rail (top hat rail) mounting optional Number of auxiliary contacts as normally closed contact Number of auxiliary contacts as change-over contact Number of auxiliary contacts as change-over contact O Number of auxiliary contacts as change-over contact D A 32 - 32 Aug. 4.92 Built-in device fixed built-in technique No Screw connection Yes Yes O O Number of auxiliary contacts as normally open contact O Number of auxiliary contacts as change-over contact O Number of auxiliary contacts as change-over contact O |
| Power loss Device construction Integrated earth fault protection Type of electrical connection of main circuit Suitable for DIN rail (top hat rail) mounting DIN rail (top hat rail) mounting optional Number of auxiliary contacts as normally closed contact Number of auxiliary contacts as change-over contact Number of auxiliary contacts as change-over contact O Number of auxiliary contacts as change-over contact O O O O O O O O O O O O O |
| Device construction Integrated earth fault protection No Type of electrical connection of main circuit Suitable for DIN rail (top hat rail) mounting DIN rail (top hat rail) mounting optional Number of auxiliary contacts as normally closed contact Number of auxiliary contacts as change-over contact Number of auxiliary contacts as change-over contact O Number of auxiliary contacts as change-over contact Description of the chinque No Screw connection Yes O Number of auxiliary contacts as normally closed contact O Number of auxiliary contacts as change-over contact O |
| Integrated earth fault protection Type of electrical connection of main circuit Screw connection Suitable for DIN rail (top hat rail) mounting Yes DIN rail (top hat rail) mounting optional Yes Number of auxiliary contacts as normally closed contact Number of auxiliary contacts as normally open contact Number of auxiliary contacts as change-over contact O Number of auxiliary contacts as change-over contact O |
| Type of electrical connection of main circuit Suitable for DIN rail (top hat rail) mounting Yes DIN rail (top hat rail) mounting optional Number of auxiliary contacts as normally closed contact Number of auxiliary contacts as normally open contact Number of auxiliary contacts as change-over contact O Number of auxiliary contacts as change-over contact O |
| Suitable for DIN rail (top hat rail) mounting Yes DIN rail (top hat rail) mounting optional Yes Number of auxiliary contacts as normally closed contact 0 Number of auxiliary contacts as normally open contact 0 Number of auxiliary contacts as change-over contact 0 |
| DIN rail (top hat rail) mounting optional Number of auxiliary contacts as normally closed contact Number of auxiliary contacts as normally open contact Number of auxiliary contacts as change-over contact O Number of auxiliary contacts as change-over contact O |
| Number of auxiliary contacts as normally closed contact 0 Number of auxiliary contacts as normally open contact 0 Number of auxiliary contacts as change-over contact 0 |
| Number of auxiliary contacts as normally open contact 0 Number of auxiliary contacts as change-over contact 0 |
| Number of auxiliary contacts as change-over contact 0 |
| |
| With switched-off indicator |
| |
| With integrated under voltage release No |
| Number of poles 3 |
| Position of connection for main current circuit Other |
| Type of control element Turn button |
| Complete device with protection unit Yes |
| Motor drive integrated No |
| Motor drive optional No |
| Degree of protection (IP) |