

Circuit-breaker 4 pole, 125A

Part no. **NZMS2-4-A125**
109988

General specifications	
Product name	Eaton Moeller series NZM molded case circuit breaker thermo-magnetic
Part no.	NZMS2-4-A125
EAN	4015081095544
Product Length/Depth	149 millimetre
Product height	184 millimetre
Product width	140 millimetre
Product weight	3 kilogram
Compliances	RoHS conform
Product Tradename	NZM
Product Type	Molded case circuit breaker
Product Sub Type	Thermo-magnetic
Delivery program	
Number of poles	Four-pole
Amperage Rating	125 A
Features	Protection unit Motor drive optional
Special features	Rated current = rated uninterrupted current: 125 A
Technical Data - Electrical	
Voltage rating	690 V - 690 V
Current rating of neutral conductor	100% of phase conductor
Instantaneous current setting (Ii) - min	6 A
Instantaneous current setting (Ii) - max	10 A
Overload current setting (Ir)	100 A - 125 A
Overload current setting (Ir) - min	100 A
Overload current setting (Ir) - max	125 A
Short delay current setting (I _{sd}) - min	0 A
Short delay current setting (I _{sd}) - max	0 A
Short-circuit release non-delayed setting - min	6 A
Short-circuit release non-delayed setting - max	10 A
Rated short-circuit breaking capacity I _{cs} (IEC/EN 60947) at 400/415 V, 50/60 Hz	70 kA
Electrical connection type of main circuit	Screw connection
Handle type	Rocker lever
Technical Data - Mechanical	
Mounting Method	DIN rail (top hat rail) mounting optional Built-in device fixed built-in technique
Degree of protection	IP20
Number of auxiliary contacts (change-over contacts)	0
Number of auxiliary contacts (normally closed contacts)	0
Number of auxiliary contacts (normally open contacts)	0
Position of connection for main current circuit	Front side
Special features	Rated current = rated uninterrupted current: 125 A
Design verification as per IEC/EN 61439 - technical data	
Equipment heat dissipation, current-dependent	27.61 W
Ambient operating temperature - min	-25 °C
Ambient operating temperature - max	70 °C
Ambient storage temperature - min	40 °C
Ambient storage temperature - max	70 °C
Design verification as per IEC/EN 61439	

10.2.2 Corrosion resistance			Meets the product standard's requirements.
10.2.3.1 Verification of thermal stability of enclosures			Meets the product standard's requirements.
10.2.3.2 Verification of resistance of insulating materials to normal heat			Meets the product standard's requirements.
10.2.3.3 Resist. of insul. mat. to abnormal heat/fire by internal elect. effects			Meets the product standard's requirements.
10.2.4 Resistance to ultra-violet (UV) radiation			Meets the product standard's requirements.
10.2.5 Lifting			Does not apply, since the entire switchgear needs to be evaluated.
10.2.6 Mechanical impact			Does not apply, since the entire switchgear needs to be evaluated.
10.2.7 Inscriptions			Meets the product standard's requirements.
10.3 Degree of protection of assemblies			Does not apply, since the entire switchgear needs to be evaluated.
10.4 Clearances and creepage distances			Meets the product standard's requirements.
10.5 Protection against electric shock			Does not apply, since the entire switchgear needs to be evaluated.
10.6 Incorporation of switching devices and components			Does not apply, since the entire switchgear needs to be evaluated.
10.7 Internal electrical circuits and connections			Is the panel builder's responsibility.
10.8 Connections for external conductors			Is the panel builder's responsibility.
10.9.2 Power-frequency electric strength			Is the panel builder's responsibility.
10.9.3 Impulse withstand voltage			Is the panel builder's responsibility.
10.9.4 Testing of enclosures made of insulating material			Is the panel builder's responsibility.
10.10 Temperature rise			The panel builder is responsible for the temperature rise calculation. Eaton will provide heat dissipation data for the devices.
10.11 Short-circuit rating			Is the panel builder's responsibility. The specifications for the switchgear must be observed.
10.12 Electromagnetic compatibility			Is the panel builder's responsibility. The specifications for the switchgear must be observed.
10.13 Mechanical function			The device meets the requirements, provided the information in the instruction leaflet (IL) is observed.