

**Changeover switch, QM, 63 A, 2 x 3 pole + N (switched), without rotary handle, With drive shaft, 6 mm square**

**Part no. QM63/3N  
1319915**

<b>General specifications</b>	
Product name	Eaton QM Changeover switch
Part no.	QM63/3N
EAN	8711426140219
Product Length/Depth	14.5 millimetre
Product height	9.5 millimetre
Product width	13 millimetre
Product weight	0.48 kilogram
Certifications	IEC/EN 60947 RoHS IEC/EN 60947-3 CE VDE 0660 IEC/EN 60204
Product Tradename	QM
Product Type	Changeover switch
Product Sub Type	None
<b>Features &amp; Functions</b>	
Fitted with:	Drive shaft
Functions	Optional Stop Function
Number of poles	Four-pole
<b>General information</b>	
Accessories	Auxiliary contact fitted by user.
Actuator type	Other
Degree of protection	NEMA Other
Degree of protection (front side)	IP20
Mounting method	Rear mounting Top-hat rail mounting
Mounting position	As required
Overvoltage category	III
Pollution degree	3
Product Category	Changeover switches
Rated impulse withstand voltage (Uimp)	6000 V
Safety parameter (EN ISO 13849-1)	B10d values as per EN ISO 13849-1, table C.1
<b>Climatic environmental conditions</b>	
Ambient operating temperature - min	-25 °C
Ambient operating temperature - max	55 °C
Ambient storage temperature - min	-30 °C
Ambient storage temperature - max	80 °C
<b>Terminal capacities</b>	
Terminal capacity	1 x (2.5 - 10) mm <sup>2</sup> , flexible 2.5 - 16 mm <sup>2</sup> , solid
Stripping length (main cable)	10 mm
Tightening torque	1.8 Nm, Screw terminals, Main cables
<b>Electrical rating</b>	
Rated conditional short-circuit current (Iq)	15 kA
Rated insulation voltage (Ui)	690 V
Rated operational power at AC-23A, 400 V, 50 Hz	22 kW
Rated operational power at AC-3, 380/400 V, 50 Hz	18.5 kW
Rated operational voltage (Ue) at AC - max	690 V

Rated uninterrupted current (Iu)		63 A
Uninterrupted current		Rated uninterrupted current Iu is specified for max. cross-section.
<b>Contacts</b>		
Number of auxiliary contacts (normally closed contacts)		0
Number of auxiliary contacts (normally open contacts)		0
<b>Design verification</b>		
Equipment heat dissipation, current-dependent Pvid		0 W
Heat dissipation capacity Pdis		0 W
Heat dissipation per pole, current-dependent Pvid		6 W
Rated operational current for specified heat dissipation (In)		63 A
Static heat dissipation, non-current-dependent Pvs		0 W
10.2.2 Corrosion resistance		Meets the product standard's requirements.
10.2.3.1 Verification of thermal stability of enclosures		Meets the product standard's requirements.
10.2.3.2 Verification of resistance of insulating materials to normal heat		Meets the product standard's requirements.
10.2.3.3 Resist. of insul. mat. to abnormal heat/fire by internal elect. effects		Meets the product standard's requirements.
10.2.4 Resistance to ultra-violet (UV) radiation		Meets the product standard's requirements.
10.2.5 Lifting		Does not apply, since the entire switchgear needs to be evaluated.
10.2.6 Mechanical impact		Does not apply, since the entire switchgear needs to be evaluated.
10.2.7 Inscriptions		Meets the product standard's requirements.
10.3 Degree of protection of assemblies		Does not apply, since the entire switchgear needs to be evaluated.
10.4 Clearances and creepage distances		Meets the product standard's requirements.
10.5 Protection against electric shock		Does not apply, since the entire switchgear needs to be evaluated.
10.6 Incorporation of switching devices and components		Does not apply, since the entire switchgear needs to be evaluated.
10.7 Internal electrical circuits and connections		Is the panel builder's responsibility.
10.8 Connections for external conductors		Is the panel builder's responsibility.
10.9.2 Power-frequency electric strength		Is the panel builder's responsibility.
10.9.3 Impulse withstand voltage		Is the panel builder's responsibility.
10.9.4 Testing of enclosures made of insulating material		Is the panel builder's responsibility.
10.10 Temperature rise		The panel builder is responsible for the temperature rise calculation. Eaton will provide heat dissipation data for the devices.
10.11 Short-circuit rating		Is the panel builder's responsibility. The specifications for the switchgear must be observed.
10.12 Electromagnetic compatibility		Is the panel builder's responsibility. The specifications for the switchgear must be observed.
10.13 Mechanical function		The device meets the requirements, provided the information in the instruction leaflet (IL) is observed.