DATASHEET - FRCMM-63/4/05-G/F



Residual current circuit breaker (RCCB), 63A, 4p, 500mA, type G/F

Powering Business Worldwide™

FRCMM-63/4/05-G/F Part no. Catalog No. 187428

Similar to illustration

| Delivery program | | | |
|------------------------------|-----------------|----|--|
| Basic function | | | Residual current circuit-breakers |
| Number of poles | | | 4 pole |
| Application | | | Switchgear for industrial and advanced commercial applications |
| Rated current | In | Α | 63 |
| Rated short-circuit strength | I _{cn} | kA | 10 with back-up fuse |
| Rated fault current | $I_{\Delta N}$ | Α | 0.5 |
| Туре | | | Typ G/F (ÖVE E 8601) |
| Tripping | | s | 10 ms delayed |
| Product range | | | FRCmM |
| Sensitivity | | | Pulse-current sensitive |
| Impulse withstand current | | | Surge-proof, 3 kA |

| ectrica |
|---------|
| |
| |

| Tankai and data | | | |
|--|--------------------|--------|---|
| Technical data | | | |
| Electrical Types conform to | | | IEC/EN 62423 |
| Current test marks | | | As per inscription |
| Tripping | | s | 10 ms delayed |
| Rated voltage according to IEC/EN 60947-2 | Un | V AC | 240/415 |
| Rated frequency | f | Hz | 50/60 |
| Limit values of the operating voltage | | 2 | 0,00 |
| Test circuit | | V AC | 184 - 440 |
| Rated fault current | $I_{\Delta n}$ | mA | 500 |
| Sensitivity | 'ΔΠ | | Pulse-current sensitive |
| Enhanced sensitivity | | | Frequency mix (10 Hz, 50 Hz, 1000 Hz) |
| Rated insulation voltage | Ui | V | 440 |
| • | | | |
| Rated impulse withstand voltage | U _{imp} | kV | 4 (1.2/50μs) |
| Rated short-circuit strength | I _{cn} | kA | 10 with back-up fuse |
| Impulse withstand current | | | 3 kA (8/20 μs) surge-proof |
| Max. admissible back-up fuse | | | |
| Short-circuit | gG/gL | Α | 63 |
| Overload | gG/gL | Α | 63 |
| Rated making and breaking capacity / Rated residual making and breaking capacity | $I_m/I_{\Delta m}$ | Α | 630 |
| lifespan | | | |
| Electrical | Operations | | ≧ 4000 |
| Mechanical | Operations | | ≧ 20000 |
| Mechanical | | | |
| Standard front dimension | | mm | 45 |
| Device height | | mm | 80 |
| Built-in width | | mm | 70 (4TE) |
| Mounting | | | Quick attachment with 2 latch positions for DIN-rail IEC/EN 60715 |
| Degree of Protection | | | IP40, IP54 (with moisture-proof enclosure) |
| Terminals top and bottom | | | Twin-purpose terminals |
| Terminal protection | | | Busbar tag shroud to BGV A3, ÖVE-EN 6 |
| Terminal cross-section | | | |
| Solid | | mm^2 | 1.5 - 35 |

| Stranded | mm^2 | 2 x 16 |
|--|--------|---|
| Terminal cross-section | | M5 (with cross-recessed screw as defined in EN ISO 4757-Z2, Pozidriv PZ2) |
| Tightening torque of fixing screws | N/m | 2 - 2.4 |
| Thickness of busbar material | mm | 0.8 - 2 |
| Admissible ambient temperature range | °C | -25 - +40 |
| Permissible storage and transport temperatures | °C | -35 - +60 |
| Climatic proofing | | 25-55°C/90-95% relative humidity according to IEC 60068-2 |
| Mounting position | | As required |
| Contact position indicator | | red / green |
| Trip indication | | white / blue |

Design verification as per IEC/EN 61439

| Technical data for design verification | | | |
|--|-------------------|----|--|
| Rated operational current for specified heat dissipation | In | Α | 63 |
| Heat dissipation per pole, current-dependent | P _{vid} | W | 0 |
| Equipment heat dissipation, current-dependent | P _{vid} | W | 13.4 |
| Static heat dissipation, non-current-dependent | P _{vs} | W | 0 |
| Heat dissipation capacity | P _{diss} | W | 0 |
| Operating ambient temperature min. | | °C | -25 |
| Operating ambient temperature max. | | °C | 40 |
| | | | Starting at 40 °C, the max. permissible continuous current decreases by 3% for every 1 °C |
| IEC/EN 61439 design verification | | | |
| 10.2 Strength of materials and parts | | | |
| 10.2.2 Corrosion resistance | | | Meets the product standard's requirements. |
| 10.2.3.1 Verification of thermal stability of enclosures | | | Meets the product standard's requirements. |
| 10.2.3.2 Verification of resistance of insulating materials to normal heat | | | Meets the product standard's requirements. |
| 10.2.3.3 Verification of resistance of insulating materials to abnormal heat and fire due to internal electric effects $ \frac{1}{2} \left(\frac{1}{2} \right) = \frac{1}{2} \left(\frac{1}{2} \right) \left($ | | | Meets the product standard's requirements. |
| 10.2.4 Resistance to ultra-violet (UV) radiation | | | Meets the product standard's requirements. |
| 10.2.5 Lifting | | | Does not apply, since the entire switchgear needs to be evaluated. |
| 10.2.6 Mechanical impact | | | Does not apply, since the entire switchgear needs to be evaluated. |
| 10.2.7 Inscriptions | | | Meets the product standard's requirements. |
| 10.3 Degree of protection of ASSEMBLIES | | | Does not apply, since the entire switchgear needs to be evaluated. |
| 10.4 Clearances and creepage distances | | | Meets the product standard's requirements. |
| 10.5 Protection against electric shock | | | Does not apply, since the entire switchgear needs to be evaluated. |
| 10.6 Incorporation of switching devices and components | | | Does not apply, since the entire switchgear needs to be evaluated. |
| 10.7 Internal electrical circuits and connections | | | Is the panel builder's responsibility. |
| 10.8 Connections for external conductors | | | Is the panel builder's responsibility. |
| 10.9 Insulation properties | | | |
| 10.9.2 Power-frequency electric strength | | | Is the panel builder's responsibility. |
| 10.9.3 Impulse withstand voltage | | | Is the panel builder's responsibility. |
| 10.9.4 Testing of enclosures made of insulating material | | | Is the panel builder's responsibility. |
| 10.10 Temperature rise | | | The panel builder is responsible for the temperature rise calculation. Eaton will provide heat dissipation data for the devices. |
| 10.11 Short-circuit rating | | | Is the panel builder's responsibility. The specifications for the switch gear must be observed. $\label{eq:constraint}$ |
| 10.12 Electromagnetic compatibility | | | Is the panel builder's responsibility. The specifications for the switch gear must be observed. $\label{eq:constraint}$ |
| 10.13 Mechanical function | | | The device meets the requirements, provided the information in the instruction leaflet (IL) is observed. |

Technical data ETIM 7.0

Circuit breakers and fuses (EG000020) / Residual current circuit breaker (RCCB) (EC000003)

Electric engineering, automation, process control engineering / Electrical installation, device / Residual current protection system / Residual current circuit breaker (RCCB) (ecl@ss10.0.1-27-14-22-01 [AAB906014])

Number of poles 4

| Rated voltage | V | 240 |
|---|-----------------|----------|
| Rated current | А | 63 |
| Rated fault current | mA | 500 |
| Rated insulation voltage Ui | V | 440 |
| Rated impulse withstand voltage Uimp | kV | 4 |
| Mounting method | | DIN rail |
| Leakage current type | | Other |
| Selective protection | | No |
| Short-time delayed tripping | | Yes |
| Short-circuit breaking capacity (Icw) | kA | 10 |
| Surge current capacity | kA | 3 |
| Frequency | | 50 Hz |
| Additional equipment possible | | Yes |
| With interlocking device | | Yes |
| Degree of protection (IP) | | IP20 |
| Width in number of modular spacings | | 4 |
| Built-in depth | mm | 70.5 |
| Ambient temperature during operating | °C | -25 - 40 |
| Pollution degree | | 2 |
| Connectable conductor cross section multi-wired | mm ² | 1.5 - 16 |
| Connectable conductor cross section solid-core | mm ² | 1.5 - 35 |
| | | |