DATASHEET - FAZT-C2/1

Miniature circuit breaker (MCB), 2 A, 1p, characteristic: C



Part no.FAZT-C2/1Catalog No.240799Alternate CatalogFAZT-C2/1No.EL-Nummer1605564(Norway)



Similar to illustration

Delivery program

Basic function			Miniature circuit-breakers
Number of poles			1 pole
Tripping characteristic			C
Application			Switchgear for industrial and advanced commercial applications
Rated current	I _n	А	2
Rated switching capacity acc. to IEC/EN 60947-2	l _{cu}	kA	25
Product range			FAZ-T

Technical data Electrical

Electrical			
Standards			IEC/EN 60947-2
Rated voltage according to IEC/EN 60947-2	Un	V AC	240
Rated switching capacity acc. to IEC/EN 60947-2	I _{cu}	kA	25
Rated service short-circuit breaking capacity according to IEC/EN 60947-2	I _{cs}		12,5 kA
Max operational voltage according to IEC/EN 60947-2		V AC	254
Rated switching capacity according to IEC/EN 60947-2 (max operational voltage)	l _{cu}	kA	15
Rated service short-circuit breaking capacity according to IEC/EN 60947-2 (max operational voltage)	I _{cs}		7,5 KA
Max operational voltage DC according to IEC/EN 60947-2		V DC	60/pole
Rated voltage according to IEC/EN 60898-1	Un	V AC	240
Rated switching capacity according to IEC/EN 60898-1	I _{cn}	kA	15
Rated service short-circuit breaking capacity according to IEC/EN 60898-1	I _{cs}		7,5 kA
Rated insulation voltage	Ui	V	440
Rated frequency	f	Hz	50/60
Characteristic			B, C, D
Direction of incoming supply			as required
lifespan			
Electrical	Operations		≧ 4000
Mechanical	Operations		≧ 10000
Mechanical			
Standard front dimension		mm	45
Enclosure height		mm	80
Mounting width per pole		mm	17.5
Mounting			Quick attachment with 3 latch positions for top-hat rail IEC/EN 60715
Degree of Protection			IP20
Terminals top and bottom			Twin-purpose terminals
Terminal protection			Finger- and back-of-hand proof according to BGV A3 and ÖVE-EN 6
Terminal capacities		mm ²	1 - 25
Tightening torque of fixing screws		N/m	max. 2.4
Thickness of busbar material		mm	0.8 (exept N 0.5 SU)
Mounting position			As required

10.11 Short-circuit rating Is the panel builder's responsibility. The specifications for the switchgear must observed.	echnical data for design verification			
Pair Pair W 1 Static heat dissipation, one-current-dependent Pairs W 0 Static heat dissipation, one-current-dependent Pairs W 0 Operating ambient temperature min. C C 0 Operating ambient temperature max. C C 0 10.25 Vortification Formation Formation Formation 10.22 Corrosion resistance Formation Meets the product standard's requirements. Formation 10.23 Vortification of resistance of insulating materials to anomal heat and fred as to internal electric electric standard's requirements. Meets the product standard's requirements. Formation 10.23 Vortification of resistance of insulating materials to anomal heat electric electric standard's requirements. Meets the product standard's requirements. Formation 10.24 Resistance to ultra-violet (UV) rediation Formation Meets the product standard's requirements. Formation 10.23 Lordification of resistance of insulating materials to anomal heat electric electric standard's requirements. Meets the product standard's requirements. Formation 10.24 Resistance to ultra-violet (UV) rediation Formation Formation in the mitelefefefere </td <td>Rated operational current for specified heat dissipation</td> <td>I_n</td> <td>А</td> <td>2</td>	Rated operational current for specified heat dissipation	I _n	А	2
Natio that dissipation, non-current-dependent Pain West Heat dissipation capacity Pains West 0 Operating ambient temperature min. "C 40 Operating ambient temperature max. "C 40 VEX 61439 design verification To mean, per +1 °C, results in a 0.5% reduction of current carrying capacity 102.2 Strongth of materials and parts Meets the product standard's requirements. 102.3 Verification of resistance Meets the product standard's requirements. 102.3 Verification of resistance of insulating materials to abnormal heat Meets the product standard's requirements. 102.4 Verification of resistance of insulating materials to abnormal heat Meets the product standard's requirements. 102.3 Verification of resistance of insulating materials to abnormal heat Meets the product standard's requirements. 102.4 Resistance to ultra-violet (WI redutation Meets the product standard's requirements. 103.2 Verification against electric effects Des not apply, since the entire switchgar needs to be evaluated. 102.5 Interport Meets the product standard's requirements. 103.0 period grandee distances Standard's requirements. 104.0 Gearnor apply, since the entire switchgar needs to be evaluated.	Heat dissipation per pole, current-dependent	P _{vid}	W	0
Heat dissipation capacity Peak W Operating ambient temperature min. *	Equipment heat dissipation, current-dependent	P _{vid}	W	1.4
Operating ambient temperature min. Operating ambient temperature max. Image model Image	Static heat dissipation, non-current-dependent	P _{vs}	W	0
Operating ambient temperature max. PC 7 CEN 61498 design verification inser, per +1°C, results in a 0.5% reduction of current carrying capacity 10.2 Strength of materials and parts inser, per +1°C, results in a 0.5% reduction of current carrying capacity 10.2.2 Corrosion resistance Meets the product standard's requirements. 10.2.3.1 Verification of the insulating materials to normal heat Meets the product standard's requirements. 10.2.3.2 Verification of resistance of insulating materials to abnormal heat Meets the product standard's requirements. 10.2.3.3 Verification of resistance of insulating materials to abnormal heat Meets the product standard's requirements. 10.2.4 Meets the ut ut -violet (UV) radiation Meets the product standard's requirements. 10.2.5 Mechanical inpact Meets the product standard's requirements. 10.3.2 Merification of ASSEMBLIES Does not apply, since the entire switchgear needs to be evaluated. 10.4 Clearances and creepage distances Meets the product standard's requirements. 10.5 Protection of ASSEMBLIES Does not apply, since the entire switchgear needs to be evaluated. 10.6 Accornation is solucing davices and components Des not apply, since the entire switchgear needs to be evaluated. 10.5 Accornation is solucing davices and components Enthe panel builder	Heat dissipation capacity	P _{diss}	W	0
Inear, per -1 *C, results in a 0.5% reduction of current carrying capacity10.2 Strength of materials and parts10.2.3 Uverification of thermal stability of enclosures10.2.3 Life infraction of thermal stability of enclosures10.2.3 Life infraction of resistance of insulating materials to normal heat10.2.3 Life infraction of resistance of insulating materials to normal heat10.2.3 Life infraction of resistance of insulating materials to abnormal heatand fire due to internal electric effects10.2.3 Life infraction of resistance of insulating materials to abnormal heatand fire due to internal electric effects10.2.4 Resistance to ultra-widet (UV) radiation10.2.5 Lifting10.2.5 Lifting10.2.6 Lifting10.2.6 Lifting10.2.7 Inscriptions10.3 Degree of protection of ASSEMBLIES10.3 Degree of switchigear needs to be evaluated.10.4 Clearances and creepage distances10.5 Protection against electric shock10.6 Incorporation of switching devices and components10.7 Internal electrical circuits and connections10.8 Connections for external conductors10.9 Insulation properties10.9.1 Proverties10.9.2 Power-frequency electric strength10.9.2 Power-frequency electric strength10.9.2 Power-frequency electric strength10.9.1 Free panel builder's responsibility.10.9.2 Power-frequency electric strength10.9.1 Free panel builder's responsibility.10.9.2 Power-frequency electric strength10.9.2 Power-frequency electric strength10.9.2 Power-frequency electri	Operating ambient temperature min.		°C	-40
LCLN 61439 design varification Models Intervalue of materials and parts 10.22 Strength of materials and parts Meets the product standard's requirements. 10.2.3 Varification of trainal stability of enclosures Meets the product standard's requirements. 10.2.3 Varification of trainal stability of enclosures Meets the product standard's requirements. 10.2.3 Varification of resistance of insulating materials to abnormal heat and fire due to interval electric effects Meets the product standard's requirements. 10.2.4 Resistance to ultra-violet (UV) radiation Meets the product standard's requirements. 10.2.5 Lifting Does not apply, since the entire switchgear needs to be evaluated. 10.2.6 Mechanical impact Does not apply, since the entire switchgear needs to be evaluated. 10.2.6 Mechanical impact Does not apply, since the entire switchgear needs to be evaluated. 10.2.6 Mechanical impact Does not apply, since the entire switchgear needs to be evaluated. 10.2.6 Incorporation of switching devices and components Does not apply, since the entire switchgear needs to be evaluated. 10.7 Internal electric direcuits and connections Is the panel builder's responsibility. 10.8 Incorporation of switching devices and components Is the panel builder's responsibility. 10.9 Instaltion properties Is the panel builder's responsibility.	Operating ambient temperature max.		°C	75
10.2 Strength of materials and parts Mets the product standard's requirements. 10.2.3 Verification of thermal stability of enclosures Mets the product standard's requirements. 10.2.3.3 Verification of resistance of insulating materials to abnormal heat and fire due to intermal electric effects Mets the product standard's requirements. 10.2.3.3 Verification of resistance of insulating materials to abnormal heat and fire due to intermal electric effects Mets the product standard's requirements. 10.2.4 Resistance to ultra-violet (UV) radiation Mets the product standard's requirements. 10.2.5 Lifting Does not apply, since the entire switchgear needs to be evaluated. 10.2.6 Mechanical impact Does not apply, since the entire switchgear needs to be evaluated. 10.3.0 Degree of protection of ASSEMBLIES Does not apply, since the entire switchgear needs to be evaluated. 10.4.1 Inscriptions Does not apply, since the entire switchgear needs to be evaluated. 10.4.2 Inscription against electric shock Does not apply, since the entire switchgear needs to be evaluated. 10.4.1 Inscription against electric shock Does not apply, since the entire switchgear needs to be evaluated. 10.4.2 Inscription for external conductors Is the panel builder's responsibility. 10.8 Incorporation of switching devices and components Does not apply, since the entire switchgear needs to be evaluated. <				linear, per +1 °C, results in a 0.5% reduction of current carrying capacity
10.2.2 Corrosion resistance Meets the product standard's requirements. 10.2.3.1 Verification of thermal stability of enclosures Meets the product standard's requirements. 10.2.3.2 Verification of resistance of insulating materials to abnormal heat and fire due to internal electric effects Meets the product standard's requirements. 10.2.3.2 Verification of resistance of insulating materials to abnormal heat and fire due to internal electric effects Meets the product standard's requirements. 10.2.4 Resistance to ultra-violet (UV) radiation Meets the product standard's requirements. 10.2.5 Lifting Does not apply, since the entire switchgear needs to be evaluated. 10.2.6 Mechanical impact Meets the product standard's requirements. 10.2.7 Inscriptions Meets the product standard's requirements. 10.2.6 Internal electric al circuits and components Meets the product standard's requirements. 10.5 Protection against electric strength Meets the product standard's requirements. 10.8 Incorporation of switching devices and components Meets the panel builder's responsibility. 10.8 Incorporation for external conductors Meets the panel builder's responsibility. 10.8 Incorporation properties Internal electric al circuits and connections. 10.8 Incorporation of external conductors Meets the panel builder's responsibility. 10.8.9	C/EN 61439 design verification			
102.3.1 Verification of thermal stability of enclosures Meets the product standard's requirements. 102.3.2 Verification of resistance of insulating materials to abnormal heat and fire due to internal electric effects Meets the product standard's requirements. 102.4 Resistance to ultra-violet (UV) radiation Meets the product standard's requirements. 102.4 Resistance to ultra-violet (UV) radiation Does not apply, since the entire switchgear needs to be evaluated. 102.5 Lifting Does not apply, since the entire switchgear needs to be evaluated. 102.7 Inscriptions Meets the product standard's requirements. 103.2 Begree of protection of ASSEMBLIES Does not apply, since the entire switchgear needs to be evaluated. 105.2 Protection against electric shock Does not apply, since the entire switchgear needs to be evaluated. 105.1 Incorporation of switching devices and components Does not apply, since the entire switchgear needs to be evaluated. 105.2 Protection against electric strength Is the panel builder's responsibility. 108.2 Dower/requency electric strength Is the panel builder's responsibility. 109.3 Insulation properties Is the panel builder's responsibility. 109.4 Testing of enclosures made of insulating material Is the panel builder's responsibility. 109.3 Insulation properties Is the panel builder's responsibility.	10.2 Strength of materials and parts			
10.2.3 Verification of resistance of insulating materials to abnormal heat Meets the product standard's requirements. 10.2.3 Verification of resistance of insulating materials to abnormal heat Meets the product standard's requirements. 10.2.4 Resistance to ultra-violet (UV) radiation Meets the product standard's requirements. 10.2.5 Lifting Does not apply, since the entire switchgear needs to be evaluated. 10.2.6 Mechanical inpact Does not apply, since the entire switchgear needs to be evaluated. 10.2.7 Inscriptions Does not apply, since the entire switchgear needs to be evaluated. 10.3.0 Egree of protection of ASSEMBLIES Does not apply, since the entire switchgear needs to be evaluated. 10.4.1 Clearances and creepage distances Meets the product standard's requirements. 10.5.1 Fortorizon of switching devices and components Does not apply, since the entire switchgear needs to be evaluated. 10.8.2 Power-frequency electric strength Is the panel builder's responsibility. 10.9.3 Inpulse withstand voltage Is the panel builder's responsibility. 10.9.4 Testing of enclosures made of insulating material Is the panel builder's responsibility. 10.9.1 Prover-frequency electric strength Is the panel builder's responsibility. 10.9.2 Power-frequency electric strength Is the panel builder's responsibility. 10.9.1 Prover freq	10.2.2 Corrosion resistance			Meets the product standard's requirements.
10.2.3.3 Verification of resistance of insulating materials to abnormal heat Meets the product standard's requirements. 10.2.4 Resistance to ultra-violet (UV) radiation Meets the product standard's requirements. 10.2.5 Lifting Does not apply, since the entire switchgear needs to be evaluated. 10.2.6 Mechanical impact Does not apply, since the entire switchgear needs to be evaluated. 10.2.7 Inscriptions Meets the product standard's requirements. 10.3 Degree of protection of ASSEMBLIES Does not apply, since the entire switchgear needs to be evaluated. 10.4 Clearances and creepage distances Does not apply, since the entire switchgear needs to be evaluated. 10.5 Protection against electric shock Does not apply, since the entire switchgear needs to be evaluated. 10.5 Incorporation of switching devices and components Does not apply, since the entire switchgear needs to be evaluated. 10.7 Internal electric al circuits and connections Internal electric strength 10.8 Connections for external conductors Internal electric strength 10.9 Insulation properties Internal electric strength 10.9.1 Temperature rise Internal electric disculation data for the devices. 10.9.2 Power-frequency electric strength Internal electric disculation data for the devices. 10.9.3 Impulse withstand voltage Internal electric diss	10.2.3.1 Verification of thermal stability of enclosures			Meets the product standard's requirements.
and fire due to internal electric effectsAnd fire due to internal electric effectsAnd fire due to internal electric effects10.2.4 Resistance to ultra-violet (UV) radiationMeets the product standard's requirements.10.2.5 LiftingDoes not apply, since the entire switchgear needs to be evaluated.10.2.5 Mechanical impactDoes not apply, since the entire switchgear needs to be evaluated.10.2.5 Mechanical impactMeets the product standard's requirements.10.3.7 InscriptionsMeets the product standard's requirements.10.3.2 Begree of protection of ASSEMBLIESDoes not apply, since the entire switchgear needs to be evaluated.10.4 Clearances and creepage distancesMeets the product standard's requirements.10.5 Protection against electric shockDoes not apply, since the entire switchgear needs to be evaluated.10.7 Internal electrical circuits and connectionsEntite panel builder's responsibility.10.8 Connections for external conductorsIs the panel builder's responsibility.10.9.2 Power-frequency electric strengthIs the panel builder's responsibility.10.9.1 Internal electrical circuits and connectionsIs the panel builder's responsibility.10.9.2 Power-frequency electric strengthIs the panel builder's responsibility.10.9.1 Temperature riseIs the panel builder's responsibility.10.10 Temperature riseIs the panel builder's responsibility.10.11 Short-circuit ratingIs the panel builder's responsibility.10.12 Electromagnetic compatibility.Is the panel builder's responsibility.10.13 Mechanical functionIs the panel builder's responsi	10.2.3.2 Verification of resistance of insulating materials to normal heat			Meets the product standard's requirements.
10.2.5 LiftingDoes not apply, since the entire switchgear needs to be evaluated.10.2.6 Mechanical impactDoes not apply, since the entire switchgear needs to be evaluated.10.2.7 InscriptionsMeets the product standard's requirements.10.3 Degree of protection of ASSEMBLIESDoes not apply, since the entire switchgear needs to be evaluated.10.4 Clearances and creepage distancesMeets the product standard's requirements.10.5 Protection against electric shockDoes not apply, since the entire switchgear needs to be evaluated.10.6 Incorporation of switching devices and componentsDoes not apply, since the entire switchgear needs to be evaluated.10.7 Internal electrical circuits and connectionsIs the panel builder's responsibility.10.8 Connections for external conductorsIs the panel builder's responsibility.10.9 Insulation propertiesIs the panel builder's responsibility.10.9.1 Subjective standard vitageIs the panel builder's responsibility.10.9.2 Power-frequency electric strengthIs the panel builder's responsibility.10.9.3 Impulse withstand voltageIs the panel builder's responsibility.10.10 Temperature riseIs the panel builder's responsibility.10.11 Short-circuit ratingIs the panel builder's responsibility. The specifications for the switchgear must observed.10.13 Mechanical functionIs the panel builder's responsibility. The specifications for the switchgear must observed.10.13 Mechanical functionIs the panel builder's responsibility. The specifications for the switchgear must observed.				Meets the product standard's requirements.
10.2.8 Mechanical impact Dees not apply, since the entire switchgear needs to be evaluated. 10.2.7 Inscriptions Meets the product standard's requirements. 10.3 Degree of protection of ASSEMBLIES Does not apply, since the entire switchgear needs to be evaluated. 10.4 Clearances and creepage distances Meets the product standard's requirements. 10.5 Protection against electric shock Does not apply, since the entire switchgear needs to be evaluated. 10.6 Incorporation of switching devices and components Does not apply, since the entire switchgear needs to be evaluated. 10.7 Internal electrical circuits and connections Is the panel builder's responsibility. 10.8 Connections for external conductors Is the panel builder's responsibility. 10.9.1 Power-frequency electric strength Is the panel builder's responsibility. 10.9.2 Power-frequency electric strength Is the panel builder's responsibility. 10.9.3 Impulse withstand voltage Is the panel builder's responsibility. 10.10 Temperature rise The panel builder's responsibility. 10.11 Short-circuit rating Is the panel builder's responsibility. The specifications for the switchgear must observed. 10.13 Mechanical function The device meets the requirements, provided the information in the instruction	10.2.4 Resistance to ultra-violet (UV) radiation			Meets the product standard's requirements.
10.2.7 Inscriptions Meets the product standard's requirements. 10.3 Degree of protection of ASSEMBLIES Does not apply, since the entire switchgear needs to be evaluated. 10.4 Clearances and creepage distances Meets the product standard's requirements. 10.5 Protection against electric shock Does not apply, since the entire switchgear needs to be evaluated. 10.6 Incorporation of switching devices and components Does not apply, since the entire switchgear needs to be evaluated. 10.7 Internal electrical circuits and connections Is the panel builder's responsibility. 10.8 Connections for external conductors Is the panel builder's responsibility. 10.9.1 Insulation properties Is the panel builder's responsibility. 10.9.2 Power-frequency electric strength Is the panel builder's responsibility. 10.9.3 Inpulse withstand voltage Is the panel builder's responsibility. 10.9.4 Testing of enclosures made of insulating material Is the panel builder's responsibility. 10.10 Temperature rise Is the panel builder's responsibility. 10.11 Short-circuit rating Is the panel builder's responsibility. The specifications for the switchgear must observed. 10.12 Electromagnetic compatibility. Is the panel builder's responsibility. The specifications for the switchgear must observed. 10.13 Mechanical function The device me	10.2.5 Lifting			Does not apply, since the entire switchgear needs to be evaluated.
10.3 Degree of protection of ASSEMBLIES Dees not apply, since the entire switchgear needs to be evaluated. 10.4 Clearances and creepage distances Meets the product standard's requirements. 10.5 Protection against electric shock Dees not apply, since the entire switchgear needs to be evaluated. 10.6 Incorporation of switching devices and components Dees not apply, since the entire switchgear needs to be evaluated. 10.7 Internal electrical circuits and connections Is the panel builder's responsibility. 10.8 Connections for external conductors Is the panel builder's responsibility. 10.9.1 Subation properties Is the panel builder's responsibility. 10.9.2 Power-frequency electric strength Is the panel builder's responsibility. 10.9.3 Inpulse withstand voltage Is the panel builder's responsibility. 10.9.4 Testing of enclosures made of insulating material Is the panel builder's responsibility. 10.10 Temperature rise Is the panel builder's responsibility. 10.11 Short-circuit rating Is the panel builder's responsibility. The specifications for the switchgear must observed. 10.12 Electromagnetic compatibility Is the panel builder's responsibility. The specifications for the switchgear must observed. 10.13 Mechanical function The device meets the requirements, provided the information in the instruction	10.2.6 Mechanical impact			Does not apply, since the entire switchgear needs to be evaluated.
10.4 Clearances and creepage distances Meets the product standard's requirements. 10.5 Protection against electric shock Does not apply, since the entire switchgear needs to be evaluated. 10.6 Incorporation of switching devices and components Does not apply, since the entire switchgear needs to be evaluated. 10.7 Internal electrical circuits and connections Is the panel builder's responsibility. 10.8 Connections for external conductors Is the panel builder's responsibility. 10.9 Insulation properties Is the panel builder's responsibility. 10.9.1 Supply electric strength Is the panel builder's responsibility. 10.9.2 Power-frequency electric strength Is the panel builder's responsibility. 10.9.3 Impulse withstand voltage Is the panel builder's responsibility. 10.9.4 Testing of enclosures made of insulating material Is the panel builder's responsibility. 10.11 Short-circuit rating Is the panel builder's responsibility. The specifications for the switchgear musc observed. 10.12 Electromagnetic compatibility Is the panel builder's responsibility. The specifications for the switchgear musc observed. 10.13 Mechanical function The device meets the requirements, provided the information in the instruction	10.2.7 Inscriptions			Meets the product standard's requirements.
10.5 Protection against electric shock Dees not apply, since the entire switchgear needs to be evaluated. 10.6 Incorporation of switching devices and components Does not apply, since the entire switchgear needs to be evaluated. 10.7 Internal electrical circuits and connections Is the panel builder's responsibility. 10.8 Connections for external conductors Is the panel builder's responsibility. 10.9 Insulation properties Is the panel builder's responsibility. 10.9.2 Power-frequency electric strength Is the panel builder's responsibility. 10.9.3 Impulse withstand voltage Is the panel builder's responsibility. 10.9.4 Testing of enclosures made of insulating material Is the panel builder's responsibility. 10.11 Short-circuit rating Is the panel builder's responsibility. 10.12 Electromagnetic compatibility Is the panel builder's responsibility. The specifications for the switchgear muse observed. 10.13 Mechanical function The device meets the requirements, provided the information in the instruction	10.3 Degree of protection of ASSEMBLIES			Does not apply, since the entire switchgear needs to be evaluated.
10.6 Incorporation of switching devices and components Does not apply, since the entire switchgear needs to be evaluated. 10.7 Internal electrical circuits and connections Is the panel builder's responsibility. 10.8 Connections for external conductors Is the panel builder's responsibility. 10.9 Insulation properties Is the panel builder's responsibility. 10.9.2 Power-frequency electric strength Is the panel builder's responsibility. 10.9.3 Impulse withstand voltage Is the panel builder's responsibility. 10.9.4 Testing of enclosures made of insulating material Is the panel builder's responsibility. 10.11 Short-circuit rating Is the panel builder's responsibility. The specifications for the switchgear must observed. 10.12 Electromagnetic compatibility Is the panel builder's responsibility. The specifications for the switchgear must observed. 10.13 Mechanical function It evice meets the requirements, provided the information in the instruction	10.4 Clearances and creepage distances			Meets the product standard's requirements.
10.7 Internal electrical circuits and connections Is the panel builder's responsibility. 10.8 Connections for external conductors Is the panel builder's responsibility. 10.9 Insulation properties Is the panel builder's responsibility. 10.9.2 Power-frequency electric strength Is the panel builder's responsibility. 10.9.3 Impulse withstand voltage Is the panel builder's responsibility. 10.9.4 Testing of enclosures made of insulating material Is the panel builder's responsibility. 10.10 Temperature rise Is the panel builder's responsibility. 10.11 Short-circuit rating Is the panel builder's responsibility. The specifications for the switchgear must observed. 10.12 Electromagnetic compatibility Is the panel builder's responsibility. The specifications for the switchgear must observed. 10.13 Mechanical function The device meets the requirements, provide the information in the instruction	10.5 Protection against electric shock			Does not apply, since the entire switchgear needs to be evaluated.
10.8 Connections for external conductors Is the panel builder's responsibility. 10.9 Insulation properties Is the panel builder's responsibility. 10.9.2 Power-frequency electric strength Is the panel builder's responsibility. 10.9.3 Impulse withstand voltage Is the panel builder's responsibility. 10.9.4 Testing of enclosures made of insulating material Is the panel builder's responsibility. 10.10 Temperature rise Is the panel builder's responsibility. 10.11 Short-circuit rating Is the panel builder's responsibility. The specifications for the switchgear must observed. 10.12 Electromagnetic compatibility Is the panel builder's responsibility. The specifications for the switchgear must observed. 10.13 Mechanical function The device meets the requirements, provided the information in the instruction	10.6 Incorporation of switching devices and components			Does not apply, since the entire switchgear needs to be evaluated.
10.9 Insulation properties Image: Constraint of the panel builder's responsibility. 10.9.2 Power-frequency electric strength Is the panel builder's responsibility. 10.9.3 Impulse withstand voltage Is the panel builder's responsibility. 10.9.4 Testing of enclosures made of insulating material Is the panel builder's responsibility. 10.10 Temperature rise Is the panel builder is responsibility. 10.11 Short-circuit rating Is the panel builder's responsibility. The specifications for the switchgear must observed. 10.12 Electromagnetic compatibility Is the panel builder's responsibility. The specifications for the switchgear must observed. 10.13 Mechanical function The device meets the requirements, provided the information in the instruction	10.7 Internal electrical circuits and connections			Is the panel builder's responsibility.
10.9.2 Power-frequency electric strengthIs the panel builder's responsibility.10.9.3 Impulse withstand voltageIs the panel builder's responsibility.10.9.4 Testing of enclosures made of insulating materialIs the panel builder's responsibility.10.10 Temperature riseIs the panel builder's responsibility.10.11 Short-circuit ratingIs the panel builder's responsibility. The specifications for the switchgear must observed.10.12 Electromagnetic compatibilityIs the panel builder's responsibility. The specifications for the switchgear must observed.10.13 Mechanical functionThe device meets the requirements, provided the information in the instruction	10.8 Connections for external conductors			Is the panel builder's responsibility.
10.9.3 Impulse withstand voltage Is the panel builder's responsibility. 10.9.4 Testing of enclosures made of insulating material Is the panel builder's responsibility. 10.10 Temperature rise The panel builder is responsibility. 10.11 Short-circuit rating Is the panel builder's responsibility. The specifications for the switchgear must observed. 10.12 Electromagnetic compatibility Is the panel builder's responsibility. The specifications for the switchgear must observed. 10.13 Mechanical function The device meets the requirements, provided the information in the instruction	10.9 Insulation properties			
10.9.4 Testing of enclosures made of insulating materialIs the panel builder's responsibility.10.10 Temperature riseIs the panel builder is responsibility.10.11 Short-circuit ratingIs the panel builder's responsibility. The specifications for the switchgear must observed.10.12 Electromagnetic compatibilityIs the panel builder's responsibility. The specifications for the switchgear must observed.10.13 Mechanical functionThe device meets the requirements, provided the information in the instruction	10.9.2 Power-frequency electric strength			Is the panel builder's responsibility.
10.10 Temperature riseThe panel builder is responsible for the temperature rise calculation. Eaton with provide heat dissipation data for the devices.10.11 Short-circuit ratingIs the panel builder's responsibility. The specifications for the switchgear must observed.10.12 Electromagnetic compatibilityIs the panel builder's responsibility. The specifications for the switchgear must observed.10.13 Mechanical functionThe device meets the requirements, provided the information in the instruction	10.9.3 Impulse withstand voltage			Is the panel builder's responsibility.
10.11 Short-circuit rating Is the panel builder's responsibility. The specifications for the switchgear must observed. 10.12 Electromagnetic compatibility Is the panel builder's responsibility. The specifications for the switchgear must observed. 10.13 Mechanical function The device meets the requirements, provided the information in the instruction	10.9.4 Testing of enclosures made of insulating material			Is the panel builder's responsibility.
10.12 Electromagnetic compatibility observed. 10.13 Mechanical function Is the panel builder's responsibility. The specifications for the switchgear must observed.	10.10 Temperature rise			The panel builder is responsible for the temperature rise calculation. Eaton will provide heat dissipation data for the devices.
10.13 Mechanical function The device meets the requirements, provided the information in the instruction	10.11 Short-circuit rating			Is the panel builder's responsibility. The specifications for the switchgear mus observed.
	10.12 Electromagnetic compatibility			Is the panel builder's responsibility. The specifications for the switchgear must observed.
	10.13 Mechanical function			

Technical data ETIM 7.0


Circuit breakers and fuses (EG000020) / Miniature circuit breaker (MCB) (EC000042)

Electric engineering, automation, process control engineering / Electrical installation, device / Miniature circuit breaker system (MCB) / Miniature circuit breaker (MCB) (ecl@ss10.0.1-27-14-19-01 [AAB905014])


Release characteristic		C
Number of poles (total)		1
Number of protected poles		1
Rated current	A	2
Rated voltage	V	240
Rated insulation voltage Ui	V	440
Rated impulse withstand voltage Uimp	kV	4
Rated short-circuit breaking capacity Icn EN 60898 at 230 V	kA	15
Rated short-circuit breaking capacity Icn EN 60898 at 400 V	kA	15
Rated short-circuit breaking capacity Icu IEC 60947-2 at 230 V	kA	25
Rated short-circuit breaking capacity Icu IEC 60947-2 at 400 V	kA	25
Voltage type		AC
Frequency	Hz	50 - 60

Current limiting class		3
Suitable for flush-mounted installation		No
Concurrently switching N-neutral		No
Over voltage category		3
Pollution degree		2
Additional equipment possible		Yes
Width in number of modular spacings		1
Built-in depth	mm	70.5
Degree of protection (IP)		IP20
Ambient temperature during operating	°C	-25 - 75
Connectable conductor cross section multi-wired	mm²	1 - 25
Connectable conductor cross section solid-core	mm²	1 - 25

Characteristics



Dimensions



Additional product information (links)

Temperature dependency, derating

https://www.eaton.com/content/dam/eaton/technicaldocumentation/technical-data-tables/Derating table FAZ_T.pdf