## DATASHEET - AZ-2-C40

Miniature circuit breaker (MCB), 40A, 2p, C-Char



Part no.	AZ-2-C40
	211785
EL Number	1601045
(Norway)	

General specifications	
Product name	Eaton Moeller series xEffect - AZ MCB
Part no.	AZ-2-C40
EAN	4015082117856
Product Length/Depth	90 millimetre
Product height	75 millimetre
Product width	54 millimetre
Product weight	0.442 kilogram
Compliances	RoHS conform
Certifications	IEC/EN 60947-2 EN45545-2 IEC 61373
Product Tradename	xEffect - AZ MCB
Product Type	MCB
Product Sub Type	None
Delivery program	
Application	Switchgear for industrial and advanced commercial applications xEffect - Switchgear for industrial and advanced commercial applications
Number of poles	Two-pole
Number of poles (total)	2
Number of poles (protected)	2
Tripping characteristic	C
Release characteristic	C
Amperage Rating	40 A
Туре	AZ Miniature circuit breaker
Technical Data - Electrical	
Voltage type	AC
Voltage rating	230 V AC / 400 V AC
Voltage rating at DC	60 V DC (per pole)
Rated operational voltage (Ue) - max	400 V
Rated insulation voltage (Ui)	440 V
Rated impulse withstand voltage (Uimp)	4 kV
Frequency rating - min	50 Hz
Frequency rating - max	60 Hz
Rated switching capacity (IEC/EN 60947-2)	25 kA
Operational switching capacity	20 kA
Rated short-circuit breaking capacity (EN 60898) at 230 V	0 kA
Rated short-circuit breaking capacity (EN 60898) at 400 V	0 kA
Rated short-circuit breaking capacity (IEC 60947-2) at 230 V	25 kA
Rated short-circuit breaking capacity (IEC 60947-2) at 400 V	25 kA
Admissible back-up fuse - max	200 A gL/gG
Selectivity class	3
Lifespan, electrical	10000 operations
Overvoltage category	II
Pollution degree	2
Direction of incoming supply	As required
Technical Data - Mechanical	
Frame	45 mm

	aa
Enclosure width	90 mm
Width in number of modular spacings	3
Built-in depth	75 mm
Mounting width per pole	27 mm
Mounting width	27 mm
Mounting Method	Top-hat rail IEC/EN 60715
Degree of protection	IP40 (when fitted) IP20
Terminals (top and bottom)	Lift terminals
Connectable conductor cross section (solid-core) - min	2.5 mm <sup>2</sup>
Connectable conductor cross section (solid-core) - max	50 mm <sup>2</sup>
Connectable conductor cross section (multi-wired) - min	2.5 mm <sup>2</sup>
Connectable conductor cross section (multi-wired) - max	50 mm <sup>2</sup>
Terminal capacity (control cable)	2.5 mm <sup>2</sup> - 50 mm <sup>2</sup>
Terminal protection	Finger and hand touch safe, DGUV VS3, EN 50274
Design verification as per IEC/EN 61439 - technical data	
	40.4
Rated operational current for specified heat dissipation (In)	40 A
Heat dissipation per pole, current-dependent	0 W
Equipment heat dissipation, current-dependent	8.84 W
Static heat dissipation, non-current-dependent	0 W
Heat dissipation capacity	0 W
Ambient operating temperature - min	-25 °C
Ambient operating temperature - max	55 °C
Design verification as per IEC/EN 61439	
10.2.2 Corrosion resistance	Meets the product standard's requirements.
10.2.3.1 Verification of thermal stability of enclosures	Meets the product standard's requirements.
10.2.3.1 Verification of thermal stability of enclosures   10.2.3.2 Verification of resistance of insulating materials to normal heat	Meets the product standard's requirements. Meets the product standard's requirements.
10.2.3.2 Verification of resistance of insulating materials to normal heat	Meets the product standard's requirements.
10.2.3.2 Verification of resistance of insulating materials to normal heat 10.2.3.3 Resist. of insul. mat. to abnormal heat/fire by internal elect. effects	Meets the product standard's requirements. Meets the product standard's requirements.
10.2.3.2 Verification of resistance of insulating materials to normal heat 10.2.3.3 Resist. of insul. mat. to abnormal heat/fire by internal elect. effects   10.2.4 Resistance to ultra-violet (UV) radiation 10.2.4 Resistance to ultra-violet (UV)	Meets the product standard's requirements. Meets the product standard's requirements. Meets the product standard's requirements.
10.2.3.2 Verification of resistance of insulating materials to normal heat   10.2.3.3 Resist. of insul. mat. to abnormal heat/fire by internal elect. effects   10.2.4 Resistance to ultra-violet (UV) radiation   10.2.5 Lifting	Meets the product standard's requirements.   Meets the product standard's requirements.   Meets the product standard's requirements.   Does not apply, since the entire switchgear needs to be evaluated.
10.2.3.2 Verification of resistance of insulating materials to normal heat10.2.3.3 Resist. of insul. mat. to abnormal heat/fire by internal elect. effects10.2.4 Resistance to ultra-violet (UV) radiation10.2.5 Lifting10.2.6 Mechanical impact	Meets the product standard's requirements.   Meets the product standard's requirements.   Meets the product standard's requirements.   Does not apply, since the entire switchgear needs to be evaluated.   Does not apply, since the entire switchgear needs to be evaluated.
10.2.3.2 Verification of resistance of insulating materials to normal heat10.2.3.3 Resist. of insul. mat. to abnormal heat/fire by internal elect. effects10.2.4 Resistance to ultra-violet (UV) radiation10.2.5 Lifting10.2.6 Mechanical impact10.2.7 Inscriptions	Meets the product standard's requirements.   Meets the product standard's requirements.   Meets the product standard's requirements.   Does not apply, since the entire switchgear needs to be evaluated.   Does not apply, since the entire switchgear needs to be evaluated.   Meets the product standard's requirements.
10.2.3.2 Verification of resistance of insulating materials to normal heat10.2.3.3 Resist. of insul. mat. to abnormal heat/fire by internal elect. effects10.2.4 Resistance to ultra-violet (UV) radiation10.2.5 Lifting10.2.6 Mechanical impact10.2.7 Inscriptions10.3 Degree of protection of assemblies	Meets the product standard's requirements.   Meets the product standard's requirements.   Meets the product standard's requirements.   Does not apply, since the entire switchgear needs to be evaluated.   Does not apply, since the entire switchgear needs to be evaluated.   Meets the product standard's requirements.   Does not apply, since the entire switchgear needs to be evaluated.   Meets the product standard's requirements.   Does not apply, since the entire switchgear needs to be evaluated.
10.2.3.2 Verification of resistance of insulating materials to normal heat10.2.3.3 Resist. of insul. mat. to abnormal heat/fire by internal elect. effects10.2.4 Resistance to ultra-violet (UV) radiation10.2.5 Lifting10.2.6 Mechanical impact10.2.7 Inscriptions10.3 Degree of protection of assemblies10.4 Clearances and creepage distances	Meets the product standard's requirements.   Meets the product standard's requirements.   Meets the product standard's requirements.   Does not apply, since the entire switchgear needs to be evaluated.   Does not apply, since the entire switchgear needs to be evaluated.   Meets the product standard's requirements.   Does not apply, since the entire switchgear needs to be evaluated.   Meets the product standard's requirements.   Does not apply, since the entire switchgear needs to be evaluated.   Meets the product standard's requirements.   Does not apply, since the entire switchgear needs to be evaluated.   Meets the product standard's requirements.
10.2.3.2 Verification of resistance of insulating materials to normal heat10.2.3.3 Resist. of insul. mat. to abnormal heat/fire by internal elect. effects10.2.4 Resistance to ultra-violet (UV) radiation10.2.5 Lifting10.2.6 Mechanical impact10.2.7 Inscriptions10.3 Degree of protection of assemblies10.4 Clearances and creepage distances10.5 Protection against electric shock	Meets the product standard's requirements.   Meets the product standard's requirements.   Meets the product standard's requirements.   Does not apply, since the entire switchgear needs to be evaluated.   Does not apply, since the entire switchgear needs to be evaluated.   Meets the product standard's requirements.   Does not apply, since the entire switchgear needs to be evaluated.   Meets the product standard's requirements.   Does not apply, since the entire switchgear needs to be evaluated.   Meets the product standard's requirements.   Does not apply, since the entire switchgear needs to be evaluated.   Meets the product standard's requirements.   Does not apply, since the entire switchgear needs to be evaluated.
10.2.3.2 Verification of resistance of insulating materials to normal heat10.2.3.3 Resist. of insul. mat. to abnormal heat/fire by internal elect. effects10.2.4 Resistance to ultra-violet (UV) radiation10.2.5 Lifting10.2.6 Mechanical impact10.2.7 Inscriptions10.3 Degree of protection of assemblies10.4 Clearances and creepage distances10.5 Protection against electric shock10.6 Incorporation of switching devices and components	Meets the product standard's requirements.Meets the product standard's requirements.Meets the product standard's requirements.Does not apply, since the entire switchgear needs to be evaluated.Does not apply, since the entire switchgear needs to be evaluated.Meets the product standard's requirements.Does not apply, since the entire switchgear needs to be evaluated.Meets the product standard's requirements.Does not apply, since the entire switchgear needs to be evaluated.Meets the product standard's requirements.Does not apply, since the entire switchgear needs to be evaluated.Meets the product standard's requirements.Does not apply, since the entire switchgear needs to be evaluated.Does not apply, since the entire switchgear needs to be evaluated.Does not apply, since the entire switchgear needs to be evaluated.
10.2.3.2 Verification of resistance of insulating materials to normal heat10.2.3.3 Resist. of insul. mat. to abnormal heat/fire by internal elect. effects10.2.4 Resistance to ultra-violet (UV) radiation10.2.5 Lifting10.2.6 Mechanical impact10.2.7 Inscriptions10.3 Degree of protection of assemblies10.4 Clearances and creepage distances10.5 Protection against electric shock10.6 Incorporation of switching devices and components10.7 Internal electrical circuits and connections	Meets the product standard's requirements.Meets the product standard's requirements.Meets the product standard's requirements.Does not apply, since the entire switchgear needs to be evaluated.Does not apply, since the entire switchgear needs to be evaluated.Meets the product standard's requirements.Does not apply, since the entire switchgear needs to be evaluated.Meets the product standard's requirements.Does not apply, since the entire switchgear needs to be evaluated.Meets the product standard's requirements.Does not apply, since the entire switchgear needs to be evaluated.Does not apply, since the entire switchgear needs to be evaluated.Does not apply, since the entire switchgear needs to be evaluated.Is the panel builder's responsibility.
10.2.3.2 Verification of resistance of insulating materials to normal heat10.2.3.3 Resist. of insul. mat. to abnormal heat/fire by internal elect. effects10.2.4 Resistance to ultra-violet (UV) radiation10.2.5 Lifting10.2.6 Mechanical impact10.2.7 Inscriptions10.3 Degree of protection of assemblies10.4 Clearances and creepage distances10.5 Protection against electric shock10.6 Incorporation of switching devices and components10.7 Internal electrical circuits and connections10.8 Connections for external conductors	Meets the product standard's requirements.Meets the product standard's requirements.Meets the product standard's requirements.Does not apply, since the entire switchgear needs to be evaluated.Does not apply, since the entire switchgear needs to be evaluated.Meets the product standard's requirements.Does not apply, since the entire switchgear needs to be evaluated.Meets the product standard's requirements.Does not apply, since the entire switchgear needs to be evaluated.Meets the product standard's requirements.Does not apply, since the entire switchgear needs to be evaluated.Does not apply, since the entire switchgear needs to be evaluated.Does not apply, since the entire switchgear needs to be evaluated.Is the panel builder's responsibility.Is the panel builder's responsibility.
10.2.3.2 Verification of resistance of insulating materials to normal heat10.2.3.2 Nerification of resistance of insulating materials to normal heat10.2.3.3 Resist. of insul. mat. to abnormal heat/fire by internal elect. effects10.2.4 Resistance to ultra-violet (UV) radiation10.2.5 Lifting10.2.6 Mechanical impact10.2.7 Inscriptions10.3 Degree of protection of assemblies10.4 Clearances and creepage distances10.5 Protection against electric shock10.6 Incorporation of switching devices and components10.7 Internal electrical circuits and connections10.8 Connections for external conductors10.9.2 Power-frequency electric strength	Meets the product standard's requirements.Meets the product standard's requirements.Meets the product standard's requirements.Does not apply, since the entire switchgear needs to be evaluated.Does not apply, since the entire switchgear needs to be evaluated.Meets the product standard's requirements.Does not apply, since the entire switchgear needs to be evaluated.Meets the product standard's requirements.Does not apply, since the entire switchgear needs to be evaluated.Meets the product standard's requirements.Does not apply, since the entire switchgear needs to be evaluated.Does not apply, since the entire switchgear needs to be evaluated.Is the panel builder's responsibility.Is the panel builder's responsibility.Is the panel builder's responsibility.Is the panel builder's responsibility.
10.2.3.2 Verification of resistance of insulating materials to normal heat10.2.3.3 Resist. of insul. mat. to abnormal heat/fire by internal elect. effects10.2.4 Resistance to ultra-violet (UV) radiation10.2.5 Lifting10.2.6 Mechanical impact10.2.7 Inscriptions10.3 Degree of protection of assemblies10.4 Clearances and creepage distances10.5 Protection against electric shock10.7 Internal electrical circuits and connections10.7 Internal electrical circuits and connections10.8 Connections for external conductors10.9.2 Power-frequency electric strength10.9.3 Impulse withstand voltage	Meets the product standard's requirements.Meets the product standard's requirements.Meets the product standard's requirements.Does not apply, since the entire switchgear needs to be evaluated.Does not apply, since the entire switchgear needs to be evaluated.Meets the product standard's requirements.Does not apply, since the entire switchgear needs to be evaluated.Meets the product standard's requirements.Does not apply, since the entire switchgear needs to be evaluated.Meets the product standard's requirements.Does not apply, since the entire switchgear needs to be evaluated.Does not apply, since the entire switchgear needs to be evaluated.Does not apply, since the entire switchgear needs to be evaluated.Is the panel builder's responsibility.Is the panel build
10.2.3.2 Verification of resistance of insulating materials to normal heat10.2.3.2 Nerification of resistance of insulating materials to normal heat10.2.3.3 Resist. of insul. mat. to abnormal heat/fire by internal elect. effects10.2.4 Resistance to ultra-violet (UV) radiation10.2.5 Lifting10.2.6 Mechanical impact10.2.7 Inscriptions10.3 Degree of protection of assemblies10.4 Clearances and creepage distances10.5 Protection against electric shock10.7 Internal electrical circuits and connections10.8 Connections for external conductors10.9.2 Power-frequency electric strength10.9.3 Impulse withstand voltage10.9.4 Testing of enclosures made of insulating material	Meets the product standard's requirements.Meets the product standard's requirements.Meets the product standard's requirements.Does not apply, since the entire switchgear needs to be evaluated.Does not apply, since the entire switchgear needs to be evaluated.Meets the product standard's requirements.Does not apply, since the entire switchgear needs to be evaluated.Meets the product standard's requirements.Does not apply, since the entire switchgear needs to be evaluated.Meets the product standard's requirements.Does not apply, since the entire switchgear needs to be evaluated.Does not apply, since the entire switchgear needs to be evaluated.Does not apply, since the entire switchgear needs to be evaluated.Is the panel builder's responsibility.Is the panel builder is responsibility.The panel builder is responsibile for the temperature rise calculation. Eaton will
10.2.3.2 Verification of resistance of insulating materials to normal heat10.2.3.3 Resist. of insul. mat. to abnormal heat/fire by internal elect. effects10.2.4 Resistance to ultra-violet (UV) radiation10.2.5 Lifting10.2.6 Mechanical impact10.2.7 Inscriptions10.3 Degree of protection of assemblies10.4 Clearances and creepage distances10.5 Protection against electric shock10.7 Internal electrical circuits and connections10.8 Connections for external conductors10.9.2 Power-frequency electric strength10.9.3 Impulse withstand voltage10.9.4 Testing of enclosures made of insulating material10.10 Temperature rise	Meets the product standard's requirements.Meets the product standard's requirements.Meets the product standard's requirements.Does not apply, since the entire switchgear needs to be evaluated.Does not apply, since the entire switchgear needs to be evaluated.Meets the product standard's requirements.Does not apply, since the entire switchgear needs to be evaluated.Meets the product standard's requirements.Does not apply, since the entire switchgear needs to be evaluated.Meets the product standard's requirements.Does not apply, since the entire switchgear needs to be evaluated.Meets the product standard's requirements.Does not apply, since the entire switchgear needs to be evaluated.Is the panel builder's responsibility.Is the panel builder's responsibility.The panel builder is responsibility.Is the panel builder's responsibility.Is the panel builder is responsibility.Is the panel builder is responsibility.The panel builder is responsibility.Is the panel builder is responsibili
10.2.3.2 Verification of resistance of insulating materials to normal heat10.2.3.3 Resist. of insul. mat. to abnormal heat/fire by internal elect. effects10.2.4 Resistance to ultra-violet (UV) radiation10.2.5 Lifting10.2.6 Mechanical impact10.2.7 Inscriptions10.3 Degree of protection of assemblies10.4 Clearances and creepage distances10.5 Protection against electric shock10.6 Incorporation of switching devices and components10.7 Internal electrical circuits and connections10.8 Connections for external conductors10.9.2 Power-frequency electric strength10.9.3 Impulse withstand voltage10.9.4 Testing of enclosures made of insulating material10.11 Short-circuit rating	Meets the product standard's requirements.Meets the product standard's requirements.Meets the product standard's requirements.Does not apply, since the entire switchgear needs to be evaluated.Does not apply, since the entire switchgear needs to be evaluated.Meets the product standard's requirements.Does not apply, since the entire switchgear needs to be evaluated.Meets the product standard's requirements.Does not apply, since the entire switchgear needs to be evaluated.Meets the product standard's requirements.Does not apply, since the entire switchgear needs to be evaluated.Meets the product standard's requirements.Does not apply, since the entire switchgear needs to be evaluated.Is the panel builder's responsibility.Is the panel builder's responsibility.
10.2.3.2 Verification of resistance of insulating materials to normal heat10.2.3.3 Resist. of insul. mat. to abnormal heat/fire by internal elect. effects10.2.4 Resistance to ultra-violet (UV) radiation10.2.5 Lifting10.2.6 Mechanical impact10.2.7 Inscriptions10.3 Degree of protection of assemblies10.4 Clearances and creepage distances10.5 Protection against electric shock10.6 Incorporation of switching devices and components10.7 Internal electrical circuits and connections10.8 Connections for external conductors10.9.4 Testing of enclosures made of insulating material10.10 Temperature rise10.11 Short-circuit rating10.12 Electromagnetic compatibility	Meets the product standard's requirements.Meets the product standard's requirements.Meets the product standard's requirements.Does not apply, since the entire switchgear needs to be evaluated.Does not apply, since the entire switchgear needs to be evaluated.Meets the product standard's requirements.Does not apply, since the entire switchgear needs to be evaluated.Meets the product standard's requirements.Does not apply, since the entire switchgear needs to be evaluated.Meets the product standard's requirements.Does not apply, since the entire switchgear needs to be evaluated.Does not apply, since the entire switchgear needs to be evaluated.Does not apply, since the entire switchgear needs to be evaluated.Is the panel builder's responsibility.Is the panel builder's responsibility.Is the panel builder's responsibility.Is the panel builder's responsibility.Is the panel builder is responsibility.Is the panel builder's responsibility.Is the pane
10.2.3.2 Verification of resistance of insulating materials to normal heat10.2.3.3 Resist. of insul. mat. to abnormal heat/fire by internal elect. effects10.2.4 Resistance to ultra-violet (UV) radiation10.2.5 Lifting10.2.6 Mechanical impact10.2.7 Inscriptions10.3 Degree of protection of assemblies10.4 Clearances and creepage distances10.5 Protection against electric shock10.6 Incorporation of switching devices and components10.7 Internal electrical circuits and connections10.8 Connections for external conductors10.9.2 Power-frequency electric strength10.9.3 Impulse withstand voltage10.10 Temperature rise10.11 Short-circuit rating10.12 Electromagnetic compatibility10.13 Mechanical function	Meets the product standard's requirements.Meets the product standard's requirements.Meets the product standard's requirements.Does not apply, since the entire switchgear needs to be evaluated.Does not apply, since the entire switchgear needs to be evaluated.Meets the product standard's requirements.Does not apply, since the entire switchgear needs to be evaluated.Meets the product standard's requirements.Does not apply, since the entire switchgear needs to be evaluated.Meets the product standard's requirements.Does not apply, since the entire switchgear needs to be evaluated.Does not apply, since the entire switchgear needs to be evaluated.Does not apply, since the entire switchgear needs to be evaluated.Is the panel builder's responsibility.Is the panel builder's responsibility.Is the panel builder's responsibility.Is the panel builder's responsibility.Is the panel builder is responsibility.Is the panel builder's responsibility.Is the pane
10.2.3.2 Verification of resistance of insulating materials to normal heat10.2.3.3 Resist. of insul. mat. to abnormal heat/fire by internal elect. effects10.2.4 Resistance to ultra-violet (UV) radiation10.2.5 Lifting10.2.6 Mechanical impact10.2.7 Inscriptions10.3 Degree of protection of assemblies10.4 Clearances and creepage distances10.5 Protection against electric shock10.7 Internal electrical circuits and connections10.8 Connections for external conductors10.9.2 Power-frequency electric strength10.9.3 Impulse withstand voltage10.11 Short-circuit rating10.12 Electromagnetic compatibility10.13 Mechanical functionAdditional information	Meets the product standard's requirements.Meets the product standard's requirements.Meets the product standard's requirements.Does not apply, since the entire switchgear needs to be evaluated.Does not apply, since the entire switchgear needs to be evaluated.Meets the product standard's requirements.Does not apply, since the entire switchgear needs to be evaluated.Meets the product standard's requirements.Does not apply, since the entire switchgear needs to be evaluated.Meets the product standard's requirements.Does not apply, since the entire switchgear needs to be evaluated.Is the panel builder's responsibility.Is the panel builder's responsibility. The specifications for the switchgear must be observed.Is the panel builder's responsibility. The specifications for the switchgear must be observed.Is the panel builder's responsibility. The specifications for the switchgear must be observed.The device meets the requirements, provided the information in the instruction leaflet (IL) is observed.
10.2.3.2 Verification of resistance of insulating materials to normal heat10.2.3.3 Resist. of insul. mat. to abnormal heat/fire by internal elect. effects10.2.4 Resistance to ultra-violet (UV) radiation10.2.5 Lifting10.2.6 Mechanical impact10.2.7 Inscriptions10.3 Degree of protection of assemblies10.4 Clearances and creepage distances10.5 Protection against electric shock10.6 Incorporation of switching devices and components10.7 Internal electrical circuits and connections10.8 Connections for external conductors10.9.2 Power-frequency electric strength10.9.1 Therparature rise10.11 Short-circuit rating10.12 Electromagnetic compatibility10.13 Mechanical functionAdditional informationCurrent limiting class	Meets the product standard's requirements.   Meets the product standard's requirements.   Meets the product standard's requirements.   Does not apply, since the entire switchgear needs to be evaluated.   Meets the product standard's requirements.   Does not apply, since the entire switchgear needs to be evaluated.   Meets the product standard's requirements.   Does not apply, since the entire switchgear needs to be evaluated.   Meets the product standard's requirements.   Does not apply, since the entire switchgear needs to be evaluated.   Meets the product standard's requirements.   Does not apply, since the entire switchgear needs to be evaluated.   Is the panel builder's responsibility.   Is the panel builder's responsibility.   Is the panel builder's responsibility.   Is the panel builder 's responsibility.   Is the panel builder 's responsibility.   Is the panel builder 's responsibility.   The panel builder 's responsibility. The specifications for the switchgear must be observed.   Is the panel builder 's responsibility. The specifications for the switchgear must be observed.   Is the panel builder 's responsibility. The specifications for the switchgear must be observed.   Is the panel builder 's responsibility. The specifications for the switchgear must be observed.   The device me

## **Technical data ETIM 9.0**

Circuit breakers and fuses (EG000020) / Miniature circuit breaker (MCB) (EC000042)

Electric engineering, automation, process control engineering / Electrical installation, device / Miniature circuit breaker system (MCB) / Miniature circuit breaker (MCB) (ecl@ss13-27-14-19-01 [AAB905019])

[AAD303013])		
Built-in depth	mm	75
Release characteristic		C
Number of poles (total)		2
Number of protected poles		2
Rated current	А	40
Rated voltage	V	400
Rated insulation voltage Ui	V	440
Rated impulse withstand voltage Uimp	kV	4
Rated short-circuit breaking capacity Icn according to EN 60898 at 230 V	kA	0
Voltage type		AC
Rated short-circuit breaking capacity Icn according to EN 60898 at 400 V	kA	0
Rated short-circuit breaking capacity Icu according to IEC 60947-2 at 230 V	kA	25
Rated short-circuit breaking capacity Icu according to IEC 60947-2 at 400 V	kA	25
Frequency	Hz	50 - 60
Power loss	W	
Current limiting class		3
Flush-mounted installation		No
Concurrently switching neutral conductor		No
Over voltage category		3
Pollution degree		2
Additional equipment possible		Yes
Width in number of modular spacings		3
Degree of protection (IP)		IP20
Ambient temperature during operating	°C	-25 - 55
Connectable conductor cross section multi-wired	mm²	2.5 - 50
Connectable conductor cross section solid-core	mm²	2.5 - 50
Explosion-proof		No