DATASHEET - NZM4-XR220-250DC



Remote operator, 220-250VAC, for size 4

Part no. NZM4-XR220-250DC Catalog No. 266694



Similar to illustration

| Dal | livor | nro | gram |
|-----|--------|-------|------|
| DC | IIVEIY | , pro | yram |

| Delivery program Product range | | | Accessories |
|--------------------------------|----------------|----|--|
| Product range | | | |
| Accessories | | | Remote operator, can be synchronized |
| Rated operating frequency | | | DC |
| Standard/Approval | | | UL/CSA, IEC |
| Construction size | | | NZM4 |
| Description | | | For remote switching of circuit-breakers and switch-disconnectors. |
| | | | ON and OFF switching and resetting by means of two-wire or three-wire control. |
| | | | Local switching by hand possible. |
| | | | Lockable in the 0 position of the remote operator with up to 3 padlocks (hasp thickness: $4-8$ mm) |
| | | | Can be synchronized |
| | | | Three-wire control Control Cont |
| | | | Terminal 75: NZM-XR: Operational readiness signal when cover closed and not locked. NZM2-XRD: Operational readiness signal when sliding switch set to Auto. Sliding switch with three positions: Manual/Auto/Locked for reliable differentiation of connected positions. AC-15: 400 V; 2 A DC-13: 220 V; 0.2 A |
| | | | Three-wire control with automatic reset to the 0 position after the switch has tripped |
| | | | Switching cycle: NZM2-XR |
| Closing delay | | ms | 100 |
| Break time | | ms | 3000 |
| Rated control voltage | U _s | V | 220 - 250 V DC |
| Number of poles | Ŭ | | 3/4 pole |
| Trained of police | | | o, . po.o |

| For use with | NZM4(-4) N(S)4(-4) |
|---|--|
| Project planning information | Cannot be combined with switch-disconnector PN Do not install M22-CK11(20/02) dual auxiliary contacts in the right-hand side auxiliary contact slot in NZM4-XR |
| Engineering information (sheet catalog) | 2/3-wire control and circuit diagrams |

Technical data

Remote operator

| Rated control voltage | U_s | V | |
|---|----------------|---------------|------------|
| DC | U _s | V DC | 220 - 250 |
| Operating range | | | |
| AC | | $x U_s$ | 0.85 - 1.1 |
| DC | | $x U_s$ | 0.85 - 1.1 |
| Motor rating | | | |
| DC | | | |
| 24 V 30 V DC | P | W | 250 |
| Minimum signal duration | | | |
| with switch on | | ms | 30 |
| with switch off | | ms | 500 |
| Lifespan, mechanical | Operations | | 10000 |
| Maximum operating frequency | | Ops./h | |
| Max. operating frequency | | Ops/h | 20 |
| Terminal capacities | | mm^2 | |
| Solid or flexible conductor, with ferrule | | mm^2 | 0,75 - 2,5 |
| | | AWG | 18 14 |

Design verification as per IEC/EN 61439

| Design verification as per IEC/EN 61439 | |
|--|--|
| IEC/EN 61439 design verification | |
| 10.2 Strength of materials and parts | |
| 10.2.2 Corrosion resistance | Meets the product standard's requirements. |
| 10.2.3.1 Verification of thermal stability of enclosures | Meets the product standard's requirements. |
| 10.2.3.2 Verification of resistance of insulating materials to normal heat | Meets the product standard's requirements. |
| 10.2.3.3 Verification of resistance of insulating materials to abnormal heat and fire due to internal electric effects | Meets the product standard's requirements. |
| 10.2.4 Resistance to ultra-violet (UV) radiation | Meets the product standard's requirements. |
| 10.2.5 Lifting | Does not apply, since the entire switchgear needs to be evaluated. |
| 10.2.6 Mechanical impact | Does not apply, since the entire switchgear needs to be evaluated. |
| 10.2.7 Inscriptions | Meets the product standard's requirements. |
| 10.3 Degree of protection of ASSEMBLIES | Does not apply, since the entire switchgear needs to be evaluated. |
| 10.4 Clearances and creepage distances | Meets the product standard's requirements. |
| 10.5 Protection against electric shock | Does not apply, since the entire switchgear needs to be evaluated. |
| 10.6 Incorporation of switching devices and components | Does not apply, since the entire switchgear needs to be evaluated. |
| 10.7 Internal electrical circuits and connections | Is the panel builder's responsibility. |
| 10.8 Connections for external conductors | Is the panel builder's responsibility. |
| 10.9 Insulation properties | |
| 10.9.2 Power-frequency electric strength | Is the panel builder's responsibility. |
| 10.9.3 Impulse withstand voltage | Is the panel builder's responsibility. |
| 10.9.4 Testing of enclosures made of insulating material | Is the panel builder's responsibility. |
| 10.10 Temperature rise | The panel builder is responsible for the temperature rise calculation. Eaton will provide heat dissipation data for the devices. |
| 10.11 Short-circuit rating | Is the panel builder's responsibility. The specifications for the switchgear must b observed. |
| 10.12 Electromagnetic compatibility | Is the panel builder's responsibility. The specifications for the switchgear must b observed. |
| 10.13 Mechanical function | The device meets the requirements, provided the information in the instruction leaflet (IL) is observed. |

Technical data ETIM 7.0

Low-voltage industrial components (EG000017) / Motor operator for power circuit-breaker (EC001030)


Electric engineering, automation, process control engineering / Low-voltage switch technology / Circuit breaker (LV < 1 kV) / Electrical drive for circuit breakers (ecl@ss10.0.1-27-37-04-12 [AKF010013])

| p in a root off | | |
|--|---|-------------|
| Type of switch drive | | Motor drive |
| Rated control supply voltage Us at AC 50HZ | V | 0 - 0 |
| Rated control supply voltage Us at AC 60HZ | V | 0 - 0 |
| Rated control supply voltage Us at DC | V | 220 - 250 |
| Voltage type for actuating | | DC |

Approvals

| Product Standards | UL489; CSA-C22.2 No. 5-09; IEC60947, CE marking |
|-----------------------------|---|
| UL File No. | E140305 |
| UL Category Control No. | DIHS |
| CSA File No. | 022086 |
| CSA Class No. | 1437-01 |
| North America Certification | UL listed, CSA certified |

Dimensions



Additional product information (links)

| IL01210006Z (AWA1230-2038) NZM4 Remote operator | |
|---|---|
| IL01210006Z (AWA1230-2038) NZM4 Remote operator | ftp://ftp.moeller.net/DOCUMENTATION/AWA_INSTRUCTIONS/IL01210006Z2019_05.pdf |
| 2/3-wire control and circuit diagrams | http://ecat.moeller.net/flip-cat/?edition=HPLEN&startpage=17.153 |