DATASHEET - +NZM3-XKRU

Connection, on rear, bottom 3p, size 3

Part no.

+NZM3-XKRU 266791



General specifications		
Product name	Eato	on Moeller series NZM connection type
Part no.	+NZ	ZM3-XKRU
EAN	4015	5082667917
Product Length/Depth	160	millimetre
Product height	45 n	nillimetre
Product width	65 n	nillimetre
Product weight	0.83	32 kilogram
Compliances	IEC	CSA IS conform
Product Tradename	NZM	Ν
Product Type	Acc	cessories
Product Sub Type	Con	nnection type
Delivery program		
Туре	Acc	cessory Connection on rear Terminal
Number of poles	Thre	ee-pole
Amperage Rating	630	A (Cu), 500 A (AI)
Frame	NZM	M3
Suitable for	Thre	oper cable lugs ee-pole minum cable lug
Used with	NZM	M3, PN3, N3
Technical Data - Mechanical		
Mounting position	Fitte	ed at the bottom
Technical Data - Mechanical - Terminals		
Terminal capacity (stranded cable)		nm² - 240 mm² (2x) nm² - 240 mm² (1x)
Terminal capacity (copper busbar)		x. 30 mm x 10 mm + 30 mm x 5 mm n. 20 mm x 5 mm
Terminal capacity (copper strip)		egments of 16 mm x 0.8 mm - 10 segments of 32 mm x 1 mm + 5 segments of 32 x 1 mm
Design verification as per IEC/EN 61439		
10.2.2 Corrosion resistance	Mee	ets the product standard's requirements.
10.2.3.1 Verification of thermal stability of enclosures	Mee	ets the product standard's requirements.
10.2.3.2 Verification of resistance of insulating materials to normal heat	Mee	ets the product standard's requirements.
10.2.3.3 Resist. of insul. mat. to abnormal heat/fire by internal elect. effects	Mee	ets the product standard's requirements.
10.2.4 Resistance to ultra-violet (UV) radiation	Mee	ets the product standard's requirements.
10.2.5 Lifting	Doe	es not apply, since the entire switchgear needs to be evaluated.
10.2.6 Mechanical impact	Doe	es not apply, since the entire switchgear needs to be evaluated.
10.2.7 Inscriptions	Mee	ets the product standard's requirements.
10.3 Degree of protection of assemblies	Doe	es not apply, since the entire switchgear needs to be evaluated.
10.4 Clearances and creepage distances	Mee	ets the product standard's requirements.
10.5 Protection against electric shock	Doe	es not apply, since the entire switchgear needs to be evaluated.
10.6 Incorporation of switching devices and components	Doe	es not apply, since the entire switchgear needs to be evaluated.
10.7 Internal electrical circuits and connections	Is th	he panel builder's responsibility.
10.8 Connections for external conductors	Is th	he panel builder's responsibility.
10.9.2 Power-frequency electric strength	Is th	he panel builder's responsibility.
10.9.3 Impulse withstand voltage	Is th	he panel builder's responsibility.
10.9.4 Testing of enclosures made of insulating material	Is th	he panel builder's responsibility.

10.10 Temperature rise	The panel builder is responsible for the temperature rise calculation. Eaton will provide heat dissipation data for the devices.		
10.11 Short-circuit rating	Is the panel builder's responsibility. The specifications for the switchgear must be observed.		
10.12 Electromagnetic compatibility	Is the panel builder's responsibility. The specifications for the switchgear must be observed.		
10.13 Mechanical function	The device meets the requirements, provided the information in the instruction leaflet (IL) is observed.		
Additional information			
Model	Other		
Technical data ETIM 9.0			
Low-voltage industrial components (EG000017) / Wiring set for power circuit breaker (EC002050)			

Electric engineering, automation, process control engineering / Low-voltage switch technology / Circuit breaker (LV < 1 kV) / Wiring set for circuit breaker (ecl@ss13-27-37-04-24 [ACN957016])

3

Other

Suitable for number of poles

Model