DATASHEET - M22-I3M-SAL



Surface mounting enclosure, metal, 3 mounting locations

Powering Business Worldwide*

Part no. M22-I3M-SAL Catalog No. 118461 Alternate Catalog M22-I3M-SALQ

No

Delivery program

| Basic function accessories | | Surface mounting enclosure |
|----------------------------|-----|---|
| Housing | | Metal |
| | | With high-grade steel screws |
| Number of locations | Ωty | 3 |
| Cable entry knockouts | | |
| Cable entry | | - |
| Degree of Protection | | IP66, IP67, IP69 |
| Connection to SmartWire-DT | | no |
| For use with | | 3 x Ø 22.5 |
| For use with | | (Illuminated) pushbuttons (Illuminated) selector switches Key-operated pushbuttons Indicator light controlled stop/emergency-stop buttons with yellow label |

Technical data General

Degree of Protection IP66, IP67, IP69

Design verification as per IEC/EN 61439

| Jesign verification as per IEG/EN 61439 | |
|--|--|
| EC/EN 61439 design verification | |
| 10.2 Strength of materials and parts | |
| 10.2.2 Corrosion resistance | Meets the product standard's requirements. |
| 10.2.3.1 Verification of thermal stability of enclosures | Meets the product standard's requirements. |
| 10.2.3.2 Verification of resistance of insulating materials to normal heat | Meets the product standard's requirements. |
| 10.2.3.3 Verification of resistance of insulating materials to abnormal heat and fire due to internal electric effects | Meets the product standard's requirements. |
| 10.2.4 Resistance to ultra-violet (UV) radiation | Please enquire |
| 10.2.5 Lifting | Does not apply, since the entire switchgear needs to be evaluated. |
| 10.2.6 Mechanical impact | Does not apply, since the entire switchgear needs to be evaluated. |
| 10.2.7 Inscriptions | Meets the product standard's requirements. |
| 10.3 Degree of protection of ASSEMBLIES | Does not apply, since the entire switchgear needs to be evaluated. |
| 10.4 Clearances and creepage distances | Meets the product standard's requirements. |
| 10.5 Protection against electric shock | Does not apply, since the entire switchgear needs to be evaluated. |
| 10.6 Incorporation of switching devices and components | Does not apply, since the entire switchgear needs to be evaluated. |
| 10.7 Internal electrical circuits and connections | Is the panel builder's responsibility. |
| 10.8 Connections for external conductors | Is the panel builder's responsibility. |
| 10.9 Insulation properties | |
| 10.9.2 Power-frequency electric strength | Is the panel builder's responsibility. |
| 10.9.3 Impulse withstand voltage | Is the panel builder's responsibility. |
| 10.9.4 Testing of enclosures made of insulating material | Is the panel builder's responsibility. |
| 10.10 Temperature rise | The panel builder is responsible for the temperature rise calculation. Eaton will provide heat dissipation data for the devices. |
| 10.11 Short-circuit rating | Is the panel builder's responsibility. The specifications for the switchgear must observed. |
| 10.12 Electromagnetic compatibility | Is the panel builder's responsibility. The specifications for the switchgear must observed. |
| 10.13 Mechanical function | The device meets the requirements, provided the information in the instruction leaflet (IL) is observed. |
| | |

Technical data ETIM 7.0

Depth

Low-voltage industrial components (EG000017) / Enclosure for control circuit devices (EC000200) Electric engineering, automation, process control engineering / Low-voltage switch technology / Command and alarm device / Housing for command and alarm devices (ecl@ss10.0.1-27-37-12-05 [AKF023014]) Number of command positions Construction type housing Surface mounting housing Material housing Aluminium Other Material quality housing 22.5 Diameter openings mm Grey Colour housing cover IP67/IP69K Degree of protection (IP) Degree of protection (NEMA) 4X Width mm 67 Height mm 84

180

mm