## **DATASHEET - NZM2-4-XKP**



Phase isolator, 4p, size 2

Part no. Catalog No. NZM2-4-XKP 119865



## Delivery program Number of conductors 4 pole Accessories Phase isolators For use with VZM2-4, PN2-4, N(S)2-4 Notes VZM2-4, PN2-4, N(S)2-4

Model contains parts for one switch side including insulating plate for mounting plate at top or bottom for 3- or 4-pole switch.

Can not be combined with connection on rear NZM1/2(-4)-XKR.

Insulation protection up to rated operational voltage Ue of 415 V AC if minimum clearances are not maintained.

## **Design verification as per IEC/EN 61439**

| IEC/EN 61439 design verification   |  |
|--|--|
| 10.2 Strength of materials and parts   |  |
| 10.2.2 Corrosion resistance  | Meets the product standard's requirements.   |
| 10.2.3.1 Verification of thermal stability of enclosures   | Meets the product standard's requirements.   |
| 10.2.3.2 Verification of resistance of insulating materials to normal heat   | Meets the product standard's requirements.   |
| 10.2.3.3 Verification of resistance of insulating materials to abnormal heat and fire due to internal electric effects | Meets the product standard's requirements.   |
| 10.2.4 Resistance to ultra-violet (UV) radiation   | Meets the product standard's requirements.   |
| 10.2.5 Lifting   | Does not apply, since the entire switchgear needs to be evaluated.   |
| 10.2.6 Mechanical impact   | Does not apply, since the entire switchgear needs to be evaluated.   |
| 10.2.7 Inscriptions  | Meets the product standard's requirements.   |
| 10.3 Degree of protection of ASSEMBLIES  | Does not apply, since the entire switchgear needs to be evaluated.   |
| 10.4 Clearances and creepage distances   | Meets the product standard's requirements.   |
| 10.5 Protection against electric shock   | Does not apply, since the entire switchgear needs to be evaluated.   |
| 10.6 Incorporation of switching devices and components   | Does not apply, since the entire switchgear needs to be evaluated.   |
| 10.7 Internal electrical circuits and connections  | Is the panel builder's responsibility.   |
| 10.8 Connections for external conductors   | Is the panel builder's responsibility.   |
| 10.9 Insulation properties   |  |
| 10.9.2 Power-frequency electric strength   | Is the panel builder's responsibility.   |
| 10.9.3 Impulse withstand voltage   | Is the panel builder's responsibility.   |
| 10.9.4 Testing of enclosures made of insulating material   | Is the panel builder's responsibility.   |
| 10.10 Temperature rise   | The panel builder is responsible for the temperature rise calculation. Eaton will provide heat dissipation data for the devices. |
| 10.11 Short-circuit rating   | Is the panel builder's responsibility. The specifications for the switchgear must be observed.                                   |
| 10.12 Electromagnetic compatibility  | Is the panel builder's responsibility. The specifications for the switchgear must be observed.                                   |
| 10.13 Mechanical function  | The device meets the requirements, provided the information in the instruction leaflet (IL) is observed.                         |

## **Technical data ETIM 7.0**

Low-voltage industrial components (EG000017) / Phase separation plate for power circuit breaker (EC002035)

Electric engineering, automation, process control engineering / Low-voltage switch technology / Circuit breaker (LV < 1 kV) / Phase separation plate for circuit breaker (ecl@ss10.0.1-27-37-04-25 [ACN959011])

| Model                   | Other                  |
|-------------------------|------------------------|
|                         |                        |
| Approvals               |                        |
| Product Standards       | UL489; CSA-C22.2 No. 5 |
| UL File No.             | E31593                 |
| UL Category Control No. | DIVQ, DKPU2, WJAZ      |



CSA Class No.

North America Certification

022086

1432-01, 1432-81, 4652-06

UL listed, CSA certified

