DATASHEET - QSA125N1-00/3



Fuse switch-disconnector, 3 pole, rear mounting, 125 A, NH000/NH00



QSA125N1-00/3 Part no. Catalog No. 1318030

Pelivery program Product range Part group reference Part proup Function Plotes			Fuse-switch-disconnector Main switch
top Function			maintenance switch
			QSA
lotes			optional
			Suitable for DIN fuse-links (blade contacts type)
nformation about equipment supplied			Auxiliary contact or neutral conductor fitted by user.
lumber of poles			3 pole
Auxiliary contacts			
		N/0	0
7		N/C	0
legree of Protection			IP00 IP20 with terminal cover
lesign			rear mounting
ontact sequence			L1 L2 L3 $ \begin{array}{c ccccccccccccccccccccccccccccccccccc$
ated uninterrupted current	I _u	Α	125
lote on rated uninterrupted current !u			Rated uninterrupted current $I_{\rm u}$ is specified for max. cross-section.

Technical data

General

Fuse cartridge

20110121			
Standards			IEC/EN 60947, VDE 0660, IEC/EN 60204 Switch-disconnector according to IEC/EN 60947-3
Certifications			CE, RoHs
Ambient temperature			
Operation	9	°C	-25 - +55
Storage	9	°C	-30 - +80
Overvoltage category/pollution degree			III/3
Rated impulse withstand voltage	U_{imp}	kV	6
Rated insulation voltage	Ui	V	690
Mounting position			As required
Contacts			

Size

NH000/NH00

Mechanical variables	
Number of poles	3 pole

Auxiliary contacts			
		N/0	0
		N/C	0
Electrical characteristics			
Rated operational voltage	U _e	V AC	690
Rated uninterrupted current	Iu	Α	125
Note on rated uninterrupted current $\mathbf{I}_{\mathbf{u}}$			Rated uninterrupted current $\mathbf{I}_{\mathbf{u}}$ is specified for max. cross-section.
Heat dissipation per pole, current-dependent	P _{vid}	W	9

Design verification as per IEC/EN 61439

besign vermoution as per 120/214 01405			
Technical data for design verification			
Rated operational current for specified heat dissipation	In	Α	125
Heat dissipation per pole, current-dependent	P _{vid}	W	9
Equipment heat dissipation, current-dependent	P _{vid}	W	0
Static heat dissipation, non-current-dependent	P _{vs}	W	0
Heat dissipation capacity	P _{diss}	W	0
Operating ambient temperature min.		°C	-25
Operating ambient temperature max.		°C	55
IEC/EN 61439 design verification			
10.2 Strength of materials and parts			
10.2.2 Corrosion resistance			Meets the product standard's requirements.
10.2.3.1 Verification of thermal stability of enclosures			Meets the product standard's requirements.
10.2.3.2 Verification of resistance of insulating materials to normal heat			Meets the product standard's requirements.
10.2.3.3 Verification of resistance of insulating materials to abnormal heat and fire due to internal electric effects			Meets the product standard's requirements.
10.2.4 Resistance to ultra-violet (UV) radiation			Meets the product standard's requirements.
10.2.5 Lifting			Does not apply, since the entire switchgear needs to be evaluated.
10.2.6 Mechanical impact			Does not apply, since the entire switchgear needs to be evaluated.
10.2.7 Inscriptions			Meets the product standard's requirements.
10.3 Degree of protection of ASSEMBLIES			Does not apply, since the entire switchgear needs to be evaluated.
10.4 Clearances and creepage distances			Meets the product standard's requirements.
10.5 Protection against electric shock			Does not apply, since the entire switchgear needs to be evaluated.
10.6 Incorporation of switching devices and components			Does not apply, since the entire switchgear needs to be evaluated.
10.7 Internal electrical circuits and connections			Is the panel builder's responsibility.
10.8 Connections for external conductors			Is the panel builder's responsibility.
10.9 Insulation properties			
10.9.2 Power-frequency electric strength			Is the panel builder's responsibility.
10.9.3 Impulse withstand voltage			Is the panel builder's responsibility.
10.9.4 Testing of enclosures made of insulating material			Is the panel builder's responsibility.
10.10 Temperature rise			The panel builder is responsible for the temperature rise calculation. Eaton will provide heat dissipation data for the devices.
10.11 Short-circuit rating			Is the panel builder's responsibility. The specifications for the switchgear must be observed.
10.12 Electromagnetic compatibility			Is the panel builder's responsibility. The specifications for the switch gear must be observed. $\label{eq:constraint}$
10.13 Mechanical function			The device meets the requirements, provided the information in the instruction leaflet (IL) is observed.

Technical data ETIM 7.0

Low-voltage industrial components (EG000017) / Fuse switch disconnector (EC001040)

Electric engineering, automation, process control engineering / Low-voltage switch technology / Off-load switch, circuit breaker, control switch / Fuse switch disconnector (ecl@ss10.0.1-27-37-14-01 [AKF058013])

(co.essistin 2) or the parameters		
Version as main switch		Yes
Version as safety switch		No
Max. rated operation voltage Ue AC	V	690
Rated permanent current lu	Α	125
Rated operation power at AC-23, 400 V	kW	59

kA	50
kA	0
	NH00
	3
	No
	Screw connection
	Other
	Yes
	Yes
	No
	No
	Other
	Front side
	No
	No
	No
	IP00

Dimensions

