DATASHEET - FRBMM-C16/1N/003-G



RCD/MCB combination, 16 A, 30 mA, MCB trip characteristic: C, 1p+N, RCD trip characteristic: AC



Part no. FRBMM-C16/1N/003-G Catalog No. 170625 Alternate Catalog FRBMM-C16/1N/003-G

Similar to illustration

| Delivery program | | | |
|--|----------------|----|--|
| Basic function | | | Combined RCD/MCB devices |
| Number of poles | | | 1 pole+N |
| Tripping characteristic | | | C |
| Application | | | Switchgear for industrial and advanced commercial applications |
| Rated current | In | Α | 16 |
| Rated switching capacity according to IEC/EN 61009 | | kA | 10 |
| Rated fault current | $I_{\Delta N}$ | Α | 0.03 |
| Туре | | | Type G (ÖVE E 8601) |
| Tripping | | s | Short time-delayed |
| Product range | | | FRBmM |
| Sensitivity | | | AC current sensitive |
| Impulse withstand current | | | Surge-proof, 3 kA |
| Contact sequence | | | |

Technical data

Electrical

| Protected pole | | | 1 |
|---|----------------|------|----------------------|
| Rated voltage according to IEC/EN 60947-2 | U_n | V AC | 240 |
| Rated frequency | f | Hz | 50 |
| Rated fault current | $I_{\Delta n}$ | mA | 30 |
| Sensitivity | | | AC current sensitive |
| Rated current | In | Α | 16 |
| Tripping characteristic | | | С |

Design verification as per IEC/EN 61439

| Technical data for design verification | | | |
|--|-------------------|----|--|
| Rated operational current for specified heat dissipation | In | Α | 16 |
| Heat dissipation per pole, current-dependent | P_{vid} | W | 0 |
| Equipment heat dissipation, current-dependent | P_{vid} | W | 3.6 |
| Static heat dissipation, non-current-dependent | P_{vs} | W | 0 |
| Heat dissipation capacity | P _{diss} | W | 0 |
| Operating ambient temperature min. | | °C | -25 |
| Operating ambient temperature max. | | °C | 40 |
| | | | 0 |
| IEC/EN 61439 design verification | | | |
| 10.2 Strength of materials and parts | | | |
| 10.2.2 Corrosion resistance | | | Meets the product standard's requirements. |
| 10.2.3.1 Verification of thermal stability of enclosures | | | Meets the product standard's requirements. |

| 10.2.3.2 Verification of resistance of insulating materials to normal heat | Meets the product standard's requirements. |
|--|--|
| 10.2.3.3 Verification of resistance of insulating materials to abnormal heat and fire due to internal electric effects | Meets the product standard's requirements. |
| 10.2.4 Resistance to ultra-violet (UV) radiation | Meets the product standard's requirements. |
| 10.2.5 Lifting | Does not apply, since the entire switchgear needs to be evaluated. |
| 10.2.6 Mechanical impact | Does not apply, since the entire switchgear needs to be evaluated. |
| 10.2.7 Inscriptions | Meets the product standard's requirements. |
| 10.3 Degree of protection of ASSEMBLIES | Does not apply, since the entire switchgear needs to be evaluated. |
| 10.4 Clearances and creepage distances | Meets the product standard's requirements. |
| 10.5 Protection against electric shock | Does not apply, since the entire switchgear needs to be evaluated. |
| 10.6 Incorporation of switching devices and components | Does not apply, since the entire switchgear needs to be evaluated. |
| 10.7 Internal electrical circuits and connections | Is the panel builder's responsibility. |
| 10.8 Connections for external conductors | Is the panel builder's responsibility. |
| 10.9 Insulation properties | |
| 10.9.2 Power-frequency electric strength | Is the panel builder's responsibility. |
| 10.9.3 Impulse withstand voltage | Is the panel builder's responsibility. |
| 10.9.4 Testing of enclosures made of insulating material | Is the panel builder's responsibility. |
| 10.10 Temperature rise | The panel builder is responsible for the temperature rise calculation. Eaton will provide heat dissipation data for the devices. |
| 10.11 Short-circuit rating | Is the panel builder's responsibility. The specifications for the switchgear must be observed. |
| 10.12 Electromagnetic compatibility | Is the panel builder's responsibility. The specifications for the switchgear must be observed. |
| 10.13 Mechanical function | The device meets the requirements, provided the information in the instruction leaflet (IL) is observed. |

Technical data ETIM 7.0

| Technical data ETTIVI 7.0 | | |
|--|--------------------|--|
| Circuit breakers and fuses (EG000020) / Earth leakage circuit breaker (EC000905) | | |
| Electric engineering, automation, process control engineering / Electrical installation, dev [AFZ810015]) | vice / Residual cu | rrent protection system / MCB/RCCB combination (ecl@ss10.0.1-27-14-22-07 |
| Number of poles (total) | | 2 |
| Number of protected poles | | 1 |
| Rated voltage | V | 240 |
| Rated insulation voltage Ui | V | 500 |
| Rated impulse withstand voltage Uimp | kV | 4 |
| Rated current | Α | 16 |
| Rated fault current | Α | 0.03 |
| Leakage current type | | AC |
| Current limiting class | | 3 |
| Rated short-circuit breaking capacity acc. EN 61009 | kA | 10 |
| Rated short-circuit breaking capacity IEC 60947-2 | kA | 15 |
| Rated short-circuit breaking capacity Icn acc. EN 61009-1 | kA | 10 |
| Disconnection characteristic | | Short-time delayed |
| Surge current capacity | kA | 3 |
| /oltage type | | AC |
| requency | | 50 Hz |
| Release characteristic | | С |
| Concurrently switching N-neutral | | Yes |
| Nith interlocking device | | No |
| Over voltage category | | 3 |
| Pollution degree | | 2 |
| Ambient temperature during operating | °C | -25 - 40 |
| Nidth in number of modular spacings | | 2 |
| Built-in depth | mm | 75.5 |
| Suitable for flush-mounted installation | | No |
| Anti-nuisance tripping version | | Yes |
| Degree of protection (IP) | | IP20 |
| Connectable conductor cross section solid-core | mm² | 1 - 25 |

Dimensions

