Illuminated selector switch actuator, RMQ-Titan, With thumb-grip, momentary, 3 positions, Blue, Bezel: titanium



Part no. M22-WLK3-B

216841

EL Number

4355757

(Norway)

(Norway)	
Product name	Eaton Moeller® series M22 Illuminated selector switch actuator
Part no.	M22-WLK3-B
EAN	4015082168414
Product Length/Depth	46 millimetre
Product height	30 millimetre
Product width	30 millimetre
Product weight	0.013 kilogram
Compliances	CE Marked
Certifications	EN 60947-5 IEC 60947-5 UL 508 CSA Std. C22.2 No. 14-05 CSA Std. C22.2 No. 94-91 VDE IEC/EN 60947-5 CSA-C22.2 No. 94-91 IEC/EN 60947 UL File No.: E29184 CSA File No.: 012528 CSA-C22.2 No. 14-05 VDE 0660 CE UL Category Control No.: NKCR CSA CIASS No.: 3211-03 CSA UL
Product Tradename	M22
Product Type	Illuminated selector switch actuator
Product Sub Type	None
Bezel color	Titanium
Bezel material	Plastic
Color	Blue
Design	With thumb-grip
Fitted with:	Front ring
Functions	Stay-put/spring-return function, can be changed with coding parts M22-XC-Y
Accessories	Thumb grip
Degree of protection	NEMA 4X, 13
Degree of protection (front side)	IP66
Lifespan, mechanical	100,000 Operations
Opening diameter	22.5 mm
Operating frequency	2000 Operations/h
Operating torque	0.3 N·m
Product category	RMQ-Titan
Size	Front diameter: 29.7 mm
Suitable for	Illumination
Switching angle	40 °
	Illuminated selector switch actuator
Туре	
Type Mounting position Shock resistance	As required Mechanical, According to IEC/EN 60068-2-27

Antiants proofing Climatic pro	Ambient operating temperature - min	-25 °C
Consection to SmartWine-DT Consection to Consection to Consection Consectio	Ambient operating temperature - max	70 °C
Connection to SmartWine-DT Actuator Color Ac	Climatic proofing	
Actuator color Actuator function Actuator functi		Damp heat, cyclic, to IEC 60068-2-30
Actuator color Actuator function Actuator functi	Consortion to ConstMins DT	V
Actuator function Actuator fype Number of switch positions Force for positive opening - min Force for positive of for sentent Force for forestance of mulating materials to normal heat Force for positive of sessitive of sententing - materials to normal heat Force for positive of sessitive of forestance of mulating material Force for positive of positive of sessitive for positive for positive for positive for forestance of positive for forestance of mulating material Force forestance of positive forestance of forestance of mulating material Force forestance of forestance of mulating materi	Connection to SmartWire-D1	
Actuator function Actuator fype Number of switch positions Force for positive opening - min Force for positive of for sentent Force for forestance of mulating materials to normal heat Force for positive of sessitive of sententing - materials to normal heat Force for positive of sessitive of forestance of mulating material Force for positive of positive of sessitive for positive for positive for positive for forestance of positive for forestance of mulating material Force forestance of positive forestance of forestance of mulating material Force forestance of forestance of mulating materi		
Actuator type Actuator type Number of switch positions Since for positive opening - min Equipment heat dissipation, current-dependent Pvid Hot dissipation, capacity Pdiss Heat dissipation, capacity Pdiss Heat dissipation capacity Pdiss Heat dissipation per pole, current-dependent Pvid Hot dissipation per pole, current-dependent Pvid Heat dissipation, non-current-dependent Pvis Heat dissipation of the requirement Pvid Heat dissipation of the requirement Pvid Heat dissipation of resistance Meets the product standard's requirements. Heat dissipation of thermal stability of enclosures Heat dissipation of the standard's requirements. Heat Resistance of instability of enclosures Heat Resistance of instability of enclosures Heat Resistance of instability distance o	Actuator color	Black
Acutor/ type Number of switch positions Force for positive opening - min Force force for positive opening - min Force force for positive opening - min Force force for posi	Actuator function	
Number of switch positions 3 Force for positive opening - min 0 N Equipment heat dissipation, current-dependent Pvid 0 W Heat dissipation, current-dependent Pvid 0 W Heat dissipation per pole, current-dependent Pvid 0 W Static hear dissipation and properties of the extra dissipation (In) 0 A Static hear dissipation on non-current-dependent Pvid 0 W 10.2.2 Corrosion resistance Meets the product standard's requirements. 10.2.3.2 Verification of thermal stability of enclosures Meets the product standard's requirements. 10.2.3.2 Verification of thermal stability of enclosures Meets the product standard's requirements. 10.2.3.2 Verification of thermal stability of enclosures Meets the product standard's requirements. 10.2.3.2 Verification of thermal stability of enclosures Meets the product standard's requirements. 10.2.3.2 Nesistance to ultra-violet (UV) radiation Des not apply, since the entire switchgear needs to be evaluated. 10.2.5 Lifting Does not apply, since the entire switchgear needs to be evaluated. 10.2 Inscriptions Meets the product standard's requirements. 10.3 Portection of assenblies Does not apply, since the entire switchgear needs to be evaluated.	Ashinterhina	
Force for positive opening - min Force		
Equipment heat dissipation, current-dependent Pvid Heat dissipation capacity Pdiss Heat dissipation capacity Pdiss Heat dissipation capacity Pdiss Heat dissipation capacity Pdiss Heat dissipation proje, current-dependent Pvid OW Static heart dissipation, non-current-dependent Pvs OW 10.22 Corrosion resistance Meets the product standard's requirements. 10.23.1 Verification of thermal stability of enclosures Meets the product standard's requirements. 10.23.2 Verification of thermal stability of enclosures Meets the product standard's requirements. 10.23.3 Resist, of insul, mat, to abnormal heat/fire by internal elect. effects Meets the product standard's requirements. 10.24.3 Resistance to ultra-violet (UV) radiation 10.25 Lifting Does not apply, since the entire switchgear needs to be evaluated. 10.25 Lifting Does not apply, since the entire switchgear needs to be evaluated. 10.27 Inscriptions Meets the product standard's requirements. 10.3 Degree of protection of assemblies Does not apply, since the entire switchgear needs to be evaluated. 10.4 Clearances and creepage distances Meets the product standard's requirements. 10.5 Protection against electric shock Does not apply, since the entire switchgear needs to be evaluated. 10.5 Protection against electric shock Does not apply, since the entire switchgear needs to be evaluated. 10.6 Incorporation of switching devices and components Does not apply, since the entire switchgear needs to be evaluated. 10.7 Internal electrical circuits and connections Is the panel builder's responsibility. 10.8 Connections for external conductors Does not apply, since the entire switchgear needs to be evaluated. 10.9 Protection against electric strength Does not apply, since the entire switchgear needs to be evaluated. 10.7 Internal electrical circuits and connections Is the panel builder's responsibility. 10.8 Connections for external conductors Does not apply, since the entire switchgear needs to be evaluated. 10.9 In pulse withstand voltage Is the panel build	realings of switch positions	
Equipment heat dissipation, current-dependent Pvid Heat dissipation capacity Pdiss Heat dissipation capacity Pdiss Heat dissipation capacity Pdiss Heat dissipation capacity Pdiss Heat dissipation proje, current-dependent Pvid OW Static heart dissipation, non-current-dependent Pvs OW 10.22 Corrosion resistance Meets the product standard's requirements. 10.23.1 Verification of thermal stability of enclosures Meets the product standard's requirements. 10.23.2 Verification of thermal stability of enclosures Meets the product standard's requirements. 10.23.3 Resist, of insul, mat, to abnormal heat/fire by internal elect. effects Meets the product standard's requirements. 10.24.3 Resistance to ultra-violet (UV) radiation 10.25 Lifting Does not apply, since the entire switchgear needs to be evaluated. 10.25 Lifting Does not apply, since the entire switchgear needs to be evaluated. 10.27 Inscriptions Meets the product standard's requirements. 10.3 Degree of protection of assemblies Does not apply, since the entire switchgear needs to be evaluated. 10.4 Clearances and creepage distances Meets the product standard's requirements. 10.5 Protection against electric shock Does not apply, since the entire switchgear needs to be evaluated. 10.5 Protection against electric shock Does not apply, since the entire switchgear needs to be evaluated. 10.6 Incorporation of switching devices and components Does not apply, since the entire switchgear needs to be evaluated. 10.7 Internal electrical circuits and connections Is the panel builder's responsibility. 10.8 Connections for external conductors Does not apply, since the entire switchgear needs to be evaluated. 10.9 Protection against electric strength Does not apply, since the entire switchgear needs to be evaluated. 10.7 Internal electrical circuits and connections Is the panel builder's responsibility. 10.8 Connections for external conductors Does not apply, since the entire switchgear needs to be evaluated. 10.9 In pulse withstand voltage Is the panel build	Force for positive opening - min	0 N
Heat dissipation capacity Pdiss 0W Rated dissipation per pole, current-dependent Pvid 0W Rated operational current for specified heat dissipation (In) 0A Static heat dissipation, non-current-dependent Pvs 0W Rated operational current for specified heat dissipation (In) 0W Rated dissipation, non-current-dependent Pvs 0W Rest the product standard's requirements. 10.2.3.1 Verification of thermal stability of enclosures Meets the product standard's requirements. 10.2.3.2 Verification of resistance of insulating materials to normal heat 10.2.3.2 Verification of resistance of insulating materials to normal heat 10.2.3.3 Resist. of insul, mat. to abnormal heat/fire by internal elect. effects Meets the product standard's requirements. 10.2.4 Resistance to ultra-violet (UV) radiation Please enquire Desent apply, since the entire switchgear needs to be evaluated. 10.2.5 Intring Desent apply, since the entire switchgear needs to be evaluated. 10.2.7 Inscriptions Desent apply, since the entire switchgear needs to be evaluated. 10.4 Clearances and creepage distances Meets the product standard's requirements. 10.5 Protection against electric shock Desent apply, since the entire switchgear needs to be evaluated. 10.6 Incorporation of switching devices and components Desent apply, since the entire switchgear needs to be evaluated. 10.6 Incorporation of switching devices and components Desent apply, since the entire switchgear needs to be evaluated. 10.6 Incorporation of switching devices and components Desent apply, since the entire switchgear needs to be evaluated. 10.6 Incorporation of switchgear needs to be evaluated. 10.7 Internal electric alcircuits and connections Personal	· · · · · · · · · · · · · · · · · · ·	
Heat dissipation capacity Pdiss 0W Rated dissipation per pole, current-dependent Pvid 0W Rated operational current for specified heat dissipation (In) 0A Static heat dissipation, non-current-dependent Pvs 0W Rated operational current for specified heat dissipation (In) 0W Rated dissipation, non-current-dependent Pvs 0W Rest the product standard's requirements. 10.2.3.1 Verification of thermal stability of enclosures Meets the product standard's requirements. 10.2.3.2 Verification of resistance of insulating materials to normal heat 10.2.3.2 Verification of resistance of insulating materials to normal heat 10.2.3.3 Resist. of insul, mat. to abnormal heat/fire by internal elect. effects Meets the product standard's requirements. 10.2.4 Resistance to ultra-violet (UV) radiation Please enquire Desent apply, since the entire switchgear needs to be evaluated. 10.2.5 Intring Desent apply, since the entire switchgear needs to be evaluated. 10.2.7 Inscriptions Desent apply, since the entire switchgear needs to be evaluated. 10.4 Clearances and creepage distances Meets the product standard's requirements. 10.5 Protection against electric shock Desent apply, since the entire switchgear needs to be evaluated. 10.6 Incorporation of switching devices and components Desent apply, since the entire switchgear needs to be evaluated. 10.6 Incorporation of switching devices and components Desent apply, since the entire switchgear needs to be evaluated. 10.6 Incorporation of switching devices and components Desent apply, since the entire switchgear needs to be evaluated. 10.6 Incorporation of switchgear needs to be evaluated. 10.7 Internal electric alcircuits and connections Personal	Equipment heat dissipation, current-dependent Pvid	0 W
Rated operational current for specified heat dissipation (In) Static heat dissipation, non-current-dependent Pvs 0 W 10.2.2 Corrosion resistance Meets the product standard's requirements. 10.2.3.1 Verification of thermal stability of enclosures Meets the product standard's requirements. 10.2.3.2 Verification of resistance of insulating materials to normal heat 10.2.3.3 Resist of insul, mat, to abnormal heat/fire by internal elect, effects 10.2.4 Resistance to ultra-violet (UV) radiation 10.2.5 Lifting 10.2.6 Mechanical impact 10.2.7 Inscriptions 10.2.8 Dees not apply, since the entire switchgear needs to be evaluated. 10.2.7 Inscriptions 10.2.9 Dees not apply, since the entire switchgear needs to be evaluated. 10.2.1 Resistance and creepage distances 10.3 Degree of protection of assemblies 10.4 Clearances and creepage distances 10.5 Protection against electric shock 10.6 Incorporation of switching devices and components 10.7 Internal electrical circuits and connections 10.8 Connections for external conductors 10.9 Power-frequency electric strength 10.9 Power-frequency electric strength 10.9 Power-frequency electric strength 10.9 In the panel builder's responsibility. 10.9 In the panel build		
Static heat dissipation, non-current-dependent Pvs 10.2.2 Corrosion resistance 10.2.3.1 Verification of thermal stability of enclosures 10.2.3.2 Verification of resistance of insulating materials to normal heat 10.2.3.2 Verification of resistance of insulating materials to normal heat 10.2.3.3 Resist. of insul. mat. to abnormal heat/fire by internal elect. effects 10.2.4 Resistance to ultra-violet (UV) radiation 10.2.5 Lifting 10.2.6 Mechanical impact 10.2.6 Mechanical impact 10.2.7 Inscriptions 10.3.0 Degree of protection of assemblies 10.4 Clearances and creepage distances 10.5 Protection against electric shock 10.6 Incorporation of switching devices and components 10.7 Internal electrical circuits and connections 10.8 Connections for external conductors 10.9 Owen-frequency electric strength 10.9.1 Inspulse withstand voltage 10.9.1 Tengander of insulating material 10.1 Short-circuit rating 10.1 Short-circuit rating 10.1 Short-circuit rating 10.13 Mechanical function 10.13 Mechanical function 10.14 Mechanical function 10.15 Mechanical function 10.15 Mechanical function	Heat dissipation per pole, current-dependent Pvid	0 W
10.2.2 Corrosion resistance 10.2.3.1 Verification of thermal stability of enclosures 10.2.3.2 Verification of resistance of insulating materials to normal heat 10.2.3.2 Verification of resistance of insulating materials to normal heat 10.2.3.3 Resist. of insul. mat. to abnormal heat/fire by internal elect. effects 10.2.4 Resistance to ultra-violet (UV) radiation 10.2.5 Lifting 10.2.6 Mechanical impact 10.2.6 Mechanical impact 10.2.7 Inscriptions 10.3 Degree of protection of assemblies 10.4 Clearances and creepage distances 10.5 Protection against electric shock 10.6 Incorporation of switching devices and components 10.7 Internal electrical circuits and connections 10.8 Connections for external conductors 10.9.2 Power-frequency electric strength 10.9.3 Impulse withstand voltage 10.9.3 Impulse withstand voltage 10.1 Internal electrications 10.1 Internal electrications 10.2.4 Resing of enclosures made of insulating material 10.1 Temperature rise 10.1.1 Short-circuit rating 10.1.2 Electromagnetic compatibility 10.1.3 Mechanical function 10.1 The device meets the requirements. 10.1 The device meets the requirements. 10.2 Internal electrication of explain the product standard's requirements. 10.3 Internal electrical circuits and connections 10.4 The panel builder's responsibility. 10.5 Internal electrical circuits and connections 10.5 Internal electrical circuits and connections 10.6 Internal electrical circuits and connections 10.7 Internal electrical circuits and connections 10.8 Lepanel builder's responsibility. 10.9 Protection against electric strength 10.9 Internal electrical circuits and connections 10.1 Internal electrical circuits and connections 10.2 Power-frequency electric strength 10.3 Impulse withstand voltage 10.4 Electromagnetic compatibility 10.5 Internal electrical circuits and connections 10.5 Internal electrical circuits and connections 10.6 Internal electrical circuits and connections 10.7 Internal electrical circuits and connections 10.8 Internal electrical circuits and connections 10.8 Internal	Rated operational current for specified heat dissipation (In)	0 A
10.2.3.1 Verification of thermal stability of enclosures 10.2.3.2 Verification of resistance of insulating materials to normal heat 10.2.3.2 Verification of resistance of insulating materials to normal heat 10.2.3.3 Resists. of insul. mat. to abnormal heat/fire by internal elect. effects 10.2.4 Resistance to ultra-violet (UV) radiation 10.2.5 Lifting 10.2.6 Mechanical impact 10.2.6 Mechanical impact 10.2.7 Inscriptions 10.3 Degree of protection of assemblies 10.3 Degree of protection of assemblies 10.4 Clearances and creepage distances 10.5 Protection against electric shock 10.6 Incorporation of switching devices and components 10.7 Internal electrical circuits and connections 10.8 Connections for external conductors 10.9.4 Power-frequency electric strength 10.9.4 Testing of enclosures made of insulating material 10.9.4 Testing of enclosures made of insulating material 10.1 Tomperature rise 10.1 Tomperature rise 10.1 Short-circuit rating 10.1 Short-circuit rating 10.1 Shechanical function 10.1 Mechanical function 10.2 Electromagnetic compatibility 10.3 Impulse withstand voltage 10.1 Internal bilder's responsibility. 10.2 The panel bilder's responsibility. 10.3 Impulse withstand voltage 10.4 Is the panel bilder's responsibility. 10.5 Is the panel bilder's responsibility. 10.6 Internal bilder's responsibility. 10.7 Internal bilder's responsibility. 10.8 Is the panel bilder's responsibility. 10.9 Is the panel bilder's responsibility. 10.9 Is the panel bilder's responsibility. 10.1 Temperature rise 10.1 Is the panel bilder's responsibility. 10.2 Is the panel bilder's responsibility. 10.3 Impulse withstand voltage 10.4 Is the panel bilder's responsibility. 10.5 Is the panel bilder's responsibility. 10.6 Internal bilder's responsibility. 10.7 Internal bilder's responsibility. 10.8 Is the panel bilder's responsibility. 10.9 Internal bilder's responsibility. 10.1 Temperature rise 10.1 Is the panel bilder's responsibility. The specifications for the switchgear must be observed.	Static heat dissipation, non-current-dependent Pvs	0 W
10.2.3.2 Verification of resistance of insulating materials to normal heat 10.2.3.3 Resist. of insul. mat. to abnormal heat/fire by internal elect. effects 10.2.4 Resistance to ultra-violet (UV) radiation 10.2.5 Lifting 10.2.5 Lifting 10.2.6 Mechanical impact 10.2.7 Inscriptions 10.2.7 Inscriptions 10.2.7 Inscriptions 10.2.7 Inscriptions 10.2.8 Meets the product standard's requirements. 10.3 Degree of protection of assemblies 10.4 Clearances and creepage distances 10.5 Protection against electric shock 10.6 Incorporation of switching devices and components 10.7 Internal electrical circuits and connections 10.8 Connections for external conductors 10.9 Power-frequency electric strength 10.9 Nover-frequency electric strength 10.9 Internal electrical circuits and other entire switchgear needs to be evaluated. 10.9 Internal electrical circuits and connections 10.5 Protection against electric strength 10.5 Protection against electric switchgear needs to be evaluated. 10.6 Incorporation of switching devices and components 10.7 Internal electrical circuits and connections 10.8 Connections for external conductors 10.9 Power-frequency electric strength 10.9 Power-frequency electric strength 10.9 Internal electrical circuits and connections 10.9 Internal electrical circuits and connecti	10.2.2 Corrosion resistance	Meets the product standard's requirements.
10.2.3.3 Resist. of insul. mat. to abnormal heat/fire by internal elect. effects 10.2.4 Resistance to ultra-violet (UV) radiation 10.2.5 Lifting 10.2.6 Mechanical impact 10.2.7 Inscriptions 10.3 Degree of protection of assemblies 10.4 Clearances and creepage distances 10.5 Protection against electric shock 10.6 Incorporation of switching devices and components 10.7 Internal electrical circuits and connections 10.9 Power-frequency electric strength 10.9 Power-frequency electric strength 10.9 Is the panel builder's responsibility. 10.9 Tomperature rise 10.1 Short-circuit rating 10.1 Short-circuit rating 10.1 Short-circuit rating 10.1 Mechanical function 10.1 Mechanical function 10.1 Mechanical function 10.1 Mechanical function 10.1 The device meets the requirements, provided the information in the instruction of the instruction of the switchgear must be observed.	10.2.3.1 Verification of thermal stability of enclosures	Meets the product standard's requirements.
10.2.4 Resistance to ultra-violet (UV) radiation 10.2.5 Lifting 10.2.6 Mechanical impact 10.2.6 Mechanical impact 10.2.7 Inscriptions 10.3 Degree of protection of assemblies 10.4 Clearances and creepage distances 10.5 Protection against electric shock 10.6 Incorporation of switching devices and components 10.7 Internal electrical circuits and connections 10.7 Internal electrical circuits and connections 10.8 Connections for external conductors 10.9 Power-frequency electric strength 10.9 Power-frequency electric strength 10.9 Is the panel builder's responsibility. 10.9 Internal electrical circuits and voltage 10.9 Is the panel builder's responsibility. 10.9 Internal electrical circuits and connections 10.9 Is the panel builder's responsibility. 10.10 Temperature rise 10.11 Short-circuit rating 10.12 Electromagnetic compatibility 10.13 Mechanical function 10.13 Mechanical function 10.14 Mechanical function 10.15 Mechanical function 10.15 Mechanical function 10.16 Meets the entire switchgear needs to be evaluated. 10.17 Description assemble as the entire switchgear needs to be evaluated. 10.18 Meets the product standard's requirements. 10.19 Meets the entire switchgear needs to be evaluated. 10.19 Meets the product standard's requirements. 10.19 Meets the product standard's requirements. 10.19 Meets the product standard's requirements. 10.19 Mee	10.2.3.2 Verification of resistance of insulating materials to normal heat	Meets the product standard's requirements.
10.2.5 Lifting 10.2.6 Mechanical impact 10.2.6 Mechanical impact 10.2.7 Inscriptions 10.2.7 Inscriptions 10.3 Degree of protection of assemblies 10.4 Clearances and creepage distances 10.5 Protection against electric shock 10.6 Incorporation of switching devices and components 10.7 Internal electrical circuits and connections 10.8 Connections for external conductors 10.9 Power-frequency electric strength 10.9 Power-frequency electric strength 10.9 Internal electric strength 10.9 Is the panel builder's responsibility. 10.9 Power-frequency electric strength 10.9 Is the panel builder's responsibility. 10.9 Internal electrical circuits and connections 10.9 Is the panel builder's responsibility. 10.9 Internal electric strength 10.9 Is the panel builder's responsibility. 10.9 Internal electric strength 10.9 Is the panel builder's responsibility. 10.9 Internal electric strength 10.9 Is the panel builder's responsibility. 10.9 Internal electric strength 10.9 Is the panel builder's responsibility. 10.9 Internal electric strength 10.9 Is the panel builder's responsibility. 10.9 Internal electric strength 10.9 Is the panel builder's responsibility. 10.9 Internal electric strength 10.9 Is the panel builder's responsibility. 10.9 Internal electric strength 10.9 Is the panel builder's responsibility. 10.9 Internal electric strength 10.9 Is the panel builder's responsibility. 10.9 Internal electric strength 10.9 Internal electric switchgear needs to be evaluated. 10.9 Internal electric switchgea	10.2.3.3 Resist. of insul. mat. to abnormal heat/fire by internal elect. effects	Meets the product standard's requirements.
10.2.6 Mechanical impact 10.2.7 Inscriptions Meets the product standard's requirements. Does not apply, since the entire switchgear needs to be evaluated. 10.3 Degree of protection of assemblies Does not apply, since the entire switchgear needs to be evaluated. 10.4 Clearances and creepage distances Meets the product standard's requirements. Does not apply, since the entire switchgear needs to be evaluated. 10.5 Protection against electric shock Does not apply, since the entire switchgear needs to be evaluated. 10.6 Incorporation of switching devices and components Does not apply, since the entire switchgear needs to be evaluated. 10.7 Internal electrical circuits and connections Is the panel builder's responsibility. 10.9.2 Power-frequency electric strength Is the panel builder's responsibility. 10.9.3 Impulse withstand voltage Is the panel builder's responsibility. 10.9.4 Testing of enclosures made of insulating material 10.10 Temperature rise Not applicable. 10.11 Short-circuit rating Is the panel builder's responsibility. The specifications for the switchgear must be observed. 10.12 Electromagnetic compatibility The device meets the requirements, provided the information in the instruction	10.2.4 Resistance to ultra-violet (UV) radiation	Please enquire
10.2.7 Inscriptions Meets the product standard's requirements. 10.3 Degree of protection of assemblies Does not apply, since the entire switchgear needs to be evaluated. 10.4 Clearances and creepage distances Meets the product standard's requirements. 10.5 Protection against electric shock Does not apply, since the entire switchgear needs to be evaluated. 10.6 Incorporation of switching devices and components Does not apply, since the entire switchgear needs to be evaluated. 10.7 Internal electrical circuits and connections Is the panel builder's responsibility. 10.9.2 Power-frequency electric strength Is the panel builder's responsibility. 10.9.3 Impulse withstand voltage Is the panel builder's responsibility. 10.9.4 Testing of enclosures made of insulating material 10.10 Temperature rise Not applicable. 10.11 Short-circuit rating Is the panel builder's responsibility. The specifications for the switchgear must be observed. 10.12 Electromagnetic compatibility The device meets the requirements, provided the information in the instruction	10.2.5 Lifting	Does not apply, since the entire switchgear needs to be evaluated.
10.3 Degree of protection of assemblies 10.4 Clearances and creepage distances Meets the product standard's requirements. 10.5 Protection against electric shock 10.6 Incorporation of switching devices and components 10.7 Internal electrical circuits and connections 10.8 Connections for external conductors 10.9.2 Power-frequency electric strength 10.9.3 Impulse withstand voltage 10.9.4 Testing of enclosures made of insulating material 10.10 Temperature rise 10.11 Short-circuit rating 10.12 Electromagnetic compatibility 10.13 Mechanical function 10.13 Mechanical function 10.14 Clearances and creepage distances Meets the product standard's requirements. Meets the product standard's requirements. Meets the product standard's requirements. Does not apply, since the entire switchgear needs to be evaluated. 10.6 Incorporation of switching devices and components Does not apply, since the entire switchgear needs to be evaluated. 10.6 Incorporation of switching devices and components Does not apply, since the entire switchgear needs to be evaluated. 10.6 Incorporation of switching average in eds to be evaluated. 10.6 Incorporation of switching average in eds to be evaluated. 10.6 Incorporation of switching average in eds to be evaluated. 10.8 Connections for external conductors Is the panel builder's responsibility. 10.9.2 Power-frequency electric strength Is the panel builder's responsibility. 10.9.3 Impulse withstand voltage Is the panel builder's responsibility. 10.9.4 Testing of enclosures made of insulating material Is the panel builder's responsibility. 10.10 Temperature rise Not applicable. 10.11 Short-circuit rating Is the panel builder's responsibility. The specifications for the switchgear must be observed. 10.12 Electromagnetic compatibility The device meets the requirements, provided the information in the instruction	10.2.6 Mechanical impact	Does not apply, since the entire switchgear needs to be evaluated.
10.4 Clearances and creepage distances 10.5 Protection against electric shock 10.6 Incorporation of switching devices and components 10.7 Internal electrical circuits and connections 10.8 Connections for external conductors 10.9.2 Power-frequency electric strength 10.9.3 Impulse withstand voltage 10.9.4 Testing of enclosures made of insulating material 10.10 Temperature rise 10.11 Short-circuit rating 10.12 Electromagnetic compatibility 10.13 Mechanical function Meets the product standard's requirements. Does not apply, since the entire switchgear needs to be evaluated. 10 Does not apply, since the entire switchgear needs to be evaluated. Is the panel builder's responsibility. The specifications for the switchgear must be observed. The device meets the requirements, provided the information in the instruction	10.2.7 Inscriptions	Meets the product standard's requirements.
10.5 Protection against electric shock 10.6 Incorporation of switching devices and components 10.7 Internal electrical circuits and connections 10.8 Connections for external conductors 10.9.2 Power-frequency electric strength 10.9.3 Impulse withstand voltage 10.9.4 Testing of enclosures made of insulating material 10.10 Temperature rise 10.11 Short-circuit rating 10.12 Electromagnetic compatibility 10.13 Mechanical function 10.13 Mechanical function 10.10 Temperature in entire switchgear needs to be evaluated. 10.10 Temperature in entire switchgear needs to be evaluated. 10.10 Temperature rise 10.11 Short-circuit rating 10.12 Electromagnetic compatibility 10.13 Mechanical function 10.14 Every eneets the requirements, provided the information in the instruction	10.3 Degree of protection of assemblies	Does not apply, since the entire switchgear needs to be evaluated.
Does not apply, since the entire switchgear needs to be evaluated. 10.7 Internal electrical circuits and connections Is the panel builder's responsibility. 10.8 Connections for external conductors Is the panel builder's responsibility. 10.9.2 Power-frequency electric strength Is the panel builder's responsibility. 10.9.3 Impulse withstand voltage Is the panel builder's responsibility. 10.9.4 Testing of enclosures made of insulating material Is the panel builder's responsibility. 10.10 Temperature rise Not applicable. 10.11 Short-circuit rating Is the panel builder's responsibility. The specifications for the switchgear must be observed. 10.12 Electromagnetic compatibility The device meets the requirements, provided the information in the instruction	10.4 Clearances and creepage distances	Meets the product standard's requirements.
10.7 Internal electrical circuits and connections 10.8 Connections for external conductors 10.9.2 Power-frequency electric strength 10.9.3 Impulse withstand voltage 10.9.4 Testing of enclosures made of insulating material 10.10 Temperature rise 10.11 Short-circuit rating 10.12 Electromagnetic compatibility 10.13 Mechanical function 10.13 Mechanical function 10.14 Is the panel builder's responsibility. The specifications for the switchgear must be observed. 10.15 Is the panel builder's responsibility. The specifications for the switchgear must be observed.	•	
10.8 Connections for external conductors 10.9.2 Power-frequency electric strength 10.9.3 Impulse withstand voltage 10.9.4 Testing of enclosures made of insulating material 10.10 Temperature rise 10.11 Short-circuit rating 10.12 Electromagnetic compatibility 10.13 Mechanical function 10.13 Mechanical function 10.14 Sthe panel builder's responsibility. The specifications for the switchgear must be observed. 10.15 the panel builder's responsibility. The specifications for the switchgear must be observed. 10.15 the panel builder's responsibility. The specifications for the switchgear must be observed. 10.16 We panel builder's responsibility. The specifications for the switchgear must be observed.	· · · · · · · · · · · · · · · · · · ·	
10.9.2 Power-frequency electric strength 10.9.3 Impulse withstand voltage 10.9.4 Testing of enclosures made of insulating material 10.10 Temperature rise 10.11 Short-circuit rating 10.12 Electromagnetic compatibility 10.13 Mechanical function 1 Is the panel builder's responsibility. 1 Is the panel builder's responsibility. 1 Is the panel builder's responsibility. The specifications for the switchgear must be observed. 1 Is the panel builder's responsibility. The specifications for the switchgear must be observed. 1 Is the panel builder's responsibility. The specifications for the switchgear must be observed. 1 Is the panel builder's responsibility. The specifications for the switchgear must be observed.		
10.9.3 Impulse withstand voltage 10.9.4 Testing of enclosures made of insulating material 10.10 Temperature rise 10.11 Short-circuit rating 10.12 Electromagnetic compatibility 10.13 Mechanical function 10.13 Mechanical function 10.14 Testing of enclosures made of insulating material 15 the panel builder's responsibility. The specifications for the switchgear must be observed. 10.15 the panel builder's responsibility. The specifications for the switchgear must be observed. 10.16 The device meets the requirements, provided the information in the instruction		
10.9.4 Testing of enclosures made of insulating material Is the panel builder's responsibility. 10.10 Temperature rise Not applicable. 10.11 Short-circuit rating Is the panel builder's responsibility. The specifications for the switchgear must be observed. 10.12 Electromagnetic compatibility Is the panel builder's responsibility. The specifications for the switchgear must be observed. 10.13 Mechanical function The device meets the requirements, provided the information in the instruction		
10.10 Temperature rise 10.11 Short-circuit rating 10.12 Electromagnetic compatibility 10.13 Mechanical function Not applicable. Is the panel builder's responsibility. The specifications for the switchgear must be observed. Is the panel builder's responsibility. The specifications for the switchgear must be observed. The device meets the requirements, provided the information in the instruction		
10.11 Short-circuit rating Is the panel builder's responsibility. The specifications for the switchgear must be observed. 10.12 Electromagnetic compatibility Is the panel builder's responsibility. The specifications for the switchgear must be observed. 10.13 Mechanical function The device meets the requirements, provided the information in the instruction		
observed. 10.12 Electromagnetic compatibility Is the panel builder's responsibility. The specifications for the switchgear must be observed. 10.13 Mechanical function The device meets the requirements, provided the information in the instruction	·	
observed. 10.13 Mechanical function The device meets the requirements, provided the information in the instruction	· ·	observed.
	10.12 Electromagnetic compatibility	Is the panel builder's responsibility. The specifications for the switchgear must be observed.
	10.13 Mechanical function	

Technical data ETIM 8.0

Low-voltage industrial components (EG000017) / Front element for selector switch (EC000222)

Electric engineering, automation, process control engineering / Low-voltage switch technology / Command and alarm device / Front element for selector switches (ecl@ss10.0.1-27-37-12-13 [AKF031014])

Number of switch positions			3
Type of control element			Toggle
Suitable for illumination			Yes
Colour control element			Black
Colour indicator light cap			Blue
Construction type lens			Round
Hole diameter	m	nm	22.5
Width opening	m	nm	0

Height opening	mm	0
Switching function latching		No
Spring-return		Yes
With front ring		Yes
Material front ring		Plastic
Colour front ring		Titanium
Degree of protection (IP), front side		IP66
Degree of protection (NEMA)		4X, 13