# **DATASHEET - PLS6-C10/2-MW**



Miniature circuit breaker (MCB), 10 A, 2p, characteristic: C

PLS6-C10/2-MW Part no. Catalog No. 242876



Similar to illustration

|  | gram |
|--|------|
|  |      |
|  |      |

| 7              |                 |    |  |
|--|-----------------|----|--|
| Basic function                                       |                 |    | Miniature circuit-breakers                             |
| Number of poles                                      |                 |    | 2 pole   |
| Tripping characteristic                              |                 |    | С  |
| Application  |                 |    | Switchgear for residential and commercial applications |
| Rated current  | In              | Α  | 10   |
| Rated switching capacity according to IEC/EN 60898-1 | I <sub>cn</sub> | kA | 6  |
| Product range  |                 |    | PLS6   |

## **Technical data**

### **Electrical**

|--|

| Design verification as per IEC/EN 61439  |                   |    |  |
|--|-------------------|----|--|
| Technical data for design verification   |                   |    |  |
| Rated operational current for specified heat dissipation   | In                | Α  | 10   |
| Heat dissipation per pole, current-dependent   | P <sub>vid</sub>  | W  | 0  |
| Equipment heat dissipation, current-dependent  | $P_{\text{vid}}$  | W  | 3  |
| Static heat dissipation, non-current-dependent   | $P_{vs}$          | W  | 0  |
| Heat dissipation capacity  | P <sub>diss</sub> | W  | 0  |
| Operating ambient temperature min.   |                   | °C | -25  |
| Operating ambient temperature max.   |                   | °C | 75   |
|  |                   |    | linear, per +1 °C, results in a 0.5% reduction of current carrying capacity  |
| EC/EN 61439 design verification  |                   |    |  |
| 10.2 Strength of materials and parts   |                   |    |  |
| 10.2.2 Corrosion resistance  |                   |    | Meets the product standard's requirements.   |
| 10.2.3.1 Verification of thermal stability of enclosures   |                   |    | Meets the product standard's requirements.   |
| 10.2.3.2 Verification of resistance of insulating materials to normal heat   |                   |    | Meets the product standard's requirements.   |
| 10.2.3.3 Verification of resistance of insulating materials to abnormal heat and fire due to internal electric effects |                   |    | Meets the product standard's requirements.   |
| 10.2.4 Resistance to ultra-violet (UV) radiation   |                   |    | Meets the product standard's requirements.   |
| 10.2.5 Lifting   |                   |    | Does not apply, since the entire switchgear needs to be evaluated.   |
| 10.2.6 Mechanical impact   |                   |    | Does not apply, since the entire switchgear needs to be evaluated.   |
| 10.2.7 Inscriptions  |                   |    | Meets the product standard's requirements.   |
| 10.3 Degree of protection of ASSEMBLIES  |                   |    | Does not apply, since the entire switchgear needs to be evaluated.   |
| 10.4 Clearances and creepage distances   |                   |    | Meets the product standard's requirements.   |
| 10.5 Protection against electric shock   |                   |    | Does not apply, since the entire switchgear needs to be evaluated.   |
| 10.6 Incorporation of switching devices and components   |                   |    | Does not apply, since the entire switchgear needs to be evaluated.   |
| 10.7 Internal electrical circuits and connections  |                   |    | Is the panel builder's responsibility.   |
| 10.8 Connections for external conductors   |                   |    | Is the panel builder's responsibility.   |
| 10.9 Insulation properties   |                   |    |  |
| 10.9.2 Power-frequency electric strength   |                   |    | Is the panel builder's responsibility.   |
| 10.9.3 Impulse withstand voltage   |                   |    | Is the panel builder's responsibility.   |
| 10.9.4 Testing of enclosures made of insulating material   |                   |    | Is the panel builder's responsibility.   |
| 10.10 Temperature rise   |                   |    | The panel builder is responsible for the temperature rise calculation. Eaton will provide heat dissipation data for the devices. |

| 10.11 Short-circuit rating          | Is the panel builder's responsibility. The specifications for the switchgear must be observed.           |
|-------------------------------------|--|
| 10.12 Electromagnetic compatibility | Is the panel builder's responsibility. The specifications for the switchgear must be observed.           |
| 10.13 Mechanical function           | The device meets the requirements, provided the information in the instruction leaflet (IL) is observed. |

## **Technical data ETIM 7.0**

| reclifficat data ETHM 7.0  |                    |           |   |
|--|--------------------|-----------|---|
| Circuit breakers and fuses (EG000020) / Miniature circuit breaker (MCB) (EC000042)   |                    |           |   |
| Electric engineering, automation, process control engineering / Electrical installation (ecl@ss10.0.1-27-14-19-01 [AAB905014]) | on, device / Minia | ature cir | cuit breaker system (MCB) / Miniature circuit breaker (MCB) |
| Release characteristic   |                    |           | С   |
| Number of poles (total)  |                    |           | 2   |
| Number of protected poles  |                    |           | 2   |
| Rated current  | A                  | A         | 10  |
| Rated voltage  | V                  | /         | 400   |
| Rated insulation voltage Ui  | V                  | /         | 440   |
| Rated impulse withstand voltage Uimp   | k                  | κV        | 4   |
| Rated short-circuit breaking capacity Icn EN 60898 at 230 V  | k                  | κA        | 6   |
| Rated short-circuit breaking capacity Icn EN 60898 at 400 V  | k                  | κA        | 6   |
| Rated short-circuit breaking capacity Icu IEC 60947-2 at 230 V   | k                  | κA        | 0   |
| Rated short-circuit breaking capacity Icu IEC 60947-2 at 400 V   | k                  | κA        | 0   |
| Voltage type   |                    |           | AC  |
| Frequency  | Н                  | Hz        | 50 - 60   |
| Current limiting class   |                    |           | 3   |
| Suitable for flush-mounted installation  |                    |           | No  |
| Concurrently switching N-neutral   |                    |           | No  |
| Over voltage category  |                    |           | 3   |
| Pollution degree   |                    |           | 2   |
| Additional equipment possible  |                    |           | Yes   |
| Width in number of modular spacings  |                    |           | 2   |
| Built-in depth   | n                  | mm        | 70.5  |
| Degree of protection (IP)  |                    |           | IP20  |
| Ambient temperature during operating   | 0                  | C.        | -25 - 75  |
| Connectable conductor cross section multi-wired  | n                  | nm²       | 1 - 25  |
| Connectable conductor cross section solid-core   | n                  | nm²       | 1 - 25  |
|  |                    |           |   |