# DATASHEET - PLS6-B8/3-MW



### Miniature circuit breaker (MCB), 8 A, 3p, characteristic: B

Powering Business Worldwide\*

Part no. PLS6-B8/3-MW Catalog No. 242918

| livery |  |  |
|--------|--|--|
|        |  |  |
|        |  |  |
|        |  |  |

| Basic function                                       |                 |    | Miniature circuit-breakers                             |
|--|-----------------|----|--|
| Number of poles                                      |                 |    | 3 pole   |
| Tripping characteristic                              |                 |    | В  |
| Application  |                 |    | Switchgear for residential and commercial applications |
| Rated current  | In              | Α  | 8  |
| Rated switching capacity according to IEC/EN 60898-1 | I <sub>cn</sub> | kA | 6  |
| Product range  |                 |    | PLS6   |

## **Technical data**

**Electrical** 

|--|

## **Design verification as per IEC/EN 61439**

| Design verification as per IEC/EN 61439   |                   |    |  |
|---|-------------------|----|--|
| Technical data for design verification  |                   |    |  |
| Rated operational current for specified heat dissipation  | In                | Α  | 8  |
| Heat dissipation per pole, current-dependent  | $P_{vid}$         | W  | 0  |
| Equipment heat dissipation, current-dependent   | P <sub>vid</sub>  | W  | 6.3  |
| Static heat dissipation, non-current-dependent  | $P_{vs}$          | W  | 0  |
| Heat dissipation capacity   | P <sub>diss</sub> | W  | 0  |
| Operating ambient temperature min.  |                   | °C | -25  |
| Operating ambient temperature max.  |                   | °C | 75   |
|   |                   |    | linear, per +1 °C, results in a 0.5% reduction of current carrying capacity  |
| EC/EN 61439 design verification   |                   |    |  |
| 10.2 Strength of materials and parts  |                   |    |  |
| 10.2.2 Corrosion resistance   |                   |    | Meets the product standard's requirements.   |
| 10.2.3.1 Verification of thermal stability of enclosures  |                   |    | Meets the product standard's requirements.   |
| 10.2.3.2 Verification of resistance of insulating materials to normal heat  |                   |    | Meets the product standard's requirements.   |
| 10.2.3.3 Verification of resistance of insulating materials to abnormal heat and fire due to internal electric effects $$ |                   |    | Meets the product standard's requirements.   |
| 10.2.4 Resistance to ultra-violet (UV) radiation  |                   |    | Meets the product standard's requirements.   |
| 10.2.5 Lifting  |                   |    | Does not apply, since the entire switchgear needs to be evaluated.   |
| 10.2.6 Mechanical impact  |                   |    | Does not apply, since the entire switchgear needs to be evaluated.   |
| 10.2.7 Inscriptions   |                   |    | Meets the product standard's requirements.   |
| 10.3 Degree of protection of ASSEMBLIES   |                   |    | Does not apply, since the entire switchgear needs to be evaluated.   |
| 10.4 Clearances and creepage distances  |                   |    | Meets the product standard's requirements.   |
| 10.5 Protection against electric shock  |                   |    | Does not apply, since the entire switchgear needs to be evaluated.   |
| 10.6 Incorporation of switching devices and components  |                   |    | Does not apply, since the entire switchgear needs to be evaluated.   |
| 10.7 Internal electrical circuits and connections   |                   |    | Is the panel builder's responsibility.   |
| 10.8 Connections for external conductors  |                   |    | Is the panel builder's responsibility.   |
| 10.9 Insulation properties  |                   |    |  |
| 10.9.2 Power-frequency electric strength  |                   |    | Is the panel builder's responsibility.   |
| 10.9.3 Impulse withstand voltage  |                   |    | Is the panel builder's responsibility.   |
| 10.9.4 Testing of enclosures made of insulating material  |                   |    | Is the panel builder's responsibility.   |
| 10.10 Temperature rise  |                   |    | The panel builder is responsible for the temperature rise calculation. Eaton will provide heat dissipation data for the devices. |
| 10.11 Short-circuit rating  |                   |    | Is the panel builder's responsibility. The specifications for the switchgear must observed.                                      |

| 10.12 Electromagnetic compatibility | Is the panel builder's responsibility. The specifications for the switchgear must be observed.           |
|-------------------------------------|--|
| 10.13 Mechanical function           | The device meets the requirements, provided the information in the instruction leaflet (IL) is observed. |

### **Technical data ETIM 7.0**

| Circuit breakers and fuses (FG000000) / Miniature circuit | L L / MACD\ / CC000040\ |
|---|-------------------------|
|   |                         |

Electric engineering, automation, process control engineering / Electrical installation, device / Miniature circuit breaker system (MCB) / Miniature circuit breaker (MCB) (pc)(@cs10.01-177-14-19-01 [AAR905014])

| (ecl@ss10.0.1-27-14-19-01 [AAB905014])                            |    |     |          |
|---|----|-----|----------|
| Release characteristic  |    |     | В        |
| Number of poles (total)   |    |     | 3        |
| Number of protected poles   |    |     | 3        |
| Rated current   | А  | 4   | 8        |
| Rated voltage   | V  | /   | 400      |
| Rated insulation voltage Ui                                       | V  | /   | 440      |
| Rated impulse withstand voltage Uimp                              | k' | :V  | 4        |
| Rated short-circuit breaking capacity Icn EN 60898 at 230 V       | k  | £Α  | 6        |
| Rated short-circuit breaking capacity Icn EN 60898 at 400 V       | k  | £Α  | 6        |
| Rated short-circuit breaking capacity Icu IEC 60947-2 at 230 V    | k  | :A  | 0        |
| Rated short-circuit breaking capacity Icu IEC 60947-2 at 400 V $$ | k  | £Α  | 0        |
| Voltage type  |    |     | AC       |
| Frequency   | Н  | łz  | 50 - 60  |
| Current limiting class  |    |     | 3        |
| Suitable for flush-mounted installation                           |    |     | No       |
| Concurrently switching N-neutral                                  |    |     | No       |
| Over voltage category   |    |     | 3        |
| Pollution degree  |    |     | 2        |
| Additional equipment possible                                     |    |     | Yes      |
| Width in number of modular spacings                               |    |     | 3        |
| Built-in depth  | m  | nm  | 70.5     |
| Degree of protection (IP)   |    |     | IP20     |
| Ambient temperature during operating                              | °( | С   | -25 - 75 |
| Connectable conductor cross section multi-wired                   | m  | nm² | 1 - 25   |
| Connectable conductor cross section solid-core                    | m  | nm² | 1 - 25   |