## **DATASHEET - PLHT-D63/4**



### Miniature circuit breaker (MCB), 63A, 4p, D-Char, AC

Powering Business Worldwide\*

Part no. PLHT-D63/4 Catalog No. 248099

EL-Nummer (Norway)

1609560

Similar to illustration

## **Delivery program**

| Basic function                                  |                 |    | Miniature circuit-breakers                                     |
|---|-----------------|----|--|
| Number of poles                                 |                 |    | 4 pole   |
| Tripping characteristic                         |                 |    | D  |
| Application                                     |                 |    | Switchgear for industrial and advanced commercial applications |
| Rated current                                   | In              | Α  | 63   |
| Rated switching capacity acc. to IEC/EN 60947-2 | I <sub>cu</sub> | kA | 25   |
| Product range                                   |                 |    | PLHT   |

# **Technical data**

#### Electrical

| I <sub>cu</sub> kA 25 |
|-----------------------|
|-----------------------|

## **Design verification as per IEC/EN 61439**

| Design verification as per IEC/EN 61439  |                   |    |  |
|--|-------------------|----|--|
| echnical data for design verification  |                   |    |  |
| Rated operational current for specified heat dissipation   | In                | Α  | 63   |
| Heat dissipation per pole, current-dependent   | $P_{\text{vid}}$  | W  | 0  |
| Equipment heat dissipation, current-dependent  | P <sub>vid</sub>  | W  | 20.8   |
| Static heat dissipation, non-current-dependent   | P <sub>vs</sub>   | W  | 0  |
| Heat dissipation capacity  | P <sub>diss</sub> | W  | 0  |
| Operating ambient temperature min.   |                   | °C | -25  |
| Operating ambient temperature max.   |                   | °C | 55   |
|  |                   |    | linear, per +1 °C, results in a 0.35% reduction of current carrying capacity   |
| C/EN 61439 design verification   |                   |    |  |
| 10.2 Strength of materials and parts   |                   |    |  |
| 10.2.2 Corrosion resistance  |                   |    | Meets the product standard's requirements.   |
| 10.2.3.1 Verification of thermal stability of enclosures   |                   |    | Meets the product standard's requirements.   |
| 10.2.3.2 Verification of resistance of insulating materials to normal heat   |                   |    | Meets the product standard's requirements.   |
| 10.2.3.3 Verification of resistance of insulating materials to abnormal heat and fire due to internal electric effects |                   |    | Meets the product standard's requirements.   |
| 10.2.4 Resistance to ultra-violet (UV) radiation   |                   |    | Meets the product standard's requirements.   |
| 10.2.5 Lifting   |                   |    | Does not apply, since the entire switchgear needs to be evaluated.   |
| 10.2.6 Mechanical impact   |                   |    | Does not apply, since the entire switchgear needs to be evaluated.   |
| 10.2.7 Inscriptions  |                   |    | Meets the product standard's requirements.   |
| 10.3 Degree of protection of ASSEMBLIES  |                   |    | Does not apply, since the entire switchgear needs to be evaluated.   |
| 10.4 Clearances and creepage distances   |                   |    | Meets the product standard's requirements.   |
| 10.5 Protection against electric shock   |                   |    | Does not apply, since the entire switchgear needs to be evaluated.   |
| 10.6 Incorporation of switching devices and components   |                   |    | Does not apply, since the entire switchgear needs to be evaluated.   |
| 10.7 Internal electrical circuits and connections  |                   |    | Is the panel builder's responsibility.   |
| 10.8 Connections for external conductors   |                   |    | Is the panel builder's responsibility.   |
| 10.9 Insulation properties   |                   |    |  |
| 10.9.2 Power-frequency electric strength   |                   |    | Is the panel builder's responsibility.   |
| 10.9.3 Impulse withstand voltage   |                   |    | Is the panel builder's responsibility.   |
| 10.9.4 Testing of enclosures made of insulating material   |                   |    | Is the panel builder's responsibility.   |
| 10.10 Temperature rise   |                   |    | The panel builder is responsible for the temperature rise calculation. Eaton will provide heat dissipation data for the devices. |

| 10.11 Short-circuit rating          | Is the panel builder's responsibility. The specifications for the switchgear must be observed.           |
|-------------------------------------|--|
| 10.12 Electromagnetic compatibility | Is the panel builder's responsibility. The specifications for the switchgear must be observed.           |
| 10.13 Mechanical function           | The device meets the requirements, provided the information in the instruction leaflet (IL) is observed. |

## **Technical data ETIM 7.0**

| IECIIIICAI UALA ETTIVI 7.0  |    |     |          |  |  |  |
|---|----|-----|----------|--|--|--|
| Circuit breakers and fuses (EG000020) / Miniature circuit breaker (MCB) (EC000042   | 2) |     |          |  |  |  |
| Electric engineering, automation, process control engineering / Electrical installation, device / Miniature circuit breaker system (MCB) / Miniature circuit breaker (MCB) (ecl@ss10.0.1-27-14-19-01 [AAB905014]) |    |     |          |  |  |  |
| Release characteristic  |    |     | D        |  |  |  |
| Number of poles (total)   |    |     | 4        |  |  |  |
| Number of protected poles   |    |     | 4        |  |  |  |
| Rated current   |    | Α   | 63       |  |  |  |
| Rated voltage   |    | V   | 400      |  |  |  |
| Rated insulation voltage Ui   |    | V   | 440      |  |  |  |
| Rated impulse withstand voltage Uimp  |    | kV  | 4        |  |  |  |
| Rated short-circuit breaking capacity Icn EN 60898 at 230 V   |    | kA  | 0        |  |  |  |
| Rated short-circuit breaking capacity Icn EN 60898 at 400 V   |    | kA  | 0        |  |  |  |
| Rated short-circuit breaking capacity Icu IEC 60947-2 at 230 V  |    | kA  | 25       |  |  |  |
| Rated short-circuit breaking capacity Icu IEC 60947-2 at 400 V  |    | kA  | 25       |  |  |  |
| Voltage type  |    |     | AC       |  |  |  |
| Frequency   |    | Hz  | 50 - 60  |  |  |  |
| Current limiting class  |    |     | 3        |  |  |  |
| Suitable for flush-mounted installation   |    |     | No       |  |  |  |
| Concurrently switching N-neutral  |    |     | Yes      |  |  |  |
| Over voltage category   |    |     | 3        |  |  |  |
| Pollution degree  |    |     | 2        |  |  |  |
| Additional equipment possible   |    |     | Yes      |  |  |  |
| Width in number of modular spacings   |    |     | 6        |  |  |  |
| Built-in depth  |    | mm  | 75       |  |  |  |
| Degree of protection (IP)   |    |     | IP20     |  |  |  |
| Ambient temperature during operating  |    | °C  | -25 - 55 |  |  |  |
| Connectable conductor cross section multi-wired   |    | mm² | 2.5 - 50 |  |  |  |
| Connectable conductor cross section solid-core  |    | mm² | 2.5 - 50 |  |  |  |