### **DATASHEET - NZM3-XSR-R**



 $\label{eq:main_switch} \textbf{Main switch assembly kit, on the right side, red, size 3}$ 

Part no. Catalog No. NZM3-XSR-R 266658



Delivery program	
Equipment supplied	Door coupling rotary handle NZMXV4 extension shaft External warning plate/marking plate in German/English Black and yellow lightning symbol
Product range	Accessories
Accessories	Main switch assembly kit for side panel mounting
Standard/Approval	UL/CSA, IEC
Construction size	NZM3
Description	Kit for use as a main switch
Function	Actuation of the switch on the control panel side wall Switch mounting on mounting plate Red-yellow for emergency switching off
Protection class	IP66 UL/CSA Type 4X, Type 12
Door interlock	Lockable in the 0 position using up to 3 padlocks on the handle
Project planning information	External warning plate/designation label can be clipped on. For enhanced busbar tag shroud on the incomer side, please order IP2X protection against contact with a finger.
Actuation	Actuation on the right
For use with	NZM3(-4) PN3(-4), N(S)3(-4)

## Design verification as per IEC/EN 61439

IEUCK 01438 design verification   Image: Control of the status of the		
10.2.2 Corosion resistance   Meets the product standard's requirements.     10.2.3.1 Verification of thermal stability of enclosures   Meets the product standard's requirements.     10.2.3.2 Verification of resistance of insulating materials to abnormal heat and fire due to internal alectric effects   Meets the product standard's requirements.     10.2.3.3 Verification of resistance of insulating materials to abnormal heat and fire due to internal alectric effects   Meets the product standard's requirements.     10.2.4 Resistance to ultra-violet (UV) radiation   Meets the product standard's requirements.     10.2.5 Lifting   Does not apply, since the entire switchgear needs to be evaluated.     10.2.5 Lifting   Does not apply, since the entire switchgear needs to be evaluated.     10.2.7 Inscriptions   Does not apply, since the entire switchgear needs to be evaluated.     10.3.6 Receptoregae distances   Does not apply, since the entire switchgear needs to be evaluated.     10.4 Clearances and creepage distances   Does not apply, since the entire switchgear needs to be evaluated.     10.5 Protection against electric shock   Does not apply, since the entire switchgear needs to be evaluated.     10.5 Incorporation of switching devices and components   Does not apply, since the entire switchgear needs to be evaluated.     10.8 Connections for external conductors   Is the panel builder's responsibility.   Is the panel builder's responsibility. <	IEC/EN 61439 design verification	
10.2.3.1 Verification of thermal stability of enclosures   Meets the product standard's requirements.     10.2.3.2 Verification of resistance of insulating materials to abnormal heat and fire due to intermal electric effects   Meets the product standard's requirements.     10.2.3.4 Resistance to ultra-violet (UV) radiation   Meets the product standard's requirements.     10.2.4 Resistance to ultra-violet (UV) radiation   Meets the product standard's requirements.     10.2.4 Resistance to ultra-violet (UV) radiation   Meets the product standard's requirements.     10.2.5 Utfing   Dees not apply, since the entire switchgear needs to be evaluated.     10.2.5 Inscriptions   Dees not apply, since the entire switchgear needs to be evaluated.     10.4 Clearances and creepage distances   Meets the product standard's requirements.     10.5 Protection against electric shock   Dees not apply, since the entire switchgear needs to be evaluated.     10.6 Incorporation of switching devices and components   Meets the product standard's requirements.     10.8 Connections for external conductors   Meets the panel builder's responsibility.     10.8 Dome-frequency electric strength   Meets apply being the entire switchgear needs to be evaluated.     10.9 Thermal electrical circuits and of insulating material   Meets the panel builder's responsibility.     10.9 Thermal electrical circuits and connections   Employmediate is the panel builder	10.2 Strength of materials and parts	
10.2.3.2 Verification of resistance of insulating materials to abnormal heat   Meets the product standard's requirements.     10.2.3.3 Verification of resistance of insulating materials to abnormal heat   Meets the product standard's requirements.     10.2.4 Resistance to ultra-violet (UV) radiation   Meets the product standard's requirements.     10.2.5 Lifting   Does not apply, since the entire switchgear needs to be evaluated.     10.2.6 Mechanical impact   Does not apply, since the entire switchgear needs to be evaluated.     10.3.0 Egree of protection of ASSEMBLIES   Does not apply, since the entire switchgear needs to be evaluated.     10.4 Clearances and creepage distances   Does not apply, since the entire switchgear needs to be evaluated.     10.5 Protection against electric shock   Does not apply, since the entire switchgear needs to be evaluated.     10.5 Interrol electrical circuits and components   Does not apply, since the entire switchgear needs to be evaluated.     10.8 Connections for external conductors   Is the panel builder's responsibility.     10.9 Insulation properties   Is the panel builder's responsibility.     10.9.1 Short-circuit rating   Is the panel builder's responsibility.     10.11 Short-circuit rating   Is the panel builder's responsibility. The specifications for the switchgear must be observed.     10.12 Electromagnetic compatibility.   Is the panel builder's responsibility. The specif	10.2.2 Corrosion resistance	Meets the product standard's requirements.
10.2.3.3 Verification of resistance of insulating materials to abnormal heat and fire due to internal electric effects   Meets the product standard's requirements.     10.2.4 Resistance to ultra-violet (UV) radiation   Meets the product standard's requirements.     10.2.5 Lifting   Does not apply, since the entire switchgear needs to be evaluated.     10.2.6 Mechanical impact   Does not apply, since the entire switchgear needs to be evaluated.     10.3.0 Begree of protection of ASSEMBLIES   Does not apply, since the entire switchgear needs to be evaluated.     10.4 Clearances and creepage distances   Does not apply, since the entire switchgear needs to be evaluated.     10.5 Protection against electric shock   Does not apply, since the entire switchgear needs to be evaluated.     10.6 Incorporation of switching devices and components   Does not apply, since the entire switchgear needs to be evaluated.     10.8 Connections for external conductors   Is the panel builder's responsibility.     10.9 Insulation properties   Is the panel builder's responsibility.     10.9.1 Temperature rise   Is the panel builder's responsibility.     10.13 Mechanical function   Is the panel builder's responsibility.     10.12 Electromagnetic compatibility.   Is the panel builder's responsibility. The specifications for the switchgear must be observed.     10.13 Mechanical function   Is the panel builder's responsibility. The specifications fo	10.2.3.1 Verification of thermal stability of enclosures	Meets the product standard's requirements.
and fire due to internal electric effects       and fire due to internal electric effects     Meets the product standard's requirements.       102.5 Lifting     Does not apply, since the entire switchgear needs to be evaluated.       102.6 Mechanical impact     Does not apply, since the entire switchgear needs to be evaluated.       102.7 Inscriptions     Does not apply, since the entire switchgear needs to be evaluated.       103.0 Begree of protection of ASSEMBLIES     Does not apply, since the entire switchgear needs to be evaluated.       104.4 Clearances and creepage distances     Does not apply, since the entire switchgear needs to be evaluated.       105.5 Protection against electric shock     Does not apply, since the entire switchgear needs to be evaluated.       105.6 Incorporation of switching devices and components     Does not apply, since the entire switchgear needs to be evaluated.       106.1 Incorporation of switching devices and connections     Does not apply, since the entire switchgear needs to be evaluated.       107.1 Internal electrical circuits and connections     Does not apply, since the entire switchgear needs to be evaluated.       108.2 Power-frequency electric strength     Is the panel builder's responsibility.       109.3 Impulse withstand voltage     Is the panel builder's responsibility.       10.10 Temperature rise     Is the panel builder's responsibility.       10.11 Short-circuit rating     Is the	10.2.3.2 Verification of resistance of insulating materials to normal heat	Meets the product standard's requirements.
10.2.5 LiftingDoes not apply, since the entire switchgear needs to be evaluated.10.2.6 Mechanical impactDoes not apply, since the entire switchgear needs to be evaluated.10.2.7 InscriptionsMeets the product standard's requirements.10.3 Degree of protection of ASSEMBLIESDoes not apply, since the entire switchgear needs to be evaluated.10.4 Clearances and creepage distancesMeets the product standard's requirements.10.5 Protection against electric shockDoes not apply, since the entire switchgear needs to be evaluated.10.6 Incorporation of switching devices and componentsDoes not apply, since the entire switchgear needs to be evaluated.10.7 Internal electrical circuits and connectionsIs the panel builder's responsibility.10.8 Connections for external conductorsIs the panel builder's responsibility.10.9 Insulation propertiesIs the panel builder's responsibility.10.9.1 Subtand voltageIs the panel builder's responsibility.10.9.2 Power-frequency electric strengthIs the panel builder's responsibility.10.9.3 Impulse withstand voltageIs the panel builder's responsibility.10.9.4 Testing of enclosures made of insulating materialIs the panel builder's responsibility.10.10 Temperature riseIs the panel builder's responsibility.10.11 Short-circuit ratingIs the panel builder's responsibility. The specifications for the switchgear must be observed.10.12 Electromagnetic compatibility.Is the panel builder's responsibility. The specifications for the switchgear must be observed.10.13 Mechanical functionIs the device meets the requirements, provided the infor		Meets the product standard's requirements.
10.2.6 Mechanical impactDoes not apply, since the entire switchgear needs to be evaluated.10.2.7 InscriptionsMeets the product standard's requirements.10.3 Degree of protection of ASSEMBLIESDoes not apply, since the entire switchgear needs to be evaluated.10.4 Clearances and creepage distancesMeets the product standard's requirements.10.5 Protection against electric shockDoes not apply, since the entire switchgear needs to be evaluated.10.6 Incorporation of switching devices and componentsDoes not apply, since the entire switchgear needs to be evaluated.10.7 Internal electrical circuits and connectionsIs the panel builder's responsibility.10.8 Connections for external conductorsIs the panel builder's responsibility.10.9 Insulation propertiesIs the panel builder's responsibility.10.9 Insulation group electric strengthIs the panel builder's responsibility.10.9.1 Subtistand voltageIs the panel builder's responsibility.10.10 Temperature riseIs the panel builder's responsibility.10.11 Short-circuit ratingIs the panel builder's responsibility.10.12 Electromegnetic compatibilityIs the panel builder's responsibility. The specifications for the switchgear must be observed.10.13 Mechanical functionIs the panel builder's responsibility. The specifications for the switchgear must be observed.	10.2.4 Resistance to ultra-violet (UV) radiation	Meets the product standard's requirements.
10.2.7 Inscriptions   Meets the product standard's requirements.     10.3 Degree of protection of ASSEMBLIES   Does not apply, since the entire switchgear needs to be evaluated.     10.4 Clearances and creepage distances   Meets the product standard's requirements.     10.5 Protection against electric shock   Does not apply, since the entire switchgear needs to be evaluated.     10.6 Incorporation of switching devices and components   Does not apply, since the entire switchgear needs to be evaluated.     10.7 Internal electrical circuits and connections   Is the panel builder's responsibility.     10.8 Connections for external conductors   Is the panel builder's responsibility.     10.8 Power-frequency electric strength   Is the panel builder's responsibility.     10.9 Insulation properties   Is the panel builder's responsibility.     10.9.1 Power-frequency electric strength   Is the panel builder's responsibility.     10.9.2 Power-frequency electric strength   Is the panel builder's responsibility.     10.9.1 Temperature rise   The panel builder's responsibility.     10.10 Temperature rise   Is the panel builder's responsibility.     10.11 Short-circuit rating   Is the panel builder's responsibility. The specifications for the switchgear must be observed.     10.12 Electromagnetic compatibility   Is the panel builder's responsibility. The specifications for the switchgear must	10.2.5 Lifting	Does not apply, since the entire switchgear needs to be evaluated.
10.3 Degree of protection of ASSEMBLIESDees not apply, since the entire switchgear needs to be evaluated.10.4 Clearances and creepage distancesMeets the product standard's requirements.10.5 Protection against electric shockDoes not apply, since the entire switchgear needs to be evaluated.10.6 Incorporation of switching devices and componentsDoes not apply, since the entire switchgear needs to be evaluated.10.7 Internal electrical circuits and connectionsIs the panel builder's responsibility.10.8 Connections for external conductorsIs the panel builder's responsibility.10.9 Insulation propertiesIs the panel builder's responsibility.10.9.2 Power-frequency electric strengthIs the panel builder's responsibility.10.9.4 Testing of enclosures made of insulating materialIs the panel builder's responsibility.10.11 Short-circuit ratingIs the panel builder's responsibility. The specifications for the switchgear must be observed.10.12 Electromagnetic compatibilityIs the panel builder's responsibility. The specifications for the switchgear must be observed.10.13 Mechanical functionThe device meets the requirements, provided the information in the instruction	10.2.6 Mechanical impact	Does not apply, since the entire switchgear needs to be evaluated.
10.4 Clearances and creepage distances   Meets the product standard's requirements.     10.5 Protection against electric shock   Does not apply, since the entire switchgear needs to be evaluated.     10.6 Incorporation of switching devices and components   Does not apply, since the entire switchgear needs to be evaluated.     10.7 Internal electrical circuits and connections   Is the panel builder's responsibility.     10.8 Connections for external conductors   Is the panel builder's responsibility.     10.9.1 Insulation properties   Is the panel builder's responsibility.     10.9.2 Power-frequency electric strength   Is the panel builder's responsibility.     10.9.3 Impulse withstand voltage   Is the panel builder's responsibility.     10.10 Temperature rise   Is the panel builder's responsibility.     10.11 Short-circuit rating   Is the panel builder's responsibility.     10.12 Electromagnetic compatibility   Is the panel builder's responsibility. The specifications for the switchgear must be observed.     10.13 Mechanical function   The device meets the requirements, provide the information in the instruction	10.2.7 Inscriptions	Meets the product standard's requirements.
10.5 Protection against electric shockDoes not apply, since the entire switchgear needs to be evaluated.10.6 Incorporation of switching devices and componentsDoes not apply, since the entire switchgear needs to be evaluated.10.7 Internal electrical circuits and connectionsIs the panel builder's responsibility.10.8 Connections for external conductorsIs the panel builder's responsibility.10.9 Insulation propertiesIs the panel builder's responsibility.10.9.2 Power-frequency electric strengthIs the panel builder's responsibility.10.9.3 Impulse withstand voltageIs the panel builder's responsibility.10.10 Temperature riseThe panel builder's responsibility.10.11 Short-circuit ratingIs the panel builder's responsibility. The specifications for the switchgear must be observed.10.12 Electromagnetic compatibilityIs the panel builder's responsibility. The specifications for the switchgear must be observed.10.13 Mechanical functionThe device meets the requirements, provided the information in the instruction	10.3 Degree of protection of ASSEMBLIES	Does not apply, since the entire switchgear needs to be evaluated.
10.6 Incorporation of switching devices and componentsDoes not apply, since the entire switchgear needs to be evaluated.10.7 Internal electrical circuits and connectionsIs the panel builder's responsibility.10.8 Connections for external conductorsIs the panel builder's responsibility.10.9 Insulation propertiesIs the panel builder's responsibility.10.9.2 Power-frequency electric strengthIs the panel builder's responsibility.10.9.3 Impulse withstand voltageIs the panel builder's responsibility.10.9.4 Testing of enclosures made of insulating materialIs the panel builder's responsibility.10.10 Temperature riseThe panel builder's responsibility.10.11 Short-circuit ratingIs the panel builder's responsibility. The specifications for the switchgear must be observed.10.12 Electromagnetic compatibilityIs the panel builder's responsibility. The specifications for the switchgear must be observed.10.13 Mechanical functionThe device meets the requirements, provided the information in the instruction	10.4 Clearances and creepage distances	Meets the product standard's requirements.
10.7 Internal electrical circuits and connectionsIs the panel builder's responsibility.10.8 Connections for external conductorsIs the panel builder's responsibility.10.9 Insulation propertiesIs the panel builder's responsibility.10.9.2 Power-frequency electric strengthIs the panel builder's responsibility.10.9.3 Impulse withstand voltageIs the panel builder's responsibility.10.9.4 Testing of enclosures made of insulating materialIs the panel builder's responsibility.10.10 Temperature riseThe panel builder's responsibility.10.11 Short-circuit ratingIs the panel builder's responsibility. The specifications for the switchgear must be observed.10.12 Electromagnetic compatibilityIs the panel builder's responsibility. The specifications for the switchgear must be observed.10.13 Mechanical functionThe device meets the requirements, provide the information in the instruction	10.5 Protection against electric shock	Does not apply, since the entire switchgear needs to be evaluated.
10.8 Connections for external conductors   Is the panel builder's responsibility.     10.9 Insulation properties   Is the panel builder's responsibility.     10.9.2 Power-frequency electric strength   Is the panel builder's responsibility.     10.9.3 Impulse withstand voltage   Is the panel builder's responsibility.     10.9.4 Testing of enclosures made of insulating material   Is the panel builder's responsibility.     10.10 Temperature rise   The panel builder's responsibility.     10.11 Short-circuit rating   Is the panel builder's responsibility. The specifications for the switchgear must be observed.     10.12 Electromagnetic compatibility   Is the panel builder's responsibility. The specifications for the switchgear must be observed.     10.13 Mechanical function   The device meets the requirements, provided the information in the instruction	10.6 Incorporation of switching devices and components	Does not apply, since the entire switchgear needs to be evaluated.
10.9 Insulation propertiesImage: Properties of the panel builder's responsibility.10.9.2 Power-frequency electric strengthIs the panel builder's responsibility.10.9.3 Impulse withstand voltageIs the panel builder's responsibility.10.9.4 Testing of enclosures made of insulating materialIs the panel builder's responsibility.10.10 Temperature riseIs the panel builder is responsibility.10.11 Short-circuit ratingIs the panel builder's responsibility. The specifications for the switchgear must be observed.10.12 Electromagnetic compatibilityIs the panel builder's responsibility. The specifications for the switchgear must be observed.10.13 Mechanical functionThe device meets the requirements, provided the information in the instruction	10.7 Internal electrical circuits and connections	Is the panel builder's responsibility.
10.9.2 Power-frequency electric strength   Is the panel builder's responsibility.     10.9.3 Impulse withstand voltage   Is the panel builder's responsibility.     10.9.4 Testing of enclosures made of insulating material   Is the panel builder's responsibility.     10.10 Temperature rise   Is the panel builder's responsibility.     10.11 Short-circuit rating   Is the panel builder's responsibility. The specifications for the switchgear must be observed.     10.12 Electromagnetic compatibility   Is the panel builder's responsibility. The specifications for the switchgear must be observed.     10.13 Mechanical function   The device meets the requirements, provide the information in the instruction	10.8 Connections for external conductors	Is the panel builder's responsibility.
10.9.3 Impulse withstand voltage   Is the panel builder's responsibility.     10.9.4 Testing of enclosures made of insulating material   Is the panel builder's responsibility.     10.10 Temperature rise   Is the panel builder's responsibility.     10.11 Short-circuit rating   Is the panel builder's responsibility.     10.12 Electromagnetic compatibility   Is the panel builder's responsibility.     10.13 Mechanical function   In the panel builder's responsibility.	10.9 Insulation properties	
10.9.4 Testing of enclosures made of insulating material   Is the panel builder's responsibility.     10.10 Temperature rise   Is the panel builder's responsible for the temperature rise calculation. Eaton will provide heat dissipation data for the devices.     10.11 Short-circuit rating   Is the panel builder's responsibility. The specifications for the switchgear must be observed.     10.12 Electromagnetic compatibility   Is the panel builder's responsibility. The specifications for the switchgear must be observed.     10.13 Mechanical function   The device meets the requirements, provide the information in the instruction	10.9.2 Power-frequency electric strength	Is the panel builder's responsibility.
10.10 Temperature rise   The panel builder is responsible for the temperature rise calculation. Eaton will provide heat dissipation data for the devices.     10.11 Short-circuit rating   Is the panel builder's responsibility. The specifications for the switchgear must be observed.     10.12 Electromagnetic compatibility   Is the panel builder's responsibility. The specifications for the switchgear must be observed.     10.13 Mechanical function   The device meets the requirements, provide the information in the instruction	10.9.3 Impulse withstand voltage	Is the panel builder's responsibility.
10.11 Short-circuit rating Is the panel builder's responsibility. The specifications for the switchgear must be observed.   10.12 Electromagnetic compatibility Is the panel builder's responsibility. The specifications for the switchgear must be observed.   10.13 Mechanical function The device meets the requirements, provide the information in the instruction	10.9.4 Testing of enclosures made of insulating material	Is the panel builder's responsibility.
10.12 Electromagnetic compatibility Is the panel builder's responsibility. The specifications for the switchgear must be observed.   10.13 Mechanical function The device meets the requirements, provided the information in the instruction	10.10 Temperature rise	
10.13 Mechanical function The device meets the requirements, provided the information in the instruction	10.11 Short-circuit rating	
	10.12 Electromagnetic compatibility	
	10.13 Mechanical function	

#### **Technical data ETIM 7.0**

Low-voltage industrial components (EG000017) / Handle for power circuit breaker (EC000229)

Electric engineering, automation, process control engineering / Low-voltage switch technology / Circuit breaker (LV < 1 kV) / Handle for switch devices (ecl@ss10.0.1-27-37-04-14 [AKF012014])		
Lockable	Yes	
Colour	Red	
Suitable for emergency stop	Yes	
With extension shaft	Yes	
Suitable for power circuit breaker	Yes	
Suitable for switch disconnector	Yes	

#### **Approvals**

Product Standards UL489; CSA-C22.2 No. 5-09; IEC60947, CE marking	
UL File No. E140305	
UL Category Control No. DIHS	
CSA File No. 022086	
CSA Class No. 1437-01	
North America Certification UL listed, CSA certified	
Degree of Protection IEC: IP66, UL/CSA Type 4X, 12	

# Dimensions

