



Miniature circuit breaker (MCB), 2.5 A, 4p, characteristic: C

Part no. FAZ-C2,5/4
Catalog No. 279050
Alternate Catalog No. FAZ-C2.5/4
EL-Nummer (Norway) 0001691148

Similar to illustration

Delivery program

| | | | |
|---|----------|----|--|
| Basic function | | | Miniature circuit-breakers |
| Number of poles | | | 4 pole |
| Tripping characteristic | | | C |
| Application | | | Switchgear for industrial and advanced commercial applications |
| Rated current | I_n | A | 2.5 |
| Rated switching capacity acc. to IEC/EN 60947-2 | I_{cu} | kA | 15 |
| Product range | | | FAZ |

Technical data

Electrical

| | | | |
|---|----------|------|-------------|
| Rated switching capacity acc. to IEC/EN 60947-2 | I_{cu} | kA | 15 |
| Breaking capacity according to UL | | kA | 10 (UL1077) |
| Max operational voltage according to IEC/EN 60947-2 | | V AC | 440 |
| Rated switching capacity according to IEC/EN 60947-2 (max operational voltage) | I_{cu} | kA | 10 |
| Rated service short-circuit breaking capacity according to IEC/EN 60947-2 (max operational voltage) | I_{cs} | | 7,5 kA |
| Rated voltage according to IEC/EN 60898-1 | U_n | V AC | 415 |
| Rated switching capacity according to IEC/EN 60898-1 | I_{cn} | kA | 10 |
| Rated service short-circuit breaking capacity according to IEC/EN 60898-1 | I_{cs} | | 7,5 kA |

Design verification as per IEC/EN 61439

| | | | |
|--|------------|----|--|
| Technical data for design verification | | | |
| Rated operational current for specified heat dissipation | I_n | A | 2.5 |
| Heat dissipation per pole, current-dependent | P_{vid} | W | 0 |
| Equipment heat dissipation, current-dependent | P_{vid} | W | 6 |
| Static heat dissipation, non-current-dependent | P_{vs} | W | 0 |
| Heat dissipation capacity | P_{diss} | W | 0 |
| Operating ambient temperature min. | | °C | -40 |
| Operating ambient temperature max. | | °C | 75 |
| linear, per +1 °C, results in a 0.5% reduction of current carrying capacity | | | |
| IEC/EN 61439 design verification | | | |
| 10.2 Strength of materials and parts | | | |
| 10.2.2 Corrosion resistance | | | Meets the product standard's requirements. |
| 10.2.3.1 Verification of thermal stability of enclosures | | | Meets the product standard's requirements. |
| 10.2.3.2 Verification of resistance of insulating materials to normal heat | | | Meets the product standard's requirements. |
| 10.2.3.3 Verification of resistance of insulating materials to abnormal heat and fire due to internal electric effects | | | Meets the product standard's requirements. |
| 10.2.4 Resistance to ultra-violet (UV) radiation | | | Meets the product standard's requirements. |
| 10.2.5 Lifting | | | Does not apply, since the entire switchgear needs to be evaluated. |
| 10.2.6 Mechanical impact | | | Does not apply, since the entire switchgear needs to be evaluated. |
| 10.2.7 Inscriptions | | | Meets the product standard's requirements. |
| 10.3 Degree of protection of ASSEMBLIES | | | Does not apply, since the entire switchgear needs to be evaluated. |
| 10.4 Clearances and creepage distances | | | Meets the product standard's requirements. |
| 10.5 Protection against electric shock | | | Does not apply, since the entire switchgear needs to be evaluated. |

| | | |
|--|--|--|
| 10.6 Incorporation of switching devices and components | | Does not apply, since the entire switchgear needs to be evaluated. |
| 10.7 Internal electrical circuits and connections | | Is the panel builder's responsibility. |
| 10.8 Connections for external conductors | | Is the panel builder's responsibility. |
| 10.9 Insulation properties | | |
| 10.9.2 Power-frequency electric strength | | Is the panel builder's responsibility. |
| 10.9.3 Impulse withstand voltage | | Is the panel builder's responsibility. |
| 10.9.4 Testing of enclosures made of insulating material | | Is the panel builder's responsibility. |
| 10.10 Temperature rise | | The panel builder is responsible for the temperature rise calculation. Eaton will provide heat dissipation data for the devices. |
| 10.11 Short-circuit rating | | Is the panel builder's responsibility. The specifications for the switchgear must be observed. |
| 10.12 Electromagnetic compatibility | | Is the panel builder's responsibility. The specifications for the switchgear must be observed. |
| 10.13 Mechanical function | | The device meets the requirements, provided the information in the instruction leaflet (IL) is observed. |

Technical data ETIM 7.0

| | | | |
|--|-----------------|--|----------|
| Circuit breakers and fuses (EG000020) / Miniature circuit breaker (MCB) (EC000042) | | | |
| Electric engineering, automation, process control engineering / Electrical installation, device / Miniature circuit breaker system (MCB) / Miniature circuit breaker (MCB) (ec1@ss10.0.1-27-14-19-01 [AAB905014]) | | | |
| Release characteristic | | | C |
| Number of poles (total) | | | 4 |
| Number of protected poles | | | 4 |
| Rated current | A | | 2.5 |
| Rated voltage | V | | 400 |
| Rated insulation voltage Ui | V | | 440 |
| Rated impulse withstand voltage Uimp | kV | | 4 |
| Rated short-circuit breaking capacity Icn EN 60898 at 230 V | kA | | 10 |
| Rated short-circuit breaking capacity Icn EN 60898 at 400 V | kA | | 10 |
| Rated short-circuit breaking capacity Icu IEC 60947-2 at 230 V | kA | | 15 |
| Rated short-circuit breaking capacity Icu IEC 60947-2 at 400 V | kA | | 15 |
| Voltage type | | | AC |
| Frequency | Hz | | 50 - 60 |
| Current limiting class | | | 3 |
| Suitable for flush-mounted installation | | | No |
| Concurrently switching N-neutral | | | No |
| Over voltage category | | | 3 |
| Pollution degree | | | 2 |
| Additional equipment possible | | | Yes |
| Width in number of modular spacings | | | 4 |
| Built-in depth | mm | | 70.5 |
| Degree of protection (IP) | | | IP20 |
| Ambient temperature during operating | °C | | -25 - 75 |
| Connectable conductor cross section multi-wired | mm ² | | 1 - 25 |
| Connectable conductor cross section solid-core | mm ² | | 1 - 25 |

Additional product information (links)

| | |
|----------------------------------|---|
| Temperature dependency, derating | https://www.eaton.com/content/dam/eaton/technicaldocumentation/technical-data-tables/Derating table FAZ.pdf |
|----------------------------------|---|