# **DATASHEET - CI-PKZ01**



Insulated enclosure, IP40\_x, for PKZ01

CI-PKZ01 Part no. Catalog No. 281403 Alternate Catalog XTPBXENCS40

**EL-Nummer** 4365000

(Norway)



# **Delivery program**

Product range	Accessories
Subrange	Surface mounting enclosures
Accessories	Insulated enclosures for PKZ
Degree of Protection	IP40
For use with	PKZM01 +NHI-E or VHI-PKZ01 +U or A or NHI +L (2 off)

Notes With integrated PE(N) terminal.

In each case 2 metric M25 cable entry knockouts with thread top and bottom.

2 metric M20 cable entry knockouts in the rear wall. Hard mirror with cable entry knockouts which can be cut out.

## **Design verification as per IEC/EN 61439**

I <sub>n</sub> P <sub>vid</sub> P <sub>vid</sub> P <sub>vid</sub> P <sub>vs</sub> P <sub>diss</sub>	A W W W C C C	0 0 0 0 10 -25
P <sub>vid</sub> P <sub>vid</sub> P <sub>vs</sub>	w w w	0 0 0 10 -25
P <sub>vid</sub>	W W °C	0 0 10 -25
P <sub>vs</sub>	W W °C	0 10 -25
	w °C	10 -25
P <sub>diss</sub>	°C	-25
	°C	70
		Meets the product standard's requirements.
		Meets the product standard's requirements.
		Meets the product standard's requirements.
		Meets the product standard's requirements.
		Please enquire
		Does not apply, since the entire switchgear needs to be evaluated.
		Does not apply, since the entire switchgear needs to be evaluated.
		Meets the product standard's requirements.
		Does not apply, since the entire switchgear needs to be evaluated.
		Meets the product standard's requirements.
		Does not apply, since the entire switchgear needs to be evaluated.
		Does not apply, since the entire switchgear needs to be evaluated.
		Is the panel builder's responsibility.
		Is the panel builder's responsibility.
		Is the panel builder's responsibility.
		Is the panel builder's responsibility.
		Is the panel builder's responsibility.
		The panel builder is responsible for the temperature rise calculation. Eaton will provide heat dissipation data for the devices.
		Is the panel builder's responsibility. The specifications for the switchgear must be observed.

10.12 Electromagnetic compatibility	Is the panel builder's responsibility. The specifications for the switchgear must be observed.
10.13 Mechanical function	The device meets the requirements, provided the information in the instruction leaflet (IL) is observed.

#### **Technical data ETIM 7.0**

Low-voltage industrial components (EG000017) / Empty enclosure for switchgear (EC000712)


Electric engineering, automation, process control engineering / Low-voltage switch technology / Component for low-voltage switching technology / Empty housing for switch devices (ecl@ss10.0.1-27-37-13-01 [AKN343014])

	Plastic
mm	97
mm	160
mm	80
	No
	No
	Surface mounting
	IP40
	Other
	mm

# **Approvals**

Specially designed for North America		No
--------------------------------------	--	----

#### **Dimensions**



## **Additional product information (links)**

Motor starters and "Special Purpose Ratings" for the North American market

Busbar Component Adapters for modern Industrial control panels

http://www.eaton.eu/ecm/groups/public/@pub/@europe/@electrical/documents/content/pct\_3258146.pdf http://www.moeller.net/binary/ver\_techpapers/ver960en.pdf