DATASHEET - DTZ8,0(*/*)*



Three-phase control isolating safety transformer, 8 kVA, Rated input voltage 50 - 950 \pm 5 % V, Rated output voltage 18.5 - 1000 V



Part no. DTZ8,0(*/*)*
Catalog No. 914811
Alternate Catalog -

Delivery program

Zonio, program		
Product range		Three-phase DTZ control transformers
Rated input voltage	V	$50 - 950 \pm 5 \%$
Rated output voltage	V	18.5 – 1000
Rated power	kVA	8
Short-time rating	kVA	20
Cu factor 18 00		

Notes

- Enclosure IP65 on request.

When ordering, the part no. must include the following details:

DTZ0.1(*/*)*

1. Wildcard ≙ Nominal input voltage

2nd Wildcard ≙ Nominal output voltage

3rd Wildcard

Configuration

Ordering example

- · desired part no. DTZ0.1
- Desired rated input voltage 200 V
- Desired rated output voltage 18.5 V
- Desired configuration Dy(n)5

The correct part no. is

DTZ0.1(200/18.5)DY(N)5

Additional tappings → 931897

Design verification as per IEC/EN 61439

Design verification as per ILG/LIN 01433			
Technical data for design verification			
Rated operational current for specified heat dissipation	In	Α	0
Heat dissipation per pole, current-dependent	P _{vid}	W	0
Equipment heat dissipation, current-dependent	P _{vid}	W	0
Static heat dissipation, non-current-dependent	P _{vs}	W	310
Heat dissipation capacity	P _{diss}	W	0
Operating ambient temperature min.		°C	-25
Operating ambient temperature max.		°C	40
EC/EN 61439 design verification			
10.2 Strength of materials and parts			
10.2.2 Corrosion resistance			Meets the product standard's requirements.
10.2.3.1 Verification of thermal stability of enclosures			Meets the product standard's requirements.
10.2.3.2 Verification of resistance of insulating materials to normal heat			Meets the product standard's requirements.
10.2.3.3 Verification of resistance of insulating materials to abnormal heat and fire due to internal electric effects $$			Meets the product standard's requirements.
10.2.4 Resistance to ultra-violet (UV) radiation			Meets the product standard's requirements.
10.2.5 Lifting			Does not apply, since the entire switchgear needs to be evaluated.
10.2.6 Mechanical impact			Does not apply, since the entire switchgear needs to be evaluated.
10.2.7 Inscriptions			Meets the product standard's requirements.
10.3 Degree of protection of ASSEMBLIES			Does not apply, since the entire switchgear needs to be evaluated.

10.4 Clearances and creepage distances	Meets the product standard's requirements.
10.5 Protection against electric shock	Does not apply, since the entire switchgear needs to be evaluated.
10.6 Incorporation of switching devices and components	Does not apply, since the entire switchgear needs to be evaluated.
10.7 Internal electrical circuits and connections	Is the panel builder's responsibility.
10.8 Connections for external conductors	Is the panel builder's responsibility.
10.9 Insulation properties	
10.9.2 Power-frequency electric strength	Is the panel builder's responsibility.
10.9.3 Impulse withstand voltage	Is the panel builder's responsibility.
10.9.4 Testing of enclosures made of insulating material	Is the panel builder's responsibility.
10.10 Temperature rise	The panel builder is responsible for the temperature rise calculation. Eaton will provide heat dissipation data for the devices.
10.11 Short-circuit rating	Is the panel builder's responsibility. The specifications for the switchgear must be observed.
10.12 Electromagnetic compatibility	Is the panel builder's responsibility. The specifications for the switchgear must be observed.
10.13 Mechanical function	The device meets the requirements, provided the information in the instruction leaflet (IL) is observed.


Technical data ETIM 7.0


Technical data ETIM 7.0		
$Low-voltage\ industrial\ components\ (EG000017)\ /\ Three-phase\ control\ transformer\ (EC000017)\ /\ Three-phase\ control\ transformer\ (EC0000017)\ /\ Three-phase\ control\ transformer\ (EC000017)\ /\ Three-phase\ control\ transformer\ (EC000017)\ /\ Three-phase\ control\ transformer\ (EC0000017)\ /\ Three-phase\ control\ transformer\ (EC00000017)\ /\ Three-phase\ control\ transformer\ (EC00000017)\ /\ Three-phase\ control\ transformer\ (EC000000000000000000000000000000000000$	002485)	
Electric engineering, automation, process control engineering / Transformer, converted	r, coil / Control transfo	ormer / Three-phase control transformer (ecl@ss10.0.1-27-03-13-01 [AAB619015])
Built as safety transformer		Yes
Built as isolating transformer		Yes
Built as energy saving transformer		No
Primary voltage 1	V	50 - 950
Primary voltage 2	V	50 - 950
Primary voltage 3	V	50 - 950
Primary voltage 4	V	50 - 950
Primary voltage 5	V	50 - 950
Primary voltage 6	V	50 - 950
Primary voltage 7	V	0 - 0
Primary voltage 8	V	0 - 0
Primary voltage 9	V	0 - 0
Primary voltage 10	V	0 - 0
Secondary voltage 1	V	18.5 - 1000
Secondary voltage 2	V	18.5 - 1000
Secondary voltage 3	V	18.5 - 1000
Secondary voltage 4	V	18.5 - 1000
Secondary voltage 5	V	18.5 - 1000
Secondary voltage 6	V	18.5 - 1000
Secondary voltage 7	V	0 - 0
Secondary voltage 8	V	0 - 0
Secondary voltage 9	V	0 - 0
Secondary voltage 10	V	0 - 0
Wiring system		Other
Rated power	VA	8000
Type of insulation material acc. IEC 85		В
Short-circuit-proof		No
Relative short circuit voltage	%	4
Conductor material		Copper
Width	mm	390
Height	mm	374
Depth	mm	200
Degree of protection (IP)		IP00
Degree of protection (NEMA)		Other

Approvals

Approvais	
Product Standards	IEC/EN 61558-2-2; CE marking
UL File No.	-
UL Category Control No.	XPTQ2, XPTQ8
CSA File No.	-
CSA Class No.	-
North America Certification	-
Specially designed for North America	No
Suitable for	Branch circuits
Max. Voltage Rating	600 V AC
Degree of Protection	IEC: IP00, UL/CSA Type: -

Dimensions





	b	С
18.5 V	200	374
24 V	200	374
42 V	200	374
110 V	184	374
230-690 V	184	374

- ① The higher rated operating voltage applies ② Terminals ≦ 25 A ③ Connection lugs > 63 A