



Declaration of conformity

For the following equipment :

Product Name: LED driver

Model Designation: IDLC-45x-y (x=Blank or A; y=350, 500, 700, 1050,1400)
 IDLC-65x-y (x=Blank or A; y=700, 1050, 1400, 1750)
 ODLC-45x-y (x=Blank or A; y=350, 500, 700, 1050,1400)
 ODLC-65x-y (x=Blank or A; y=700, 1050, 1400, 1750)
 IDLC-45-yDA (y=350, 500, 700, 1050,1400)
 IDLC-65-yDA (y=700, 1050, 1400, 1750)
 ODLC-45-yDA (y=350, 500, 700, 1050,1400)
 ODLC-65-yDA (y=700, 1050, 1400, 1750)

is herewith confirmed to comply with the requirements set out in the Council Directive, the following standards were applied :

RoHS Directive (2011/65/EU)

Energy-Related Products Directive (2009/125/EC)

Implementing measure COMMISSION REGULATION(EC) No 1194/2012

Low Voltage Directive (2014/35/EU) :

EN 61347-1:2008+A1:2011+A2:2013 EN61347-2-13:2014

EN 62384:2006+A1:2009

ENEC certificate No: 351003.01

Electromagnetic Compatibility Directive (2014/30/EU) :

EMI (Electro-Magnetic Interference)

Conducted emission / Radiated emission

EN55015:2013

Harmonic current

EN61000-3-2: 2014

Class C(≥60% load)

Voltage flicker

EN61000-3-3: 2013

EMS (Electro-Magnetic Susceptibility)

EN61547:2009

ESD air

EN61000-4-2:2009

Level 3

8KV

ESD contact

EN61000-4-2:2009

Level 2

4KV

RF field susceptibility

EN61000-4-3:2006+A1:2008+A2:2010

Level 2

3V/m

EFT bursts

EN61000-4-4:2012

Level 2

1KV/5KHz

Surge susceptibility

EN61000-4-5:2014

Level 3

Line-Line 1KV

Conducted susceptibility

EN61000-4-6:2014

Level 2

3V

Magnetic field immunity

EN61000-4-8:2010

Level 2

3A/m

Voltage dip, interruption

EN61000-4-11:2004

30% dip 10 periods

100% interruptions 0.5 periods

Note:

Component power supply will be operated with a final equipment. Since EMC performance will be affected by the complete installation, the final equipment manufacturers must re-qualify EMC Directive on the complete installation again.

Tests above are only to be performed with LEDs.

For guidance on how to perform these EMC tests, please refer to TDF (Technical Documentation File).

This Declaration is effective from serial number HB7xxxxxxx

Person responsible for marking this declaration :

MEAN WELL (Guangzhou) Electronics Co., Ltd.

(Manufacturer Name)

2/F, A Building, Yuean Ind. Park, Huangcun, Dongpu Town, Tianhe District, Guangzhou, China

(Manufacturer Address)

Howay_Lin/ Engineering Manager :

(Name / Position)

Howay Lin
(Signature)

Frank_Peng/ RD Manager :

(Name / Position)

Frank Peng
(Signature)

GuangZhou

(Place)

May. 31, 2017

(Date)